

Lincoln Elementary (Water Boiler)

Write down the number for pressure and temp, not just an "X"

If you need to call in a job sheet, make sure you write down the work order # on this report.

Initials:		Twice Daily		Daily		Twice Daily		Daily			
		Boiler Pressure (0-30 lbs)	Boiler Temp. (80-190)	Air Comp. Pressure, # on the gauge & operation	Walk-in Freezer & Cooler	Boiler Pressure (0-30 lbs)	Boiler Temp. (80-190)	Air Comp. Pressure, # on the gauge & operation	Walk-in Freezer & Cooler		
1	am					17	am				
	pm						pm				
2	am					18	am				
	pm						pm				
3	am					19	am				
	pm						pm				
4	am					20	am				
	pm						pm				
5	am					21	am				
	pm						pm				
6	am					22	am				
	pm						pm				
7	am					23	am				
	pm						pm				
8	am					24	am				
	pm						pm				
9	am					25	am				
	pm						pm				
10	am					26	am				
	pm						pm				
11	am					27	am				
	pm						pm				
12	am					28	am				
	pm						pm				
13	am					29	am				
	pm						pm				
14	am					30	am				
	pm						pm				
15	am					31	am				
	pm						pm				
16	am					Post this report in the boiler room & write your findings daily or as indicated. At the end of the month, share with your principal & email to dsdcustodial@dsdmail.net or fax to ext. 27881.					
	pm										

Each individual boiler requires a separate report throughout the year.

The Boiler Room is **NOT** to be used for storage. Keep **ALL COMBUSTIBLE MATERIAL OUT** of the room! **Nightly Lock-Up: Ensure the boiler is on prior to locking up for the night.**

Boiler# U _____

Boiler Room Inspection Report

School Lincoln El
 Month/Year _____

Water Boiler

Twice a Week

	1st Week - 2 times	2nd Week - 2 times	3rd Week - 2 times	4th Week - 2 times
1 Check water softener				

Every Week

	1st Week	2nd Week	3rd Week	4th Week
1 Observe boiler through firing cycle				
2 a) Check air compressor oil level				

Check heating pumps for:

3 a) bearing noise				
b) leaking seals				
c) correct pressure				

Check domestic hot water pumps for:

4 a) Broken couplers				
b) Motor mounts				
c) Leaks				
5 Sweep floor, dust equipment & piping. (If not asbestos)				

Every Month

1 Oil domestic hot water pumps & motors				
2 Check for leaks on heating equipment & associated piping.				
3 Check digital reading on water heater for error codes & temps. In excess of 135. Report any problems/concerns.				
4 Blow down mud legs				
5 Emergency lights in bldg.				
Fan Room				
6 Check oil on heat pumps				
Check filters				

Every other month

1 Check pop-off valve operation				
---------------------------------	--	--	--	--

Concerns/Issues regarding your boiler(s) & room:
