

**Addendum #1 Lodi Unified School District  
Prop 39 Year 3-5 Lighting Project**

The following items shall be considered and accounted for in all responding Contractors' proposals for the Prop 39 Year 3-5 Lighting Project at Lodi Unified School District.

**Retrofit Kit Options** – A portion of the project at both sites call for the use of retrofit kits on troffer fixtures. The Client will consider alternatives to the kits including Type A, B and C tubes. Contractors shall provide specifications for all equipment being proposed.

**Ballast Replacement** – For all retrofits that include a fixture mounted power supply (LED driver, power supply ballast, etc.), the existing ballast shall be replaced 100% of the time.

**Energy Savings** – Responding contractors electing to offer a solution other than the retrofit kits shall provide energy savings estimates in their proposal. To determine savings, use utility cost data and burn hours identified in the McNair and Bear Creek Appendix 1 files located on the District website.

**Rebates/Incentives** – Responding contractors shall include a current estimate for anticipated rebates as well as any available incentives based upon their proposed scope of work. If the proposed retrofit is not eligible for rebates or incentives please note this in the response. Responding contractors shall include cost in their proposal for the management of the rebate process.

**Occupancy Control** – Contractors shall provide occupancy control in areas that do not currently have control. A file has been uploaded to the District Prop page with the name "McNair & Bear Creek – Add OCS List" identifying specifically where OCS should be added. For all existing OCS it is assumed that 100% of the systems are operational.

**Exterior Lighting Control** – Contractors shall include photocontrol or astronomical time switch device that turns off all lighting when sufficient daylight is available.

**Title 24/Code Compliance** – All work proposed shall comply with Title 24 and all applicable building codes

**RFP Due Date** – The deadline to respond to this RFP and the bid opening has been extended to May 24, 2018 at 11:00am to Facilities and Planning. Accordingly, all dates in the RFP have been delayed one week.