

Bear Creek HS - Add Occupancy Sensors to Control Selected Lighting

#	Area ID	Fixture Type	Existing Watts/ Fixt	# Fixt	Lamps per Fixture	Sensor W/C	# OCS
163	B Bldg: B Staff Office	Recessed 2'x4'	89	4	3	C	1
164	B Bldg: Classroom B1	Pendant	89	20	3	C	1
162	B Bldg: Classroom B2	Pendant	89	20	3	C	1
160	B Bldg: Classroom B3	Pendant	89	20	3	C	1
159	B Bldg: Classroom B4	Pendant	89	15	3	C	1
161	B Bldg: Classroom B5	Pendant	89	20	3	C	1
165	B Bldg: Classroom B6	Pendant	89	15	3	C	1
187	D Bldg: Classroom D1	Pendant	89	24	3	C	1
170	D Bldg: Classroom D10	Pendant	89	15	3	C	1
182	D Bldg: Classroom D2	Pendant	89	15	3	C	1
181	D Bldg: Classroom D4	Pendant	89	30	3	C	1
178	D Bldg: Classroom D5	Pendant	89	15	3	C	1
177	D Bldg: Classroom D6	Pendant	89	15	3	C	1
174	D Bldg: Classroom D7	Pendant	89	15	3	C	1
172	D Bldg: Classroom D8	Pendant	89	15	3	C	1
171	D Bldg: Classroom D9	Pendant	89	15	3	C	1
179	D Bldg: D Staff Office by D4	Recessed 2'x4'	89	3	3	C	1
175	D Bldg: D Staff Office by D7	Recessed 2'x4'	89	3	3	C	1
173	D Bldg: D Workroom, D12	Recessed 2'x4'	89	3	3	C	1
199	E Bldg: Classroom E1	Pendant	89	23	3	C	1
193	E Bldg: Classroom E2	Pendant	89	18	3	C	1
192	E Bldg: Classroom E3	Pendant	89	15	3	C	1
190	E Bldg: Classroom E4	Pendant	89	15	3	C	1
189	E Bldg: Classroom E5	Pendant	89	15	3	C	1
191	E Bldg: E Staff Office, E13	Recessed 2'x4'	89	3	3	C	1
196	E Bldg: Rm E6 Lab	Pendant	89	10	3	C	1
14	H Bldg: Admin, Mail Rm, H27	Recessed 2'x4'	89	4	3	C	1
17	I Bldg: Library, Librarian, I11	Recessed 2'x4'	59	2	2	C	1
15	I Bldg: Library, Office, I2	Recessed 2'x4'	89	4	3	C	1
20	I Bldg: Library, PC Lab, I4	Pendant	59	50	2	C	1
22	I Bldg: Library, Work, I6	Recessed 2'x4'	59	2	2	C	1
4	K Bldg: Classroom K2	Pendant	89	15	3	C	1
3	K Bldg: Classroom K3	Recessed 2'x4'	59	15	2	C	1
1	K Bldg: Classroom K4	Pendant	89	15	3	C	1
2	K Bldg: K Work Experience	Recessed 2'x4'	89	3	3	C	1
7	K Bldg: K1	Pendant	89	15	3	C	1
5	K Bldg: Office K6	Recessed 2'x4'	89	2	3	C	1
52	L Bldg: Art Class., L20	Pendant	89	24	3	C	1
45	L Bldg: Band Class., L1	Pendant	89	28	3	C	1
43	L Bldg: Choral/Music Class., L9/L28	Pendant	89	28	3	C	1
51	L Bldg: Classroom, L21	Pendant	89	8	3	C	1
29	L Bldg: Clay Rm, L17	Recessed 2'x4'	59	3	2	C	1

	35	L Bldg: Crafts Class., L14	Pendant	89	28	3	C	1
	36	L Bldg: Ensemble, L11	Recessed 2'x4'	59	4	2	C	1
e	28	L Bldg: Materials, L18	Recessed 2'x4'	59	3	2	C	1
	39	L Bldg: Music Office, L10	Recessed 2'x4'	59	2	3	C	1
	42	L Bldg: Music Office, L5	Recessed 2'x4'	89	2	3	C	1
	32	L Bldg: Music, L4	Recessed 2'x4'	89	4	3	C	1
	30	L Bldg: Staff Office, L16	Recessed 2'x4'	59	2	2	C	1
	31	L Bldg: Staff Office, L16	Recessed 1'x4'	59	1	2	C	0
	50	L Bldg: Work, L22	Surface 1'x4'	59	2	2	C	1
	64	N Bldg East - Caf.: Cafeteria, N6	Surface 1'x4'	234	28	4	C	1
	66	N Bldg East - Caf.: Cafeteria, N6	Recessed 1'x1'	215	12	1	C	1
	63	N Bldg East - Caf.: Dry Storage, N16	Surface 1'x4'	59	8	2	C	1
	53	N Bldg East - Caf.: Faculty Dining, N13	Pendant	89	21	3	C	1
	62	N Bldg East - Caf.: Kitchen Office, N20	Recessed 2'x4'	59	2	2	C	1
	71	N Bldg East - Caf.: Tickets, N5	Recessed 2'x4'	59	6	2	C	1
	72	O Bldg - Lockers: Athletics Director, O7	Recessed 2'x4'	89	4	3	C	1
	85	O Bldg - Lockers: Boy's Coach Office, O17	Recessed 2'x4'	89	6	3	C	1
	74	O Bldg - Lockers: Conference, O13	Recessed 2'x4'	89	3	3	C	1
e	92	O Bldg - Lockers: Girl's Coach Office, O3	Recessed 2'x4'	89	6	3	C	1
	96	P Bldg Addition: Workout Room	Recessed 2'x4'	59	15	2	C	1
	95	P Bldg: Student Activities, P1	Pendant	89	32	3	C	1
	145	Pool Bldg: Weight Rm	Pendant	59	32	2	C	1
	146	Pool Bldg: Weight Rm	Recessed 2'x4'	59	15	2	C	1
	218	Portable Classroom: A28	Recessed 2'x4'	112	12	4	C	1
	217	Portable Classroom: A29	Recessed 2'x4'	112	12	4	C	1
	216	Portable Classroom: A30	Recessed 2'x4'	112	12	4	C	1
	215	Portable Classroom: A31	Recessed 2'x4'	112	10	4	C	1
	228	Portable Classroom: T1	Recessed 2'x4'	112	10	4	C	1
	220	Portable Classroom: T10	Recessed 2'x4'	112	10	4	C	1
	219	Portable Classroom: T11	Recessed 2'x4'	112	10	4	C	1
	227	Portable Classroom: T2	Recessed 2'x4'	112	10	4	C	1
	226	Portable Classroom: T3	Recessed 2'x4'	112	10	4	C	1
	225	Portable Classroom: T4	Recessed 2'x4'	112	10	4	C	1
	224	Portable Classroom: T5	Recessed 2'x4'	112	10	4	C	1
	223	Portable Classroom: T7	Recessed 2'x4'	112	10	4	C	1
	222	Portable Classroom: T8	Recessed 2'x4'	112	10	4	C	1
	221	Portable Classroom: T9	Recessed 2'x4'	112	10	4	C	1
	151	Q Bldg: Center Work Rm Q13	Pendant	59	12	2	C	1
	147	Q Bldg: Center Work Rm Q14	Recessed 2'x4'	59	10	2	C	1
	152	Q Bldg: Science Q12	Recessed 2'x4'	59	6	2	C	1
	150	Q Bldg: Storage, Q20	Recessed 2'x4'	59	5	2	C	1
	139	Snack Bar: Snack Bar	Surface 1'x4'	59	3	2	C	1
	134	Theatre Bldg: Book Storage, Rm 119	Recessed 2'x4'	59	10	2	C	1
	109	Theatre Bldg: Dance/Wrestling, Rm 118	Recessed 2'x4'	59	28	2	C	1
	138	Theatre Bldg: Rm 503	Recessed 2'x4'	112	10	4	C	1
TOTAL					1,067			86

