

McNair HS: Add Occupancy Sensors to Control Selected Lighting

#	Area ID	Fixture Type	Existing Watts/ Fixt	# Fixt	Lamps per Fixture	Sensor W/C	# OCS
1	A Bldg: 1st Floor: A108	Recessed 2'X4'	50	12	2	C	1
2	A Bldg: 1st Floor: A130A Testing	Recessed 2'X4'	50	2	2	C	1
3	A Bldg: 1st Floor: A140	Recessed 2'X4'	50	3	2	C	1
4	A Bldg: 1st Floor: AA1 Registration	Recessed 2'X4'	50	3	2	C	1
5	A Bldg: 1st Floor: AA12	Can Recessed	45	3	2	C	1
6	A Bldg: 1st Floor: AA17	Strip 4' Wrap	50	3	2	C	1
7	A Bldg: 1st Floor: AA19	Strip 4' Wrap	50	2	2	C	1
8	A Bldg: 1st Floor: AA2	Strip 4' Wrap	50	3	2	C	1
9	A Bldg: 1st Floor: AA20	Strip 4' Wrap	50	1	2	C	1
10	A Bldg: 1st Floor: AA23 Copy	Recessed 2'X4'	50	6	2	C	1
11	A Bldg: 1st Floor: AA27	Recessed 2'X4'	50	2	2	C	1
12	A Bldg: 1st Floor: AA28 Nurse	Recessed 2'X4'	50	2	2	C	1
13	A Bldg: 1st Floor: AA3	Recessed 2'X4'	50	2	2	C	1
14	A Bldg: 1st Floor: AA32 Attendance	Recessed 2'X4'	50	4	2	C	1
15	A Bldg: 1st Floor: AA37	Pendant D/ID	50	24	2	C	1
16	A Bldg: 1st Floor: AA41	Recessed 2'X4'	50	2	2	C	1
17	A Bldg: 1st Floor: AA7	Recessed 2'X4'	50	3	2	C	1
18	A Bldg: 1st Floor: AA9	Recessed 2'X4'	50	2	2	C	1
19	A Bldg: 1st Floor: AB4 Library	Pendant D/ID	50	37	2	C	3
20	A Bldg: 1st Floor: AB7	Recessed 2'X4'	50	10	2	C	1
21	A Bldg: 1st Floor: AB8	Strip 4' Wrap	50	2	2	C	1
22	A Bldg: 1st Floor: AB9	Strip 4' Wrap	50	1	2	C	1
24	A Bldg: 1st Floor: AC121a	Strip 4' Wrap	50	1	2	C	1
27	A Bldg: 1st Floor: AD11	Strip 4' Wrap	50	3	2	C	1
28	A Bldg: 1st Floor: AD12	Strip 4' Wrap	50	2	2	C	1
29	A Bldg: 1st Floor: AD14 Kitchen	Strip 4' Wrap	50	4	2	C	1
30	A Bldg: 1st Floor: AD15	Strip 4' Wrap	50	1	2	C	1
31	A Bldg: 1st Floor: AD3	Recessed 2'X4'	50	2	2	C	1
32	A Bldg: 1st Floor: AD3A Work Area	Recessed 2'X4'	50	4	2	C	1
33	A Bldg: 1st Floor: AE5	Recessed 2'X4'	50	4	2	C	1
34	A Bldg: 1st Floor: AF13	Strip 4' Wrap	50	1	2	C	1
35	A Bldg: 1st Floor: AF17	Strip 4' Wrap	50	1	2	C	1
37	A Bldg: 1st Floor: AG17	Strip 4' Wrap	50	1	2	C	1
38	A Bldg: 1st Floor: AG19	Strip 4' Wrap	50	1	2	C	1
39	A Bldg: 1st Floor: AH17	Strip 4' Wrap	50	1	2	C	1
41	A Bldg: 1st Floor: AH19	Strip 4' Wrap	50	1	2	C	1
42	A Bldg: 1st Floor: Reception Main Entry	Can Recessed	45	12	2	C	1
43	A Bldg: 2nd Floor: A235	Recessed 2'X4'	50	28	2	C	1
47	A Bldg: 2nd Floor: AJ8	Strip 4' Wrap	50	1	2	C	1
48	A Bldg: 2nd Floor: AK9 Break Rm	Recessed 2'X4'	50	3	2	C	1
49	A Bldg: 2nd Floor: AM13	Strip 4' Wrap	50	1	2	C	1
50	A Bldg: 2nd Floor: AN13	Strip 4' Wrap	50	1	2	C	1

51	A Bldg: 2nd Floor: AN19	Strip 4' Cage	25	2	1	C	1
52	A Bldg: 2nd Floor: AP1 Work Area	Recessed 2'X4'	50	24	2	C	1
53	A Bldg: 2nd Floor: AP17	Strip 4' Wrap	50	1	2	C	1
56	B Bldg: B14 Receiving	Strip 4' Cage	25	6	1	C	1
57	B Bldg: B15 Staff Dining	Recessed 2'X4'	50	7	2	C	1
58	B Bldg: B17 MPR	Pendant D/ID	50	144	2	C	1
59	B Bldg: B17 MPR Café	Can Recessed 8"	66	2	2	C	1
60	B Bldg: B17 MPR Entry	SM 1'X4'	50	2	2	C	1
61	B Bldg: B20 Student Store	Recessed 2'X4'	50	4	2	C	1
66	B Bldg: B4 Dry Storage	Strip 4' Cage	25	4	1	C	1
67	B Bldg: B5 Snack Bar	Strip 4' Wrap	50	4	2	C	1
68	B Bldg: B6 Food Court	Strip 4' Wrap	50	15	2	C	1
69	B Bldg: B8 Kitchen Office	SM 1'X4'	50	2	2	C	1
73	C Bldg: C10	Recessed 2'X2'	33	6	2	C	1
74	C Bldg: C104 Weight Rm	Pendant	50	40	2	C	1
75	C Bldg: C105 Wrestling	Pendant	50	40	2	C	1
81	C Bldg: C7	Strip 4' Wrap	50	2	2	C	1
82	C Bldg: C9 Lobby	Pendant	50	16	2	C	1
84	D Bldg: D102 Band	Recessed 2'X4'	50	30	2	C	1
85	D Bldg: D103 Drama	Strip 4' Wrap	50	23	2	C	1
86	D Bldg: D104 Backstage	SM Troffer 2'x4'	74	21	3	C	1
94	D Bldg: D17	Strip 4' Wrap	50	1	2	C	1
96	D Bldg: D2 Chior	Recessed 2'X4'	50	34	2	C	1
97	D Bldg: D21 Drama Office	Strip 4' Wrap	50	2	2	C	1
98	D Bldg: D22 Costumes	Strip 4' Wrap	50	2	2	C	1
99	D Bldg: D23 Control Rm	Can Recessed 8"	66	7	2	C	1
104	D Bldg: D28	Strip 4' Wrap	50	1	2	C	1
107	D Bldg: D34/D20	Strip 4' Wrap	50	7	2	C	1
108	D Bldg: D35	Strip 4' Wrap	50	3	2	C	1
109	D Bldg: D37	Strip 4' Wrap	50	2	2	C	1
110	D Bldg: D39 Control Rm	Can Recessed 8"	66	6	2	C	1
111	D Bldg: D4 Office	Strip 4' Wrap	50	4	2	C	1
112	D Bldg: D40 Foyer	Can Recessed 8"	66	7	2	C	1
114	D Bldg: D43 Theater Lobby	Can Recessed 8"	66	10	2	C	1
116	E Bldg: E101	Recessed 2'X4'	50	22	2	C	1
117	E Bldg: E102	Recessed 2'X4'	50	12	2	C	1
118	E Bldg: E103	Recessed 2'X4'	50	12	2	C	1
122	E Bldg: E6 Office	Strip 4'	50	1	2	C	1
128	Portables: P-1	Recessed 2'X4'	50	12	2	C	1
129	Portables: P-10	Recessed 2'X4'	50	10	2	C	1
130	Portables: P-2	Recessed 2'X4'	50	10	2	C	1
131	Portables: P-3	Recessed 2'X4'	50	10	2	C	1
132	Portables: P-4	Recessed 2'X4'	50	10	2	C	1
133	Portables: P-5	Recessed 2'X4'	50	10	2	C	1
134	Portables: P-6	Recessed 2'X4'	50	10	2	C	1
135	Portables: P-7	Recessed 2'X4'	50	10	2	C	1
136	Portables: P-8	Recessed 2'X4'	50	10	2	C	1

137	Portables: P-9	Recessed 2'X4'	50	10	2	C	1
TOTAL				832			92