

Bennett Lead Testing Results

Bldg	Area	Description	Results
Bennett	Café	Water Fountain Bottle Filler	1.0 U
Bennett	Café	Water Fountain Bubbler	1.0 U
Bennett	Kitchen	2-Bay Stainless Sink	1.0 U
Bennett	Kitchen	1-Bay Stainless Sink	2.5
Bennett	Kitchen	Hand Wash Sink	1.0 U
Bennett	Boiler Rm	Custodial Sink	7.8
Bennett	Girls Toilet	near Boiler Room Sink Faucet	2.5
Bennett	Boys Toilet	near Boiler Room Sink Faucet	4.0
Bennett	Room 28	Left Sink Faucet	3.8
Bennett	Room 28	Right Sink Faucet	3.9
Bennett	Room 26	Left Sink Faucet	2.8
Bennett	Room 26	Right Sink Faucet	3.1
Bennett	Room 24	Sink Faucet	14.0
Bennett	Health Of	Sink Faucet	5.1
Bennett	Health Of	TR Sink Faucet	1.1
Bennett	Principal	TR Sink Faucet	20.0
Bennett	Main Off	Water Fountain	1.0 U
Bennett	Room 12	Sink Faucet	8.1
Bennett	Room 12	Bubbler	160.0
Bennett	Room 10	Sink Faucet	9.6
Bennett	Room 10	Bubbler	97.0
Bennett	Room 8	Sink Faucet	13.0
Bennett	Room 8	Bubbler	6.6
Bennett	Room 6	Sink Faucet	6.8
Bennett	Room 6	Bubbler	7.8
Bennett	Room 4	Sink Faucet	3.9
Bennett	Room 4	Bubbler	49.0
Bennett	Room 2	Sink Faucet	2.0
Bennett	Room 2	Bubbler	19.0
Bennett	Room 1	Stainless Sink Left Faucet	1.5
Bennett	Room 1	Stainless Sink Right Faucet	4.7
Bennett	Room 1	Sink Faucet	3.2
Bennett	Room 1	Bubbler	2900.0
Bennett	Room 3	Sink Faucet	3.3
Bennett	Room 3	Bubbler	19.0
Bennett	Room 5	Sink Faucet	26.0
Bennett	Room 5	Bubbler	120.0
Bennett	Room 7	Sink Faucet	27.0
Bennett	Room 7	Bubbler	220.0
Bennett	Room 9	Sink Faucet	230.0
Bennett	Room 9	Bubbler	180.0
Bennett	Room 11	Sink Faucet	22.0
Bennett	Girls Toilet	Front Hall Left Sink Faucet	4.5
Bennett	Girls Toilet	Front Hall Left Middle Sink	4.0
Bennett	Girls Toilet	Front Hall Right Middle Sink	6.7
Bennett	Girls Toilet	Front Hall Right Sink Faucet	36.0
Bennett	Men's TR	Front Hall Sink	8.7

Bennett Lead Testing Results

Bennett	Men'sTR	Front Hall Slop Sink	6.2
Bennett	Boys Toilet	Front Hall Left Sink Faucet	22.0
Bennett	Boys Toilet	Front Hall Left Middle Sink	3.2
Bennett	Boys Toilet	Front Hall Right Middle Sink	3.8
Bennett	Boys Toilet	Front Hall Right Sink Faucet	1.5
Bennett	Staff TR	Front Hall Women Sink Faucet	1.1
Bennett	Room 13	Sink Faucet	9.0
Bennett	Courtyard	Hose Bib	24.0
Bennett	Staff TR	Rear Hall Men's Sink Faucet	1.7
Bennett	Staff TR	Rear Hall Women's Sink Faucet	3.7
Bennett	Girls Toilet	Rear Hall Left Sink Faucet	3.5
Bennett	Girls Toilet	Rear Hall Right Sink Faucet	1.0 U
Bennett	Boys Toilet	Rear Hall Left Sink Faucet	1.9
Bennett	Boys Toilet	Rear Hall Right Sink Faucet	1.0 U
Bennett	Rear Hall	Water Fountain Left	1.0 U
Bennett	Rear Hall	Water Fountain Right	1.0 U
Bennett	Room 30	Sink Faucet	1.9
Bennett	Room 30	Bubbler	1.0 U
Bennett	Room 32	Sink Faucet	1.0 U
Bennett	Room 32	Bubbler	1.0 U
Bennett	Room 34	Sink Faucet	1.2
Bennett	Room 34	Bubbler	1.0 U
Bennett	Room 36	Sink Faucet	1.0 U
Bennett	Room 36	Bubbler	1.0 U
Bennett	Room 38	Sink Faucet	1.0 U
Bennett	Room 38	Bubbler	1.0 U
Bennett	Room 40	Sink Faucet	1.0 U
Bennett	Room 39	Sink Faucet	1.0 U
Bennett	Room 39	Bubbler	1.0 U
Bennett	Room 37	Sink Faucet	1.0 U
Bennett	Room 37	Bubbler	1.0 U
Bennett	Room 35	Sink Faucet	74.0
Bennett	Room 35	Bubbler	1.0 U
Bennett	Room 33	Sink Faucet	1.0 U
Bennett	Room 33	Bubbler	1.0 U
Bennett	Room 31	Sink Faucet	1.0 U
Bennett	Room 31	Bubbler	1.0 U

Middle School-High School Lead Testing Results

Area	Description	Location	Results
HS	Gym Lobby	Men's TR Sink Faucet	3.3
HS	Gym Lobby	Women's TR Sink Faucet	2.7
HS	HS Boy's Locker Room	TR Sink Faucet	22.0
HS	HS Boy's Locker Room	Cust. Sink Faucet	5.2
HS	HS Girl's Locker Room	Left Sink Faucet	4.1
HS	HS Girl's Locker Room	Right Sink Faucet	2.6
HS	HS Girl's Locker Room	Cust. Sink Faucet	14.0
HS	Kitchen Serving Area	Left Sink Faucet	1.0 U
HS	Kitchen Serving Area	Right Sink Faucet	4.9
HS	Kitchen Sink	Near Ice Machine	2.8
HS	Kitchen Groen	Left Pot Filler	1.0 U
HS	Kitchen Groen	Right Pot Filler	1.1
HS	Kitchen	2 Bay Prep Sink Faucet	2.4
HS	Kitchen	3 Bay Left Sink Faucet	5.6
HS	Kitchen	3 Bay Right Sink Faucet	2.8
HS	Kitchen	TR Sink Faucet	1.0 U
HS	Kitchen	Cust. Sink Faucet	5.8
HS	Cafeteria	Water Fountain	1.0 U
HS	Cafeteria	Right Water Fountain	1.0 U
HS	Cafeteria	Girl's TR Left Sink Faucet	1.0 U
HS	Cafeteria	Girl's TR Right Sink Faucet	1.0 U
HS	Cafeteria	Boy's TR Left Sink Faucet	1.0 U
HS	Cafeteria	Boy's TR Right Sink Faucet	1.0 U
HS	Guidance	TR Sink Faucet	2.1
HS	Math Hall	Cust. Mop Sink Faucet	5.1
HS	Math Hall	Men's TR Left Sink Faucet	1.7
HS	Math Hall	Men's TR Right Sink Faucet	14.0
HS	Math Hall	Women's TR Left Sink Faucet	15.0
HS	Math Hall	Women's TR L/M Sink Faucet	290.0
HS	Math Hall	Women's TR R/M Sink Faucet	6.7
HS	Math Hall	Women's TR Right Sink Faucet	6.2
HS	Math Hall	Older Water Fountain (Left)	2.2
HS	Math Hall	Water Fountain Bubbler	1.0 U
HS	Math Hall	Water Fountain Filter	1.0 U
HS	Science Hall	Women's TR Sink Faucet	4.5
HS	Science Hall	Men's TR Sink Faucet	2.7
HS	Science Hall	Men's TR Left Sink Faucet	40.0
HS	Science Hall	Men's TR Middle Sink Faucet	9.8
HS	Science Hall	Men's TR Right Sink Faucet	20.0
HS	Science Hall	Cust. Sink Faucet	2.5
HS	Science Hall	Women's TR Left Sink Faucet	86.0
HS	Science Hall	Women's TR Middle Sink Fauc.	1.0 U
HS	Science Hall	Women's TR Right Sink Faucet	1.6
HS	Science Hall	Old Water Fountain	5.5
IIS	Science Hall	New Water Fountain Bubbler	1.0 U
HS	Science Hall	New Water Fountaini Filler	1.0 U
HS	Room 94	2-Bay Left Sink Faucet	8.6
HS	Room 94	2-Bay Right Sink Faucet	9.4
HS	Room 96	Left Sink Faucet	3.0
HS	Room 97	Sink Faucet	3.8
HS	Room 98	TR Sink Faucet	4.1
HS	Room 100	Sink Faucet	10.0
HS	Lower 28 Hall	Men's TR Left Sink Faucet	21.0
HS	Lower 28 Hall	Men's TR Right Sink Faucet	5.1
HS	Lower 28 Hall	Women's TR Left Sink	2.4

Middle School-High School Lead Testing Results

HS	Lower 28 Hall	Women's TR Middle Sink	1.8
HS	Lower 28 Hall	Women's TR Right Sink	4.0
HS	Lower 28 Hall	Cust. Sink Faucet	13.0
HS	A.D.s Office	TR Sink Faucet	6.7
HS	Principal's Office	TR Sink Faucet	3.8
HS	Main Office	TR Sink Faucet	2.1
HS	Main Hall	Water Fountain Bubbler	1.0 U
HS	Main Hall	Water Fountain Filler	1.0 U
HS	Main Hall	Staff Men's TR Left Sink Faucet	1.2
HS	Main Hall	Staff Men's TR Right Sink	1.0 U
HS	Main Hall	Staff Women's TR Left Sink	1.1
HS	Main Hall	Staff Women's TR Right Sink	1.0 U
HS	HS Nurse Office	Stainless Sink Faucet	1.0 U
HS	HS Health Office	TR Sink Faucet	1.7
HS	Room 126	TR Sink Faucet	10.0
HS	Room 122	Corner Office Sink Faucet	190.0
HS	Room 122	Small Office Sink Faucet	160.0
HS	Basement	Custodial Sink Faucet	1.6
HS	TR near B&G Office	Left Sink Faucet	1.1
HS	TR near B&G Office	Right Sink Faucet	2.4
HS	TR near B&G Office	Custodial Sink Faucet	3.9
HS	B&G Office	Stainless Sink Faucet	1.0 U
HS	B&G Break Room	Sink Faucet	2.0
HS	Adm.	Front TR Sink Faucet	1.0 U
HS	Adm.	Rear TR Sink Faucet	1.0 U
HS	Adm.	Break Room Sink Faucet	1.0 U
HS	Superintendent Office	TR Sink Faucet	1.0 U
MS	MS Boy's Locker Room	Left Sink Faucet	2.4
MS	MS Boy's Locker Room	Right Sink Faucet	3.4
MS	MS Boy's Locker Room	Coach's Sink	3.1
MS	MS Gym	Water Fountain	5.8
MS	MS Girl's Locker Room	Left Sink Faucet	51.0
MS	MS Girl's Locker Room	Right Sink Faucet	42.0
MS	MS Girl's Locker Room	Coach's Sink	4.7
MS	Lower MS Hall	Boy's TR Left Sink Faucet	3.4
MS	Lower MS Hall	Boy's TR Right Sink Faucet	9.2
MS	Lower MS Hall	Cust. Sink Faucet	6.8
MS	Lower MS Hall	Water Fountain near Room	1.0 U
MS	Lower MS Hall	Water Fountain near Room	1.0 U
MS	Room 145	Sink Faucet	4.6
MS	Room 145	2-Bay Sink 1	1.7
MS	Room 145	2-Bay Sink 2	1.6
MS	Room 145	2-Bay Sink 3	1.5
MS	Room 145	2-Bay Sink 4	1.0 U
MS	Water Fountain	Near Room 152 Bubbler	1.0 U
MS	Water Fountain	Near Room 152 Filler	1.0 U
MS	Room 152	Sink Faucet	3.5
MS	Upper MS Boy's TR	Left Sink Faucet	38.0
MS	Upper MS Boy's TR	Right Sink Faucet	32.0
MS	Upper MS hall	Cust. Sink Faucet	25.0
MS	Upper MS Girl's TR	Left Sink Faucet	10.0
MS	Upper MS Girls TR	Right Sink Faucet	17.0
MS	Room 163	1-Bay Sink Faucet	15.0
MS	Room 163	Left Corner Sink A Faucet	3.2
MS	Room 163	Left Middle Sink B Faucet	1.7
MS	Room 163	Right Middle Sink C Faucet	3.0

Middle School-High School Lead Testing Results

MS	Room 163	Right Corner Sink K Faucet	6.9
MS	Room 124	Stainless Sink Faucet	1.6
MS	Room 124	TR Sink Faucet	1.8
MS	Room 044	Left Sink Faucet	8.7
MS	Room 044	Right Sink Faucet	7.9
MS	Room 045	Left Sink Faucet	29.0
MS	Room 045	Middle Sink Faucet	26.0
MS	Room 045	Right Sink Faucet	5.4

Phoenicia Lead Testing Results

Bldg	Area	Description	Results
PH	Room 16	Mod. Sink Faucet	1.6
PH	Room 15	Mod. Sink Faucet	7.4
PH	Room 15	Mod. Bubbler	2.8
PH	Cust. Stor	Utlity Sink Faucet	1.0 U
PH	Kitchen	2-Bay Sink Faucet	2.5
PH	Kitchen	3-Bay Sink Faucet Left	4.2
PH	Kitchen	3-Bay Sink Faucet Right	1.4
PH	Kitchen	Toilet Room Sink Faucet	27.0
PH	Boy's Rm.	Left Sink Faucet	1.3
PH	Boy's Rm.	Middle Sink Faucet	2.8
PH	Boy's Rm.	Right Sink Faucet	3.5
PH	Girl's Rm.	Left Sink Faucet	1.5
PH	Girl's Rm.	Middle Sink Faucet	1.3
PH	Girl's Rm.	Right Sink Faucet	2.1
PH	Room 1	Sink Faucet	27.0
PH	Room 1	Bubbler	5.3
PH	Room 3	Sink Faucet	2.0
PH	Room 3	Bubbler	4.2
PH	Room 5	Sink Faucet	5.2
PH	Room 5	Bubbler	5.7
PH	Room 7	Sink Faucet	4.6
PH	Room 7	Bubbler	3.4
PH	Room 9	Sink Faucet	5.4
PH	Room 9	Bubbler	6.4
PH	Room 15	Sink Faucet	5.8
PH	Room 11	Bubbler	7.0
PH	Room 11	Sink Faucet	8.0
PH	Room 13	Sink Faucet	6.6
PH	Room 13	Bubbler	3.3
PH	Room 14	Sink Faucet	1.6
PH	Room 14	Bubbler	1.0 U
PH	Room 14	TR Sink Faucet	2.0
PH	Room 12	Sink Faucet	3.6
PH	Room 12	Bubbler	5.5
PH	Room 12	TR Sink Faucet	6.8
PH	Room 10	Sink Faucet	8.8
PH	Room 10	Bubbler	4.4
PH	Room 10	TR Sink Faucet	19.0
PH	Room 8	Sink Faucet	4.8
PH	Room 8	Bubbler	2.5
PH	Room 6	Sink Faucet	3.1
PH	Room 6	Bubbler	2.7
PH	Room 4	Sink Faucet	4.2
PH	Room 4	Bubbler	2.7
PH	Room 2	Sink Faucet	10.0

Phoenicia Lead Testing Results

PH	Room 2	Bubbler	7.2
PH	Teachers Lounge	Sink	1.9
PH	Faculty Bath-Ladies	Sink	2.7
PH	Faculty Bath-Mens	Sink	7.1
PH	Gym Bathroom	Sink	3.6
PH	Comp. Lab Bath	Sink	5.2
PH	Lobby	Drinking Fountain	1.0 U
PH	Main Office	Sink	13.0
PH	Nurse Bath	Sink	2.9
PH	Nurse Office	Sink	5.1
PH	Hall Near Baths	Drinking Fountain	1.0 U

Woodstock Lead Testing Results

Bldg	Area	Description	Results
Woodstock	Health Of	TR Sink Faucet	1.6
Woodstock	Health Of	Sink Faucet	1.0 U
Woodstock	Room 21	Bubbler	2.8
Woodstock	Room 21	Sink Faucet	1.4
Woodstock	Room 21	TR Sink Faucet	3.5
Woodstock	Room 29	Sink Faucet	3.5
Woodstock	Main Off	TR Sink Faucet	1.6
Woodstock	Room 16	Sink Faucet	1.0 U
Woodstock	Room 18	Cast Fe Sink Faucet	1.0 U
Woodstock	Room 18	Utility Sink Faucet	1.0 U
Woodstock	Room 19	Sink Faucet	1.0 U
Woodstock	Fac. Room	Sink Faucet	1.9
Woodstock	Fac. Room	TR Right Front Hall Sink Faucet	1.1
Woodstock	Fac. Room	TR Left Front Hall Sink Faucet	1.0 U
Woodstock	B's TR	Front Hall Left Sink Faucet	1.0 U
Woodstock	B's TR	Front Hall Right Sink Faucet	1.0 U
Woodstock	Closet	Front Hall custodial sink faucet	39.0
Woodstock	G's TR	Front Hall Left Sink Faucet	1.0 U
Woodstock	G's TR	Front Hall Right Sink Faucet	850.0
Woodstock	Room 17	Sink Faucet	1.3
Woodstock	Room 17	Bubbler	28.0
Woodstock	Front Hall	Water fountain	1.0 U
Woodstock	Room 15	Sink Faucet	1.0 U
Woodstock	Room 15	Bubbler	1.0 U
Woodstock	Mid Hall	Left Water Fountain Bottle Filt	1.0 U
Woodstock	Mid Hall	Left Fountain Bubbler	1.0 U
Woodstock	Mid Hall	Right Water Fountain	1.0 U
Woodstock	Mid Hall	G's TR Left Sink Faucet	1.0 U
Woodstock	Mid Hall	G's TR Right Sink Faucet	1.0 U
Woodstock	Mid Hall	B's TR Left Sink Faucet	1.0 U
Woodstock	Mid Hall	B's TR Right Sink Faucet	1.0 U
Woodstock	Mid Hall	B's TR Custodial Sink Faucet	1.0 U
Woodstock	Room 14	Sink Faucet	1.6
Woodstock	Room 14	Bubbler	1.0 U
Woodstock	Room 13	Sink Faucet	1.3
Woodstock	Room 13	Bubbler	1.0 U
Woodstock	Room 12	Sink Faucet	3.9
Woodstock	Room 10	Sink Faucet	13.0
Woodstock	Room 10	Bubbler	1.0 U
Woodstock	Kitchen	TR Sink Faucet	1.0 U
Woodstock	Kitchen	3-Bay Sink Left Faucet	1.0 U
Woodstock	Kitchen	3-Bay Sink Right Faucet	1.0 U
Woodstock	Kitchen	Custodial Sink Faucet	3.1
Woodstock	Kitchen	Hose Bib	14.0
Woodstock	Gym	Water fountain	1.0 U
Woodstock	Gym	Coach's TR Sink Faucet	8.5
Woodstock	Room 11	TR Sink Faucet	2.6
Woodstock	Room 11	Sink Faucet	18.0
Woodstock	Room 11	Bubbler	1600.0

Woodstock Lead Testing Results

Woodstock	Room 9	TR Sink Faucet	3.7
Woodstock	Room 9	Sink Faucet	130.0
Woodstock	Room 9	Bubbler	1500.0
Woodstock	Room 9	Utility Sink Faucet	120.0
Woodstock	Room 7	TR Sink Faucet	1.6
Woodstock	Room 7	Sink Faucet	14.0
Woodstock	Room 7	Bubbler	1.4
Woodstock	Room 5	TR Sink Faucet	3.3
Woodstock	Room 5	Sink Faucet	1.6
Woodstock	Room 5	Bubbler	1.7
Woodstock	Room 3	TR Sink Faucet	1.5
Woodstock	Room 3	Sink Faucet	4.1
Woodstock	Room 3	Bubbler	3.1
Woodstock	Room 1	TR Sink Faucet	1.0 U
Woodstock	Room 1	Sink Faucet	1.0 U
Woodstock	Room 1	Bubbler	1.0 U
Woodstock	Room 2	TR Sink Faucet	14.0
Woodstock	Room 2	Sink Faucet	1.3
Woodstock	Room 2	Bubbler	1.0 U
Woodstock	Room 4	TR Sink Faucet	1.1
Woodstock	Room 4	Sink Faucet	1.4
Woodstock	Room 4	Bubbler	2.3
Woodstock	Room 6	TR Sink Faucet	1.2
Woodstock	Room 6	Sink Faucet	1.8
Woodstock	Room 6	Bubbler	1.3
Woodstock	Rom 6	Sink Faucet	1.9
Woodstock	Room 6	Bubbler	2.0
Woodstock	Rear Hall	B's TR Sink Faucet	1.8
Woodstock	Rear Hall	G's TR Sink Faucet	1.4
Woodstock	Outside	Hose Bib outside cafeteria	22.0