

**Addendum 1**  
**Bid 19-016-Chiller Compressor Replacement at Apache Elementary**

To: Vendors

From: Shawnee Mission School District

Date: April 1, 2019

RE: Addendum 1- Bid 19-016-Chiller Compressor Replacement at Apache Elementary

1. Please note that the correct chiller and installation for the chiller should be a **Smardt with Turbocor TT300 compressor** not a Daikin TT400 compressor.
2. Please note the bid due date will now be Friday, April 5, 2019 at 2:00 pm.