

April 17, 2019

**SOLICITATION ADDENDUM NO. 2**  
**ITB 19-0013**

**General Contractor for Montclair Elementary School Classroom Re-Flooring**

**THE FOLLOWING CHANGES/ADDITIONS TO THE ABOVE CITED SOLICITATION ARE ANNOUNCED:**

This Addendum modifies the Invitation to Bid (ITB) document(s) only to the extent indicated herein. All other areas not changed or otherwise modified by this Addendum shall remain in full force and effect. This Addendum is hereby made an integral part of the ITB document. Bidder must be responsive to any requirements of this Addendum as if the requirements were set forth in the ITB. Failure to do so may result in Bid rejection. See the ITB regarding requests for clarification or change and protests of this Addendum, and the deadlines for the foregoing.

This addendum is to be acknowledged in the space provided on the Bidder Certification form supplied in the solicitation document. Failure to acknowledge receipt of this addendum may be cause to reject your offer.

The closing date **REMAINS UNCHANGED: April 24, 2019 at 2:00 PM Pacific Time**

**CHANGES:**

1. Attachment K – Montclair Floor Plan replaced with Attachment K – Montclair Floor Plan Addendum 2.

**CLARIFICATIONS:**

Questions Submitted via Email

Question: Do you have a bid threshold below which bid security is not required, or is bid security required for all bids?

Answer: Bid Security is required for all Bids.

Question: Will there be additional patch and paint required that wouldn't be a result of the flooring demo and installation?

Answer: No. Any additional patching or painting required will be completed by the District.

Question: There is the Attachment K Floor Plan, and the Attachment K Floor Plan Addendum 1? We were having trouble distinguishing what the distinction between the (2) attachments is? Could you please clarify?

Answer: Please see CHANGES item one (1) above.

Question: In the ITB; Section II letter d. states "Install 11 (40' linear ft. Total) mechanically fastened, non-ferrous metal transition strips at classroom doorways and VCT tile hallway as specified in the attached flooring index."; although, there is no depiction as to where exactly these doorways are. I see multiple doorways that lead to outside but none that lead out into the hallways. Please Specify where these doorways are located.

Answer: The transition strip in the hallway is not located at a doorway but rather at the junction of where existing VCT tile meets existing carpet. This transition is located outside and south of the doorway to room #100. Please see attached marked site map and photo for exact location. All ther transitions are at exterior doorways as shown on the site map.

**-END of Addendum**

Justin Sweet  
Contract Specialist