

YR 3-5 2016 – 19 HVAC – DSA – FOUR SITE PROJECT

ADDENDUM #2:

1. Official Bid documents are DSA stamped. PDF's of these drawings are included in this Addendum. PDF's replace the original Bid documents. All changes to the documents have been clouded for reference. Clouded revisions include Item 2, 3, and 4 listed below (general description refer to the drawings).
2. Washington School – Sheet M2.1, key note #4 stating drywell requirements for additional units where hardscape exists.
3. Davis School – Detail D on M5.2, provide 4x4 blocking at fall protection anchor points.
4. Davis School – Revise the CO (carbon monoxide) alarm point list on sheet FA0.1.
5. Updated DSA drawings found under Lodi USD website; Prop 39, YR 3-5 2016-19 HVAC - DSA - Four Sites Project; Site Plans/Drawings 4 School Sites; sub-titled:

WAGNER-HOLT_02-117348_DWG_A.pdf
JOHN_MUIR_02-117347_DWG_A.pdf
DAVIS_02-117346_DWG_A.pdf
WASHINGTON_02-117345_DWG_A.pdf
6. Bids must acknowledge all addendums.