



AQUA ENVIRONMENTAL LAB

56 Church Hill Road • Newtown, CT 06470 • (203) 270-9973

Report of Analysis

Name: Parkway School
 Greenwich Public Schools - Cordes George
 290 Greenwich Ave
 Greenwich, CT 06830-6521

Sample ID#: 207688
Sample Type: Drinking Water
Sampler: PT
PWS ID: CT0570212

Sample Date: 11/21/2017 7:20 AM
Receipt Date: 11/21/2017 4:30 PM
Report Date: 11/28/2017
Sample Site: DISTRIBUTION SYSTEM

Parameter	Sample Result	Units	Limits	Method	MDL	Analysis Date
Metals						
Copper(1 - 2N)	0.17	mg/L	1.3	EPA 200.5	0.01	11/27/2017
Lead(1 - 2N)	0.008	mg/L	0.015	EPA 200.5	0.001	11/27/2017
Copper(10 - Art 1)	0.16	mg/L	1.3	EPA 200.5	0.01	11/27/2017
Lead(10 - Art 1)	0.006	mg/L	0.015	EPA 200.5	0.001	11/27/2017
Copper(11 - Art 2)	0.11	mg/L	1.3	EPA 200.5	0.01	11/27/2017
Lead(11 - Art 2)	0.007	mg/L	0.015	EPA 200.5	0.001	11/27/2017
Copper(12 - Art 3)	0.10	mg/L	1.3	EPA 200.5	0.01	11/27/2017
Lead(12 - Art 3)	<0.001	mg/L	0.015	EPA 200.5	0.001	11/27/2017
Copper(13 - 5 North)	0.19	mg/L	1.3	EPA 200.5	0.01	11/27/2017
Lead(13 - 5 North)	0.007	mg/L	0.015	EPA 200.5	0.001	11/27/2017
Copper(2 - 4NORTH)	0.17	mg/L	1.3	EPA 200.5	0.01	11/27/2017
Lead(2 - 4NORTH)	0.012	mg/L	0.015	EPA 200.5	0.001	11/28/2017
Copper(3 - 7E)	0.22	mg/L	1.3	EPA 200.5	0.01	11/27/2017
Lead(3 - 7E)	0.006	mg/L	0.015	EPA 200.5	0.001	11/27/2017
Copper(4 - 8E)	0.18	mg/L	1.3	EPA 200.5	0.01	11/27/2017
Lead(4 - 8E)	0.005	mg/L	0.015	EPA 200.5	0.001	11/27/2017
Copper(5 - N)	0.17	mg/L	1.3	EPA 200.5	0.01	11/27/2017
Lead(5 - N)	<0.001	mg/L	0.015	EPA 200.5	0.001	11/27/2017
Copper(6 - TL)	0.17	mg/L	1.3	EPA 200.5	0.01	11/27/2017
Lead(6 - TL)	0.006	mg/L	0.015	EPA 200.5	0.001	11/27/2017
Copper(7 - Kitchen L)	0.14	mg/L	1.3	EPA 200.5	0.01	11/27/2017
Lead(7 - Kitchen L)	0.004	mg/L	0.015	EPA 200.5	0.001	11/27/2017
Copper(8 - Kitchen M)	0.16	mg/L	1.3	EPA 200.5	0.01	11/27/2017
Lead(8 - Kitchen M)	0.007	mg/L	0.015	EPA 200.5	0.001	11/27/2017
Copper(9 - Kitchen R)	0.10	mg/L	1.3	EPA 200.5	0.01	11/27/2017

**Revised Report

ND = Not Detected * = Above Specified Limit
--

CT Lic PH-0787

NY Lic 11706

Analytical results relate to the samples as received at the laboratory. Report shall not be reproduced except in its entirety without written approval from the laboratory.



AQUA ENVIRONMENTAL LAB

56 Church Hill Road • Newtown, CT 06470 • (203) 270-9973

Report of Analysis

Name: Parkway School
 Greenwich Public Schools - Cordes George
 290 Greenwich Ave
 Greenwich, CT 06830-6521

Sample ID#: 207688
Sample Type: Drinking Water
Sampler: PT
PWS ID: CT0570212

Sample Date: 11/21/2017 7:20 AM
Receipt Date: 11/21/2017 4:30 PM
Report Date: 11/28/2017
Sample Site: DISTRIBUTION SYSTEM

Parameter	Sample Result	Units	Limits	Method	MDL	Analysis Date
Metals						
Lead(9 - Kitchen R)	0.005	mg/L	0.015	EPA 200.5	0.001	11/27/2017

Comments: **Revised Report

ND = Not Detected
 * = Above Specified Limit

Report Approved by:  CT Lic PH-0787 NY Lic 11706
 Lab Director

Analytical results relate to the samples as received at the laboratory. Report shall not be reproduced except in its entirety without written approval from the laboratory.