

CAROLINE CALDERONE BAISLEY
DIRECTOR OF HEALTH



C: L.O'Donnell

D. Watson

MICHAEL LONG, Director

DIVISION OF ENVIRONMENTAL SERVICES

DOUGLAS SERAFIN, Laboratory

DEBORAH TRAVERS, DIRECTOR


DIVISION OF FAMILY HEALTH

ROBIN CLARK-SMITH, Director

SPECIAL CLINICAL SERVICES

DEPARTMENT OF HEALTH

Dr. Jill Gildea
Parkway School
Havemever Bldg.
290 Greenwich Ave.
Greenwich, CT 06830-6521



July 06, 2018

Dear Dr. Jill Gildea,

This letter is to advise you that based upon the results of the most recent water tests collected on **5/15/2018** from your public well that your water is in compliance and meets the standards set by the Town of Greenwich and the State of Connecticut. Please contact this Department at 203-987-1001 if you have any questions.

Test Performed	Acceptable Results	Your Results
Total Coliform	Absent	Absent
E-Coli	Absent	Absent
pH	Between 6.4 – 10.0	7.44
Color Units	Less than 15 (Not to exceed 30)	5
Turbidity	Less than 5 (Not to exceed 10)	0.5
Odor	Less than 2	0
Nitrate (mg/l)	Less than 10.0 mg/l	3.55
Nitrite (mg/l)	Less than 1.0 mg/l	0.024
Sodium (mg/l)	Recommended below 100 mg/l	52.4

Division of Environmental Services