



AQUA ENVIRONMENTAL LAB

56 Church Hill Road • Newtown, CT 06470 • (203) 270-9973

Report of Analysis

Name: Parkway School
 Greenwich Public Schools - Cordes George
 290 Greenwich Ave
 Greenwich, CT 06830-6521
Sample ID#: 222339
Sample Type: Drinking Water
Sampler: PT
PWS ID: CT0570212
Sample Date: 11/14/2018 6:50 AM
Receipt Date: 11/14/2018 3:00 PM
Report Date: 11/15/2018
Sample Site: ENTRY POINT

| Parameter | Sample Result | Units | Method | Minimum Detection Level | Analysis Date | Analyst |
|-----------------|---------------|-------|-----------|-------------------------|---------------|---------|
| Nutrient | | | | | | |
| Nitrate as N | 1.5 | mg/L | EPA 300.0 | 1 | 11/14/2018 | TJB |
| Nitrite as N | <0.1 | mg/L | EPA 300.0 | 0.1 | 11/14/2018 | TJB |

ND = Not Detected
 * = Above Specified Limit

Report Approved by:  _____ CT Lic PH-0787 NY Lic 11706
 Lab Director

Analytical results relate to the samples as received at the laboratory. Report shall not be reproduced except in its entirety without written approval from the laboratory.