

# SUBURBAN LABORATORIES, Inc.



1950 S. Batavia Ave., Suite 150 Geneva, Illinois 60134  
Tel. (708) 544-3260 • Toll Free (800) 783-LABS  
Fax (708) 544-8587  
www.suburbanlabs.com

**Client ID:** Environmental Services Inc

**Project Name:** West Aurora School District 129 Freeman Drinking Water

**Report Date:** January 31, 2018

**Workorder:** 1801H32

**Analyte:** Lead

**Method:** EPA 200.8

**Matrix:** Drinking Water

Sample ID	Client Sample ID	Result	MRL	Units	Date & Time Water System Last Used	Date Collected	Date Analyzed
1801H32-001A	FR 5.1~First Draw CW~First Draw	3.53	2.00	µg/L	1/29/2018 18:30	1/30/2018	1/31/2018
1801H32-002A	FR 5.2~2nd Draw CW~Flush	ND	2.00	µg/L	1/29/2018 18:30	1/30/2018	1/31/2018
1801H32-003A	FR 5.3~First Draw HW~First Draw	ND	2.00	µg/L	1/29/2018 18:30	1/30/2018	1/31/2018
1801H32-004A	FR 13.1~First Draw CW~First Draw	ND	2.00	µg/L	1/29/2018 18:30	1/30/2018	1/31/2018
1801H32-005A	FR 13.2~2nd Draw CW~Flush	ND	2.00	µg/L	1/29/2018 18:30	1/30/2018	1/31/2018
1801H32-006A	FR 13.3~First Draw HW~First Draw	ND	2.00	µg/L	1/29/2018 18:30	1/30/2018	1/31/2018
1801H32-007A	FR 16.1~First Draw CW~First Draw	2.22	2.00	µg/L	1/29/2018 18:30	1/30/2018	1/31/2018
1801H32-008A	FR 16.2~2nd Draw CW~Flush	ND	2.00	µg/L	1/29/2018 18:30	1/30/2018	1/31/2018

1801H32

FIELD DATA FORM

School/Facility Name
West Aurora SD 129 - Freeman
ISBE ID: (ex:01-001-0001-01-00001)



Address
Environmental Services, Inc.
P.O. BOX 688
LaGrange, IL 60525-0688
MMDDYY
HH24MM

Sample Collector Name(s)
KP
ESI PROJECT 5270

All samples must be collected in unpreserved 250 ml plastic bottles

Water system last used Date: 01292018 Time: 18:30

	Bldg. ID	Bldg. Desc	Sample ID#	Sample Loc. Desc	Collection Date MMDDYYYY	Collection Time HH24MM	Fixture Type	Sample Type	Sample Vol.	Notes
Ex1:	0001	Main Building	01	1st Floor Classroom	02232017	800	O - Other	First Draw	250	Description if "Other" is selected
Ex2:	0001	Main Building	01A	1st Floor Classroom	02232017	800	S - Sink	Flush	250	
1	0001	Main Building	FR 5.1	First Draw CW	01302018	6:20	S - Sink	First Draw	250	ROOM 107 Stand Alone Sink
2	0001	Main Building	FR 5.2	2nd Draw CW	01302018	6:20	S - Sink	Flush	250	ROOM 107 Stand Alone Sink
3	0001	Main Building	FR 5.3	First Draw HW	01302018	6:20	S - Sink	First Draw	250	ROOM 107 Stand Alone Sink
4	0001	Main Building	FR 13.1	First Draw CW	01302018	6:24	S - Sink	First Draw	250	Kitchen Room 130
5	0001	Main Building	FR 13.2	2nd Draw CW	01302018	6:24	S - Sink	Flush	250	Kitchen Room 130
6	0001	Main Building	FR 13.3	First Draw HW	01302018	6:24	S - Sink	First Draw	250	Kitchen Room 130
7	0001	Main Building	FR 16.1	First Draw CW	01302018	6:30	S - Sink	First Draw	250	Room 04A
8	0001	Main Building	FR 16.2	2nd Draw CW	01302018	6:30	S - Sink	Flush	250	Room 04A
9										
10										
11										
12										
13										
14										
15										
16										
17										
18										
19										
20										
21										
22										
23										
24										
25										
26										
27										
28										
29										
30										
31										
32										
33										
34										
35										
36										
37										
38										
39										
40										
41										
42										
43										
44										
45										
46										
47										
48										
49										
50										
51										
52										
53										
54										
55										
56										
57										
58										

 1/30/18 10:06  


# SUBURBAN LABORATORIES, Inc.



1950 S. Batavia Ave., Suite 150 Geneva, Illinois 60134  
 Tel. (708) 544-3260 • Toll Free (800) 783-LABS  
 Fax (708) 544-8587  
 www.suburbanlabs.com

**Client ID:** Environmental Services Inc

**Project Name:** West Aurora School District 129 Freeman Drinking Water

**Report Date:** January 12, 2018

**Workorder:** 1801049

**Analyte:** Lead

**Method:** EPA 200.8

**Matrix:** Drinking Water

Sample ID	Client Sample ID	Result	MRL	Units	Date & Time Water System Last Used	Date Collected	Date Analyzed
1801049-001A	FR 5.1~First Draw CW~First Draw	19.3	2.00	µg/L	01/02/2018 18:30	1/3/2018	1/10/2018
1801049-002A	FR 5.2~2nd Draw CW~Flush	ND	2.00	µg/L	01/02/2018 18:30	1/3/2018	1/10/2018
1801049-003A	FR 5.3~First Draw HW~First Draw	11.7	2.00	µg/L	01/02/2018 18:30	1/3/2018	1/10/2018
1801049-004A	FR 6 A.1~First Draw CW~First Draw	ND	2.00	µg/L	01/02/2018 18:30	1/3/2018	1/10/2018
1801049-005A	FR 6 A.2~2nd Draw CW~Flush	ND	2.00	µg/L	01/02/2018 18:30	1/3/2018	1/10/2018
1801049-006A	FR 6 A.3~First Draw HW~First Draw	ND	2.00	µg/L	01/02/2018 18:30	1/3/2018	1/10/2018
1801049-007A	FR 13.1~First Draw CW~First Draw	5.33	2.00	µg/L	01/02/2018 18:30	1/3/2018	1/10/2018
1801049-008A	FR 13.2~2nd Draw CW~Flush	ND	2.00	µg/L	01/02/2018 18:30	1/3/2018	1/10/2018
1801049-009A	FR 13.3~First Draw HW~First Draw	ND	2.00	µg/L	01/02/2018 18:30	1/3/2018	1/10/2018
1801049-010A	FR 15.1~First Draw CW~First Draw	4.22	2.00	µg/L	01/02/2018 18:30	1/3/2018	1/10/2018
1801049-011A	FR 15.2~2nd Draw CW~Flush	ND	2.00	µg/L	01/02/2018 18:30	1/3/2018	1/10/2018
1801049-012A	FR 15.3~First Draw HW~First Draw	2.40	2.00	µg/L	01/02/2018 18:30	1/3/2018	1/10/2018
1801049-013A	FR 16.1~First Draw CW~First Draw	20.8	2.00	µg/L	01/02/2018 18:30	1/3/2018	1/10/2018
1801049-014A	FR 16.2~2nd Draw CW~Flush	15.8	2.00	µg/L	01/02/2018 18:30	1/3/2018	1/10/2018
1801049-015A	FR 16.3~First Draw HW~First Draw	118	2.00	µg/L	01/02/2018 18:30	1/3/2018	1/10/2018
1801049-016A	FR 17 A.1~First Draw CW~First Draw	ND	2.00	µg/L	01/02/2018 18:30	1/3/2018	1/10/2018
1801049-017A	FR 17 A.2~2nd Draw CW~Flush	ND	2.00	µg/L	01/02/2018 18:30	1/3/2018	1/10/2018
1801049-018A	FR 17 A.3~First Draw HW~First Draw	ND	2.00	µg/L	01/02/2018 18:30	1/3/2018	1/10/2018

# ASAP RUSH

# 1801049

### FIELD DATA FORM

School/Facility Name
West Aurora SD 129 - Freeman
ISBE ID: (ex:01-001-0001-01-00001)

Address
Environmental Services, Inc.
P.O. BOX 688
LaGrange, IL 60525-0688

Sample Collector Name(s)
KW
ESI PROJECT 5270

Water system last used Date:	01022018	Time:	18:30
------------------------------	----------	-------	-------

All samples must be collected in unpreserved 250 ml plastic bottles

	Bldg. ID	Bldg. Desc	Sample ID#	Sample Loc. Desc	Collection Date MMDDYYYY	Collection Time HH24MM	Fixture Type	Sample Type	Sample Vol.	Notes
Ex1:	0001	Main Building	01	1st Floor Classroom	02232017	800	O - Other	First Draw	250	Description if "Other" is selected
Ex2:	0001	Main Building	01A	1st Floor Classroom	02232017	800	S - Sink	Flush	250	
1	0001	Main Building	FR 5.1	First Draw CW	01032018	6:44	S - Sink	First Draw	250	
2	0001	Main Building	FR 5.2	2nd Draw CW	01032018	6:44	S - Sink	Flush	250	
3	0001	Main Building	FR 5.3	First Draw HW	01032018	6:44	S - Sink	First Draw	250	
4	0001	Main Building	FR 6 A.1	First Draw CW	01032018	6:47	S - Sink	First Draw	250	
5	0001	Main Building	FR 6 A.2	2nd Draw CW	01032018	6:47	S - Sink	Flush	250	
6	0001	Main Building	FR 6 A.3	First Draw HW	01032018	6:47	S - Sink	First Draw	250	
7	0001	Main Building	FR 13.1	First Draw CW	01032018	6:52	S - Sink	First Draw	250	
8	0001	Main Building	FR 13.2	2nd Draw CW	01032018	6:52	S - Sink	Flush	250	
9	0001	Main Building	FR 13.3	First Draw HW	01032018	6:52	S - Sink	First Draw	250	
10	0001	Main Building	FR 15.1	First Draw CW	01032018	6:57	S - Sink	First Draw	250	
11	0001	Main Building	FR 15.2	2nd Draw CW	01032018	6:57	S - Sink	Flush	250	
12	0001	Main Building	FR 15.3	First Draw HW	01032018	6:57	S - Sink	First Draw	250	
13	0001	Main Building	FR 16.1	First Draw CW	01032018	7:09	S - Sink	First Draw	250	
14	0001	Main Building	FR 16.2	2nd Draw CW	01032018	7:09	S - Sink	Flush	250	
15	0001	Main Building	FR 16.3	First Draw HW	01032018	7:09	S - Sink	First Draw	250	
16	0001	Main Building	FR 17 A.1	First Draw CW	01032018	7:15	S - Sink	First Draw	250	
17	0001	Main Building	FR 17 A.2	2nd Draw CW	01032018	7:15	S - Sink	Flush	250	
18	0001	Main Building	FR 17 A.3	First Draw HW	01032018	7:15	S - Sink	First Draw	250	
19										
20										
21										
22										
23										
24										
25										
26										
27										
28										
29										
30										
31										
32										
33										
34										
35										
36										
37										
38										
39										
40										
41										
42										
43										
44										
45										
46										
47										
48										
49										
50										
51										
52										
53										
54										
55										
56										
57										
58										

*Koulaye*  
1-31-17

1/31/17 14:31 *Ram* *Ram* Page 8 of 18 1/31/18