

CERTIFICATE OF ANALYSIS

Client: TTI Environmental Inc.
1253 North Church St.
Moorestown NJ 08057

Report Date: 5/18/2017
Report No.: 535755 - Lead Water
Project: Bridgewater-Raritan High School
Project No.: 16-1944

Client: TTI379

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.:6229333 **Location:**823-Faucet **Result(ppb):**4.00
Client No.:HS-SL1-823

Lab No.:6229334 **Location:**823-Faucet **Result(ppb):**2.80
Client No.:HS-SL2-823

Lab No.:6229335 **Location:**824-Faucet **Result(ppb):**120
Client No.:HS-SL1-824

Lab No.:6229336 **Location:**824-Faucet **Result(ppb):**<2.00
Client No.:HS-SL3-824

Lab No.:6229337 **Location:**824-Faucet **Result(ppb):**<2.00
Client No.:HS-SL4-824

Lab No.:6229338 **Location:**824-Faucet **Result(ppb):**<2.00
Client No.:HS-SL5-824

Lab No.:6229339 **Location:**824-Faucet **Result(ppb):**<2.00
Client No.:HS-SL6-824

Lab No.:6229340 **Location:**824-Faucet **Result(ppb):**<2.00
Client No.:HS-SL7-824

Lab No.:6229341 **Location:**824-Faucet **Result(ppb):**<2.00
Client No.:HS-SL8-824

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 5/4/2017

Date Analyzed: 05/18/2017

Signature: 

Analyst: Chad Shaffer

Approved By: 

Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: TTI Environmental Inc.
1253 North Church St.
Moorestown NJ 08057

Report Date: 5/18/2017
Report No.: 535755 - Lead Water
Project: Bridgewater-Raritan High School
Project No.: 16-1944

Client: TTI379

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.:6229342 **Location:**825-Faucet **Result(ppb):**15.4

Client No.:HS-SL1-825

Note: Sample turbidity >1.0 NTU. Does not meet Federal and NJ State Primary and Secondary Drinking Water Standards.

Lab No.:6229343 **Location:**825-Faucet **Result(ppb):**2.60

Client No.:HS-SL2-825

Lab No.:6229344 **Location:**826-Faucet **Result(ppb):**8.20

Client No.:HS-SL1-826

Lab No.:6229345 **Location:**826-Faucet **Result(ppb):**<2.00

Client No.:HS-SL2-826

Lab No.:6229346 **Location:**826-Faucet **Result(ppb):**<2.00

Client No.:HS-SL3-826

Lab No.:6229347 **Location:**826-Faucet **Result(ppb):**4.20

Client No.:HS-SL4-826

Lab No.:6229348 **Location:**826-Faucet **Result(ppb):**<2.00

Client No.:HS-SL5-826

Lab No.:6229349 **Location:**826-Faucet **Result(ppb):**2.40

Client No.:HS-SL6-826

Lab No.:6229350 **Location:**826-Faucet **Result(ppb):**<2.00

Client No.:HS-SL7-826

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 5/4/2017

Date Analyzed: 05/18/2017

Signature: 

Analyst: Chad Shaffer

Approved By: 

Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: TTI Environmental Inc.
1253 North Church St.
Moorestown NJ 08057

Report Date: 5/18/2017
Report No.: 535755 - Lead Water
Project: Bridgewater-Raritan High School
Project No.: 16-1944

Client: TTI379

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.:6229351 **Location:**827-Faucet **Result(ppb):**<2.00
Client No.:HS-SL1-827

Lab No.:6229352 **Location:**827-Faucet **Result(ppb):**<2.00
Client No.:HS-SL3-827

Lab No.:6229353 **Location:**827-Faucet **Result(ppb):**<2.00
Client No.:HS-SL4-827

Lab No.:6229354 **Location:**827-Faucet **Result(ppb):**<2.00
Client No.:HS-SL5-827

Lab No.:6229355 **Location:**827-Faucet **Result(ppb):**<2.00
Client No.:HS-SL6-827


Lab No.:6229356 **Location:**827-Faucet **Result(ppb):**<2.00
Client No.:HS-SL7-827


Lab No.:6229357 **Location:**827-Faucet **Result(ppb):**<2.00
Client No.:HS-SL8-827

Lab No.:6229358 **Location:**828-Faucet **Result(ppb):**8.10
Client No.:HS-SL1-828

Lab No.:6229359 **Location:**828-Faucet **Result(ppb):**8.00
Client No.:HS-SL3-828

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 5/4/2017
Date Analyzed: 05/18/2017
Signature: 
Analyst: Chad Shaffer

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: TTI Environmental Inc.
1253 North Church St.
Moorestown NJ 08057

Report Date: 5/18/2017
Report No.: 535755 - Lead Water
Project: Bridgewater-Raritan High School
Project No.: 16-1944

Client: TTI379

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.:6229360 **Location:**829-Faucet **Result(ppb):**2.20
Client No.:HS-SL1-829

Lab No.:6229361 **Location:**829-Faucet **Result(ppb):**20.8
Client No.:HS-SL3-829

Lab No.:6229362 **Location:**829-Faucet **Result(ppb):**<2.00
Client No.:HS-SL4-829

Lab No.:6229363 **Location:**829-Faucet **Result(ppb):**<2.00
Client No.:HS-SL5-829

Lab No.:6229364 **Location:**829-Faucet **Result(ppb):**<2.00
Client No.:HS-SL6-829


Lab No.:6229365 **Location:**829-Faucet **Result(ppb):**<2.00
Client No.:HS-SL7-829


Lab No.:6229366 **Location:**829-Faucet **Result(ppb):**<2.00
Client No.:HS-SL8-829

Lab No.:6229367 **Location:**811-Faucet **Result(ppb):**31.5
Client No.:HS-SL1-811

Lab No.:6229368 **Location:**811-Faucet **Result(ppb):**41.5
Client No.:HS-SL2-811

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 5/4/2017
Date Analyzed: 05/18/2017
Signature: 
Analyst: Chad Shaffer

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: TTI Environmental Inc.
1253 North Church St.
Moorestown NJ 08057


Report Date: 5/18/2017
Report No.: 535755 - Lead Water
Project: Bridgewater-Raritan High School
Project No.: 16-1944


Client: TTI379

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.: 6229369 Client No.: HS-SL3-811	Location: 811-Faucet	Result(ppb): 4.40
Lab No.: 6229370 Client No.: HS-SL4-811	Location: 811-Faucet	Result(ppb): 2.20
Lab No.: 6229371 Client No.: HS-SL5-811	Location: 811-Faucet	Result(ppb): 2.50
Lab No.: 6229372 Client No.: HS-SL6-811	Location: 811-Faucet	Result(ppb): <2.00
Lab No.: 6229373 Client No.: HS-SL7-811	Location: 811-Faucet	Result(ppb): 2.70
Lab No.: 6229374 Client No.: HS-SL8-811	Location: 811-Faucet	Result(ppb): <2.00
Lab No.: 6229375 Client No.: HS-SL9-811	Location: 811-Faucet	Result(ppb): <2.00
Lab No.: 6229376 Client No.: HS-SL1-812	Location: 812-Faucet	Result(ppb): <2.00
Lab No.: 6229377 Client No.: HS-SL1-813	Location: 813-Faucet	Result(ppb): 18.5

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 5/4/2017
Date Analyzed: 05/18/2017
Signature: 
Analyst: Chad Shaffer

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: TTI Environmental Inc.
1253 North Church St.
Moorestown NJ 08057

Report Date: 5/18/2017
Report No.: 535755 - Lead Water
Project: Bridgewater-Raritan High School
Project No.: 16-1944

Client: TTI379

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.: 6229378 Client No.: HS-SL2-813	Location: 813-Faucet	Result(ppb): 5.30
Lab No.: 6229379 Client No.: HS-SL3-813	Location: 813-Faucet	Result(ppb): 3.40
Lab No.: 6229380 Client No.: HS-SL4-813	Location: 813-Faucet	Result(ppb): <2.00
Lab No.: 6229381 Client No.: HS-SL5-813	Location: 813-Faucet	Result(ppb): 3.60
Lab No.: 6229382 Client No.: HS-SL6-813	Location: 813-Faucet	Result(ppb): 3.30
Lab No.: 6229383 Client No.: HS-SL7-813	Location: 813-Faucet	Result(ppb): 8.30
Lab No.: 6229384 Client No.: HS-SL8-813	Location: 813-Faucet	Result(ppb): <2.00
Lab No.: 6229385 Client No.: HS-SL9-813	Location: 813-Faucet	Result(ppb): <2.00
Lab No.: 6229386 Client No.: HS-SL1-814	Location: 814-Faucet	Result(ppb): 57.6

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 5/4/2017
Date Analyzed: 05/18/2017
Signature:
Analyst: Chad Shaffer

Approved By:
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: TTI Environmental Inc.
1253 North Church St.
Moorestown NJ 08057


Report Date: 5/18/2017
Report No.: 535755 - Lead Water
Project: Bridgewater-Raritan High School
Project No.: 16-1944


Client: TTI379

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.: 6229387 Client No.: HS-SL2-814	Location: 814-Faucet	Result(ppb): 6.30
Lab No.: 6229388 Client No.: HS-SL3-814	Location: 814-Faucet	Result(ppb): <2.00
Lab No.: 6229389 Client No.: HS-SL4-814	Location: 814-Faucet	Result(ppb): <2.00
Lab No.: 6229390 Client No.: HS-SL5-814	Location: 814-Faucet	Result(ppb): <2.00
Lab No.: 6229391 Client No.: HS-SL6-814	Location: 814-Faucet	Result(ppb): 6.00
Lab No.: 6229392 Client No.: HS-SL7-814	Location: 814-Faucet	Result(ppb): 4.80
Lab No.: 6229393 Client No.: HS-SL8-814	Location: 814-Faucet	Result(ppb): <2.00
Lab No.: 6229394 Client No.: HS-SL9-814	Location: 814-Faucet	Result(ppb): <2.00
Lab No.: 6229395 Client No.: HS-SL1-815	Location: 815-Faucet	Result(ppb): 22.0

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 5/4/2017
Date Analyzed: 05/18/2017
Signature: 
Analyst: Chad Shaffer

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: TTI Environmental Inc.
1253 North Church St.
Moorestown NJ 08057

Report Date: 5/18/2017
Report No.: 535755 - Lead Water
Project: Bridgewater-Raritan High School
Project No.: 16-1944

Client: TTI379

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.:6229396 **Location:**815-Faucet **Result(ppb):**39.2
Client No.:HS-SL2-815

Lab No.:6229397 **Location:**816-Faucet **Result(ppb):**<2.00
Client No.:HS-SL1-816

Lab No.:6229398 **Location:**816-Faucet **Result(ppb):**<2.00
Client No.:HS-SL2-816

Lab No.:6229399 **Location:**816-Faucet **Result(ppb):**<2.00
Client No.:HS-SL3-816

Lab No.:6229400 **Location:**816-Faucet **Result(ppb):**<2.00
Client No.:HS-SL4-816

Note: Sample turbidity >1.0 NTU. Does not meet Federal and NJ State Primary and Secondary Drinking Water Standards.


Lab No.:6229401 **Location:**816-Faucet **Result(ppb):**<2.00
Client No.:HS-SL5-816


Lab No.:6229402 **Location:**816-Faucet **Result(ppb):**<2.00
Client No.:HS-SL6-816

Lab No.:6229403 **Location:**816-Faucet **Result(ppb):**<2.00
Client No.:HS-SL7-816

Lab No.:6229404 **Location:**816-Faucet **Result(ppb):**<2.00
Client No.:HS-SL8-816

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 5/4/2017
Date Analyzed: 05/18/2017
Signature: 
Analyst: Chad Shaffer

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: TTI Environmental Inc.
1253 North Church St.
Moorestown NJ 08057


Report Date: 5/18/2017
Report No.: 535755 - Lead Water
Project: Bridgewater-Raritan High School
Project No.: 16-1944


Client: TTI379

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.: 6229405 Client No.: HS-SL1-817	Location: 817-Faucet	Result(ppb): 112
Lab No.: 6229406 Client No.: HS-SL2-817	Location: 817-Faucet	Result(ppb): 18.6
Lab No.: 6229407 Client No.: HS-SL3-817	Location: 817-Faucet	Result(ppb): 2.20
Lab No.: 6229408 Client No.: HS-SL4-817	Location: 817-Faucet	Result(ppb): <2.00
Lab No.: 6229409 Client No.: HS-SL5-817	Location: 817-Faucet	Result(ppb): <2.00
Lab No.: 6229410 Client No.: HS-SL6-817	Location: 817-Faucet	Result(ppb): <2.00
Lab No.: 6229411 Client No.: HS-SL7-817	Location: 817-Faucet	Result(ppb): 2.10
Lab No.: 6229412 Client No.: HS-SL8-817	Location: 817-Faucet	Result(ppb): <2.00
Lab No.: 6229413 Client No.: HS-SL9-817	Location: 817-Faucet	Result(ppb): <2.00

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 5/4/2017
Date Analyzed: 05/18/2017
Signature: 
Analyst: Chad Shaffer

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: TTI Environmental Inc.
1253 North Church St.
Moorestown NJ 08057

Report Date: 5/18/2017
Report No.: 535755 - Lead Water
Project: Bridgewater-Raritan High School
Project No.: 16-1944

Client: TTI379

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.: 6229414 Client No.: HS-SL1-818	Location: 818-Faucet	Result(ppb): 7.30
Lab No.: 6229415 Client No.: HS-SL2-818	Location: 818-Faucet	Result(ppb): 92.0
Lab No.: 6229416 Client No.: HS-SL1-818	Location: 819-Faucet	Result(ppb): 17.5
Lab No.: 6229417 Client No.: HS-SL2-819	Location: 819-Faucet	Result(ppb): 4.00
Lab No.: 6229418 Client No.: HS-SL3-819	Location: 819-Faucet	Result(ppb): <2.00
Lab No.: 6229419 Client No.: HS-SL4-819	Location: 819-Faucet	Result(ppb): 2.30
Lab No.: 6229420 Client No.: HS-SL5-819	Location: 819-Faucet	Result(ppb): <2.00
Lab No.: 6229421 Client No.: HS-SL6-819	Location: 819-Faucet	Result(ppb): <2.00
Lab No.: 6229422 Client No.: HS-SL7-819	Location: 819-Faucet	Result(ppb): <2.00

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 5/4/2017
Date Analyzed: 05/18/2017
Signature:
Analyst: Chad Shaffer

Approved By:
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: TTI Environmental Inc.
1253 North Church St.
Moorestown NJ 08057

Report Date: 5/18/2017
Report No.: 535755 - Lead Water
Project: Bridgewater-Raritan High School
Project No.: 16-1944

Client: TTI379

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.: 6229423 Client No.: HS-SL8-819	Location: 819-Faucet	Result(ppb): 6.00
Lab No.: 6229424 Client No.: HS-SL9-819	Location: 819-Faucet	Result(ppb): <2.00
Lab No.: 6229425 Client No.: HS-SL1-820	Location: 820-Faucet	Result(ppb): 32.6
Lab No.: 6229426 Client No.: HS-SL2-820	Location: 820-Faucet	Result(ppb): 15.5
Lab No.: 6229427 Client No.: HS-SL3-820	Location: 820-Faucet	Result(ppb): <2.00
Lab No.: 6229428 Client No.: HS-SL4-820	Location: 820-Faucet	Result(ppb): <2.00
Lab No.: 6229429 Client No.: HS-SL5-820	Location: 820-Faucet	Result(ppb): <2.00
Lab No.: 6229430 Client No.: HS-SL7-820	Location: 820-Faucet	Result(ppb): <2.00
Lab No.: 6229431 Client No.: HS-SL8-820	Location: 820-Faucet	Result(ppb): <2.00

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 5/4/2017
Date Analyzed: 05/18/2017
Signature:
Analyst: Chad Shaffer

Approved By:
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: TTI Environmental Inc.
1253 North Church St.
Moorestown NJ 08057

Report Date: 5/18/2017
Report No.: 535755 - Lead Water
Project: Bridgewater-Raritan High School
Project No.: 16-1944

Client: TTI379

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.:6229432 **Location:**820-Faucet **Result(ppb):**<2.00
Client No.:HS-SL9-820

Lab No.:6229433 **Location:**821-Faucet **Result(ppb):**119
Client No.:HS-SL1-821

Lab No.:6229434 **Location:**822-Faucet **Result(ppb):**56.4
Client No.:HS-SL1-822

Lab No.:6229435 **Location:**822-Faucet **Result(ppb):**19.5
Client No.:HS-SL2-822

Lab No.:6229436 **Location:**822-Faucet **Result(ppb):**<2.00
Client No.:HS-SL3-822

Lab No.:6229437 **Location:**822-Faucet **Result(ppb):**<2.00
Client No.:HS-SL4-822

Lab No.:6229438 **Location:**822-Faucet **Result(ppb):**<2.00
Client No.:HS-SL5-822

Lab No.:6229439 **Location:**822-Faucet **Result(ppb):**5.70
Client No.:HS-SL6-822

Lab No.:6229440 **Location:**822-Faucet **Result(ppb):**<2.00
Client No.:HS-SL7-822

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 5/4/2017

Date Analyzed: 05/18/2017

Signature: 

Analyst: Chad Shaffer

Approved By: 

Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: TTI Environmental Inc.
1253 North Church St.
Moorestown NJ 08057

Report Date: 5/18/2017
Report No.: 535755 - Lead Water
Project: Bridgewater-Raritan High School
Project No.: 16-1944

Client: TTI379

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.:6229441
Client No.:HS-SL8-822

Location:822-Faucet

Result(ppb):<2.00

Lab No.:6229442
Client No.:HS-SL9-822

Location:822-Faucet

Result(ppb):<2.00

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 5/4/2017

Date Analyzed: 05/18/2017

Signature: 

Analyst: Chad Shaffer

Approved By: 

Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: TTI Environmental Inc.
1253 North Church St.
Moorestown NJ 08057

Report Date: 5/18/2017
Report No.: 535755 - Lead Water
Project: Bridgewater-Raritan High School
Project No.: 16-1944

Client: TTI379

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.:6229484 **Location:**802-Faucet **Result(ppb):**6.10
Client No.:HS-SL1-802

Lab No.:6229485 **Location:**802-Faucet **Result(ppb):**<2.00
Client No.:HS-SL3-802

Lab No.:6229486 **Location:**802-Faucet **Result(ppb):**<2.00
Client No.:HS-SL4-802

Lab No.:6229487 **Location:**802-Faucet **Result(ppb):**<2.00
Client No.:HS-SL5-802

Lab No.:6229488 **Location:**802-Faucet **Result(ppb):**<2.00
Client No.:HS-SL6-802

Lab No.:6229489 **Location:**802-Faucet **Result(ppb):**3.10
Client No.:HS-SL7-802


Lab No.:6229490 **Location:**802-Faucet **Result(ppb):**2.10
Client No.:HS-SL8-802


Lab No.:6229491 **Location:**803-Faucet **Result(ppb):**2.30
Client No.:HS-SL1-803

Lab No.:6229492 **Location:**803-Faucet **Result(ppb):**2.60
Client No.:HS-SL2-803

Lab No.:6229493 **Location:**803-Faucet **Result(ppb):**4.70
Client No.:HS-SL3-803

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 5/4/2017
Date Analyzed: 05/18/2017
Signature: 
Analyst: Chad Shaffer

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: TTI Environmental Inc.
1253 North Church St.
Moorestown NJ 08057


Report Date: 5/18/2017
Report No.: 535755 - Lead Water
Project: Bridgewater-Raritan High School
Project No.: 16-1944


Client: TTI379

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.: 6229494 Client No.: HS-SL1-804	Location: 804-Faucet	Result(ppb): 6.10
Lab No.: 6229495 Client No.: HS-SL2-804	Location: 804-Faucet	Result(ppb): 44.0
Lab No.: 6229496 Client No.: HS-SL3-804	Location: 804-Faucet	Result(ppb): 2.10
Lab No.: 6229497 Client No.: HS-SL4-804	Location: 804-Faucet	Result(ppb): <2.00
Lab No.: 6229498 Client No.: HS-SL5-804	Location: 804-Faucet	Result(ppb): <2.00
Lab No.: 6229499 Client No.: HS-SL6-804	Location: 804-Faucet	Result(ppb): <2.00
Lab No.: 6229500 Client No.: HS-SL7-804	Location: 804-Faucet	Result(ppb): <2.00
Lab No.: 6229501 Client No.: HS-SL8-804	Location: 804-Faucet	Result(ppb): <2.00
Lab No.: 6229502 Client No.: HS-SL1-805	Location: 805-Faucet	Result(ppb): 6.20
Lab No.: 6229503 Client No.: HS-SL2-805	Location: 805-Faucet	Result(ppb): 2.20

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 5/4/2017
Date Analyzed: 05/18/2017
Signature: 
Analyst: Chad Shaffer

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: TTI Environmental Inc.
1253 North Church St.
Moorestown NJ 08057

Report Date: 5/18/2017
Report No.: 535755 - Lead Water
Project: Bridgewater-Raritan High School
Project No.: 16-1944

Client: TTI379

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.:6229504 **Location:**805-Faucet **Result(ppb):**<2.00
Client No.:HS-SL3-805

Lab No.:6229505 **Location:**805-Faucet **Result(ppb):**<2.00
Client No.:HS-SL4-805

Lab No.:6229506 **Location:**805-Faucet **Result(ppb):**<2.00
Client No.:HS-SL5-805

Lab No.:6229507 **Location:**805-Faucet **Result(ppb):**<2.00
Client No.:HS-SL6-805

Lab No.:6229508 **Location:**805-Faucet **Result(ppb):**<2.00
Client No.:HS-SL7-805

Lab No.:6229509 **Location:**806-Faucet **Result(ppb):**4.10
Client No.:HS-SL1-806


Lab No.:6229510 **Location:**806-Faucet **Result(ppb):**<2.00
Client No.:HS-SL2-806


Lab No.:6229511 **Location:**807-Faucet **Result(ppb):**4.30
Client No.:HS-SL1-807

Lab No.:6229512 **Location:**807-Faucet **Result(ppb):**5.70
Client No.:HS-SL2-807

Lab No.:6229513 **Location:**807-Faucet **Result(ppb):**6.70
Client No.:HS-SL3-807

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 5/4/2017
Date Analyzed: 05/18/2017
Signature: 
Analyst: Chad Shaffer

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: TTI Environmental Inc.
1253 North Church St.
Moorestown NJ 08057

Report Date: 5/18/2017
Report No.: 535755 - Lead Water
Project: Bridgewater-Raritan High School
Project No.: 16-1944

Client: TTI379

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.:6229514 **Location:**807-Faucet **Result(ppb):**6.10
Client No.:HS-SL4-807


Lab No.:6229515 **Location:**807-Faucet **Result(ppb):**7.10
Client No.:HS-SL5-807


Lab No.:6229516 **Location:**807-Faucet **Result(ppb):**3.00
Client No.:HS-SL6-807

Lab No.:6229517 **Location:**807-Faucet **Result(ppb):**6.60
Client No.:HS-SL7-807

Lab No.:6229518 **Location:**807-Faucet **Result(ppb):**4.20
Client No.:HS-SL8-807

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 5/4/2017
Date Analyzed: 05/18/2017
Signature: 
Analyst: Chad Shaffer

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: TTI Environmental Inc.
1253 North Church St.
Moorestown NJ 08057

Report Date: 5/18/2017
Report No.: 535755 - Lead Water
Project: Bridgewater-Raritan High School
Project No.: 16-1944

Client: TTI379

Appendix to Analytical Report:

Customer Contact: TTI Reports

Analysis: AAS-GF - ASTM D3559-08D, USEPA 40CFR 141.11B, 2010

This appendix seeks to promote greater understanding of any observations, exceptions, special instructions, or circumstances that the laboratory needs to communicate to the client concerning the above samples. The information below is used to help promote your ability to make the most informed decisions for you and your customers. Please note the following points of contact for any questions you may have.

iATL Customer Service: customerservice@iatl.com

iATL Office Manager: cdavis@iatl.com

iATL Account Representative: Shirley Clark

Sample Login Notes: See Batch Sheet Attached

Sample Matrix: Water

Exceptions Noted: See Following Pages

General Terms, Warrants, Limits, Qualifiers:

General information about iATL capabilities and client/laboratory relationships and responsibilities are spelled out in iATL policies that are listed at www.iATL.com and in our Quality Assurance Manual per ISO 17025 standard requirements. The information therein is a representation of iATL definitions and policies for turnaround times, sample submittal, collection media, blank definitions, quantification issues and limit of detection, analytical methods and procedures, sub-contracting policies, results reporting options, fees, terms, and discounts, confidentiality, sample archival and disposal, and data interpretation.

iATL warrants the test results to be of a precision normal for the type and methodology employed for each sample submitted. iATL disclaims any other warrants, expressed or implied, including warranty of fitness for a particular purpose and warranty of merchantability. iATL accepts no legal responsibility for the purpose for which the client uses test results. Any analytical work performed must be governed by our Standard Terms and Conditions. Prices, methods and detection limits may be changed without notification. Please contact your Customer Service Representative for the most current information.

This confidential report relates only to those item(s) tested and does not represent an endorsement by NIST-NVLAP, AIHA LAP LLC, or any agency of local, state or province governments nor of any agency of the U.S. government.

This report shall not be reproduced except in full, without written approval of the laboratory.

Information Pertinent to this Report:

Analysis by AAS Graphite Furnace:

- ASTM D3559-08D, USEPA 40CFR 141.11B, 2010

- USEPA 200.9Pb, AAS-GF, RL <2 ppb/sample

- USEPA SW 846-7000B:7421 - Pb(AAS-GF, RL <2 ppb/sample)

Certification:

- NYS-DOH No. 11021

- NJDEP No. 03863

Regulatory limit for lead in drinking water is 15.0 parts per billion as cited in EPA 40 CFR 141.11 National Primary Drinking Water Regulations, Subpart B: Maximum contaminant levels for inorganic chemicals.

All results are based on the samples as received at the lab. iATL assumes that appropriate sampling methods have been used and that the data upon which these results are based have been accurately supplied by the client.

Sample results are not corrected for contamination by field or analytical blanks.

PPB = Parts per billion. 1 µg/L = 1 ppb MDL = 0.24 PPB Reporting Limit (RL) = 2.0 PPB

Disclaimers / Qualifiers:

There may be some samples in this project that have a "NOTE:" associated with a sample result. We use added disclaimers or qualifiers to inform the client about something that requires further explanation. Here is a complete list with highlighted disclaimers pertinent to this project. For a full explanation of these and other disclaimers, please inquire at customerservice@iatl.com.

Water Sample Turbidity greater than 1.0 NTU does not meet Federal and NJ State Primary & Secondary Drinking Water Standards.