

# Annual Comprehensive Facility Inspection

**Office of:**

Lake County Schools - District Offices  
201 West Burleigh Blvd.

Tavares, 32778  
352 343-3531

District Inspector: Antonio Peace

Inspector #: 171133

**Local Municipal Inspection Authority:**

Mascotte Fire Rescue

529 East Meyers Blvd.

Mascotte, 34753

352 429-4766

District: Lake County

Facility: Mascotte Charter Elementary School

FISH #: 35-00073-00065

Address: 460 Midway Ave.

Mascotte, 34753

352 429-2294

Facility Type: K-6 (Elementary)

Fiscal Year: 2015-2016

Inspection Date: 11/10/2015

Scheduled Reinspection Date: 12/08/2015

Actual Reinspection Date: 12/08/2015

Print Date: 12/08/2015

**Legend:****Priority:**

- 1 = Serious
- 2 = High
- 3 = Moderate
- 4 = Low
- 5 = Minimal

**Category:**

- A = Fire Safety
- B = Casualty Safety and Sanitation

**Citations from Code:**

69A-58 = Fire Safety Standards and Requirements for Educational and Ancillary Facilities and Plants (F.A.C.)

SREF = State Requirements for Educational Facilities (2009)

NFPA = National Fire Protection Association

**Deficiency Type and Corrective Action Planned and Schedule:**

O = Operation of Plant -- School Responsibility to complete within 7 days of receipt of inspection report

M = Maintenance of Plant -- 90 days to complete after Inspection Date

C = Capital Outlay -- June 30 of fiscal year or becomes part of Plan of Correction

Validated = Correction verified by a certified inspector

**Complete:**

Y = Yes

N = No

**Fire Exit Drill Requirements:**

NFPA 101-15.7.2.2 (1): At least one fire exit drill shall be conducted every month the facility is in session.

NFPA 101-15.7.2.2 (3): One additional fire exit drill shall be required within the first 30 days of operation.

**Certifications of Compliance with Florida Statutes:**

District HAS complied with section 1013.12(2)(d) and 1013.20 of Florida Statutes regarding corrective action plans and relocatable inspections.

Local Authority HAS complied with section 1013.12(2)(c) of Florida Statutes regarding plan of action and schedule for correction of each fire safety deficiency

Required Exit Drills Completed as of this inspection date.

**Signatures:**

Signature of Facility Administrator Acknowledging Awareness of Discovered Deficiencies: Radeam Johnson Date: 12/8/15

Signature of Facility Administrator Verifying Required Exit Drills Completed (if applicable): Radeam Johnson Date: 12/8/15

Signature of School District Inspector Reporting Deficiencies: Peace Date: 12-8-15

Signature of Local Municipal Inspection Authority Inspector Reporting Deficiencies (if applicable): \_\_\_\_\_ Date: \_\_\_\_\_