



AQUA ENVIRONMENTAL LAB

56 Church Hill Road • Newtown, CT 06470 • (203) 270-9973

Report of Analysis


Name: Parkway School
 Greenwich Public Schools - Cordes George
 290 Greenwich Ave
 Greenwich, CT 06830-6521

Sample ID#: 232139
Sample Type: Drinking Water
Sample Source: TL - Teachers Lounge
Sampler: PT
PWS ID: CT0570212

Sample Date: 7/9/2019 11:25 AM
Receipt Date: 7/9/2019 4:00 PM
Report Date: 7/10/2019
Sample Site: DISTRIBUTION SYSTEM

Parameter	Sample Result	Units	Method	Minimum Detection Level	Analysis Date	Analyst
Physical						
Color	<5	CU	SM2120B-22	0	7/10/2019	TJB
Odor	0	TON	SM2150B-22	0	7/9/2019	TJB
PH	7.2	pH	SM4500HB-22	0	7/9/2019	TJB
Turbidity	1.0	NTU	EPA 180.1	0.05	7/10/2019	TJB

ND = Not Detected
 * = Above Specified Limit

Report Approved by:  _____ CT Lic PH-0787 NY Lic 11706
 Lab Director

Analytical results relate to the samples as received at the laboratory. Report shall not be reproduced except in its entirety without written approval from the laboratory.