



**GROTON UTILITIES**

*Groton Utilities WTP Lab  
295 Meridian St. Groton, CT 06340  
(860) 446-4082  
Stephen Dietrich, Lab Director  
CT Lab Registration # PH-0409*

At Your Service

Groton Public Schools, 1st draw Lead and Copper testing

School: Claude Chester Elementary RESAMPLES

Action Level > **0.015**      **1.30**

Locations	Date of sampling	Lead	Copper
CC 4 - 1	6/23/18	0.0032	0.073
CC 4 - 2	6/23/18	0.002	0.063
CC 4 - 3	6/23/18	0.0014	0.054
CC 4 - 4	6/23/18	0.0013	0.048
CC 17 - 1	6/23/18	0.007	0.073
CC 17 - 2	6/23/18	0.0023	0.063
CC 17 - 3	6/23/18	0.0033	0.054
CC 17 - 4	6/23/18	<b>0.420</b>	0.048

All results in mg/L

All lead and copper analyses performed by our subcontract lab, CT DPH registration # PH-0116.

Collected by: MD

*Stephen Dietrich*  
Stephen Dietrich, Lab Director