



At Your Service

Pleasant Valley Elementary

Sampling date: August 30, 2016

(Water last used 8/29/16 10:00 pm)

PV 3: Room 3
PV 6: Room 5
PV 7: Art room, Room 7
PV 8: Room 6
PV 9: Room 4
PV 10: Room 2
PV 11: Room 1
PV 12: Wtr fount. Front of Room 1

Pb action level = 0.015

Lead results (mg/L)

First draw Flushed

Cu action level = 1.30

Copper (mg/L)

First draw Flushed

First-draw

Collection

time

0.003	0.001	0.07	0.02	6:15 AM
0.014	<0.001	0.12	0.02	6:18 AM
0.037	0.001	0.14	0.02	6:20 AM
0.023	0.001	0.13	0.05	6:22 AM
0.011	0.003	0.22	0.07	6:24 AM
0.006	0.001	0.14	0.04	6:28 AM
0.006	0.097	0.04	0.07	6:40 AM
0.098	0.010	0.07	0.04	6:43 AM

Claude Chester Elementary

Sampling Date: August 30, 2016

(Water last used 8/29/16 8:00 pm)

CC 2: Nurse

Pb action level = 0.015

Lead results (mg/L)

First draw Flushed

Cu action level = 1.30

Copper (mg/L)

First draw Flushed

First-draw

Collection

time

0.002	0.009	0.02	0.01	6:13 AM
-------	-------	------	------	---------

All analyses performed by Regional Water Authority Laboratory, PH-0411


 Stephen Dietrich
 Water Quality Manager
 Groton Utilities

Date: October 24, 2016