



GROTON UTILITIES

Groton Utilities WTP Lab
295 Meridian St. Groton, CT 06340
(860) 446-4082

Stephen Dietrich, Lab Director
CT Lab Registration # PH-0409

At Your Service

Groton Public Schools, 1st draw Lead and Copper testing

School: Fitch HS

Locations	Date of sampling	Action Level >	
		0.015 <i>Lead</i>	1.30 <i>Copper</i>
FHS 1	6/22/18	0.006	0.34
FHS 2	6/23/18	ND<0.0010	0.14
FHS 3	6/23/18	0.0012	0.088
FHS 4	6/22/18	0.0019	0.062
FHS 5	6/22/18	ND<0.0010	0.061
FHS 6	6/22/18	0.024	0.091
FHS 7	6/23/18	ND<0.0010	0.15
FHS 8	6/22/18	0.038	0.11
FHS 9	6/23/18	ND<0.0010	0.15
FHS 10	6/22/18	ND<0.0010	0.13
FHS 11	6/22/18	ND<0.0010	0.14
FHS 12	6/23/18	ND<0.0010	0.15
FHS 13	6/23/18	ND<0.0010	0.0094
FHS 14	6/23/18	ND<0.0010	0.14
FHS 15	6/23/18	0.0013	0.097
FHS 16	6/22/18	0.0066	0.094
FHS 17	6/22/18	0.0017	0.15
FHS 18	6/22/18	0.0022	0.084
FHS 19	6/23/18	0.0076	0.12
FHS 20	6/22/18	0.0011	0.087
FHS 21	6/22/18	0.0017	0.11
FHS 22	6/23/18	ND<0.0010	0.15
FHS 23	6/23/18	ND<0.0010	0.14
FHS 24	6/23/18	ND<0.0010	0.11
FHS 25	6/23/18	ND<0.0010	0.12
FHS 26	6/23/18	ND<0.0010	0.15
FHS 27	6/23/18	ND<0.0010	0.15
FHS 28	6/22/18	0.002	0.085
FHS 29	6/23/18	0.0035	0.078
FHS 30	6/23/18	0.067	0.021
FHS 31	6/23/18	0.140	0.058

All results in mg/L

All lead and copper analyses performed by our subcontract lab, CT DPH registration # PH-0116.

Collected by: MD

Stephen Dietrich, Lab Director

Groton, Connecticut 06340
T 860-446-4000 F 860-446-4098