



GROTON UTILITIES

At Your Service

Claude Chester Elementary

Sampling Date: April 27, 2016

(Water last used 4/26/16 10:00 pm)

	Pb action level = 0.015 Lead results (mg/L)		Cu action level = 1.30 Copper (mg/L)		First-draw Collection time
	First draw	Flushed	First draw	Flushed	
CC 1: Kitchen	0.004	<0.001	0.07	0.02	7:10 AM
CC 2: Nurse	0.130	0.010	0.11	0.04	7:13 AM
CC 3: Bubbl outs. Gym	0.001	0.002	0.09	0.02	7:15 AM
CC 4: Bubbl outs. rm 15	<0.001	<0.001	0.11	0.07	7:16 AM
CC 5: Bubbl opp. rm 25	<0.001	<0.001	0.10	0.06	7:17 AM
Bridge Market, Fort Hill Rd. <i>flushed</i>		<0.001		0.01	7:59 AM
Groton POE		<0.001		<0.01	8:45 AM
6-May-16					
CC 2 Nurse, resample (no aerator)	0.130	0.004	0.05	0.02	6:17 AM

Pleasant Valley Elementary

Sampling date: May 4, 2016

(Water last used 5/3/16 10:00 pm)

PV 1: Kitchen	0.012	<0.001	0.09	0.03	6:27 AM
PV 2: Nurse	0.002	<0.001	0.06	0.03	6:29 AM
PV 3: Bubbl in Art room	0.124	0.002	0.22	0.06	6:32 AM
PV 4: fount. across from café	0.004	0.002	0.10	0.04	6:34 AM
PV 5: fount. By room 11	<0.001	<0.001	0.06	0.08	6:36 AM
Michael Kia, 421 Route 12		<0.001		0.02	7:25 AM
Groton POE		<0.001		<0.01	8:45 AM

Charles Barnum Elementary

Sampling date: May 4, 2016

(Water last used 5/3/16 10:00 pm)

CB 1: Kitchen	<0.001	<0.001	0.03	0.02	6:33 AM
CB 2: Nurse	<0.001	<0.001	0.06	0.02	6:42 AM
CB 3: fount. by rm 12	<0.001	<0.001	0.04	0.02	6:36 AM
CB 4: fount. by rm 18	0.003	<0.001	0.09	0.04	6:37 AM
CB 5: fount. by main entrance	<0.001	<0.001	0.06	0.09	6:40 AM
Gungywamp Pump Station		<0.001		<0.01	7:35 AM

Mary Morrison Elementary

Sampling date: May 11, 2016

(Water last used 5/10/16 10:00 pm)

MM 1: Kitchen	0.001	<0.001	0.03	<0.01	6:30 AM
MM 2: Nurse's Office	0.001	<0.001	0.03	<0.01	6:31 AM
MM 3: fountain by rm 4	<0.001	<0.001	0.04	0.02	6:32 AM
MM 4: fountain by rm 15	<0.001	<0.001	0.04	0.02	6:34 AM
MM 5: fount. by main office	<0.001	<0.001	0.05	<0.01	6:35 AM
Henny Penny, route 12 & Tollgate		<0.001		0.01	7:17 AM
Groton POE		<0.001		<0.01	8:29 AM

295 Meridian Street

Groton, Connecticut 06340

T 860-446-4000 F 860-446-4098