



**GROTON UTILITIES**

At Your Service

**West Side Middle School**

Sampling date: May 11, 2016

(Water last used 5/10/16 9:30 pm)

|                              |
|------------------------------|
| WSMS 1: Kitchen              |
| WSMS 2: Nurse's Office       |
| WSMS 3: fount. by music room |
| WSMS 4: fount. by room 21    |
| WSMS 5: fount. by rm 43      |
| 300 Brandegee Ave.           |

Pb action level = 0.015

Lead results (mg/L)

First draw      Flushed

|        |        |
|--------|--------|
| 0.012  | <0.001 |
| <0.001 | <0.001 |
| <0.001 | <0.001 |
| <0.001 | <0.001 |
| <0.001 | <0.001 |
| <0.001 | <0.001 |
|        | <0.001 |

Cu action level = 1.30

Copper (mg/L)

First draw      Flushed

|      |       |
|------|-------|
| 0.12 | 0.02  |
| 0.06 | 0.03  |
| 0.08 | 0.07  |
| 0.09 | 0.09  |
| 0.08 | 0.05  |
|      | <0.01 |

First-draw

Collection

time

|         |
|---------|
| 6:30 AM |
| 6:34 AM |
| 6:36 AM |
| 6:38 AM |
| 6:37 AM |
| 7:25 AM |

All analyses performed by Regional Water Authority Laboratory, PH-0411

Joyce Brown  
Water Quality Manager  
Groton Utilities

Date:

5/25/16