



AQUA ENVIRONMENTAL LAB

56 Church Hill Road • Newtown, CT 06470 • (203) 270-9973

Report of Analysis

Name: Parkway School
 Greenwich Public Schools - Cordes George
 290 Greenwich Ave
 Greenwich, CT 06830-6521


Sample ID#: 235192
Sample Type: Drinking Water
Sampler: CV
PWS ID: CT0570212

Sample Date: 9/5/2019 12:50 PM
Receipt Date: 9/5/2019 2:35 PM
Report Date: 9/6/2019
Sample Site: WELL #2

Parameter	Sample Result	Units	Method	Minimum Detection Level	Analysis Date	Analyst
Biological						
MF Coliform Bacteria	0	CFU	SM9222D-22	0	9/5/2019	KH
MF e Coli Bacteria	0	CFU	SM9222D-22	0	9/5/2019	KH
Inorganic Compounds						
Chlorine, residual	ND	mg/L	M4500CLG-2	0.05	9/5/2019	KH

Comments: Based on the bacteriological examination, according to the Federal Safe Drinking Water Act (SDWA), this water was safe for drinking purposes at the time the sample was collected.

ND = Not Detected
 * = Above Specified Limit

Report Approved by:  _____ CT Lic PH-0787 NY Lic 11706
 Lab Director

Analytical results relate to the samples as received at the laboratory. Report shall not be reproduced except in its entirety without written approval from the laboratory.