

**Morris School District
Drinking Water Analysis
HILLCREST SCHOOL**

Results MG/L = Micrograms per Liter												
FD Sample #	Sample Location	FD Date	FD Time	Drinking Source	Test	First Draw	1 Minute	5 Minute	Retest 4/27/16			Corrective Action Taken
					3/18/16	4/1/16	4/13/16		FD	5 Minute	After Line Flush	
877120	Room #2	4/1/16	6:17 am	BB - O		0.017 MG/L	0.004 MG/L	0.001 MG/L				X
884886	Room #3	4/1/16	6:20 am	Right sink BB - O		0.010 MG/L	0.001 MG/L	<.001 MG/L				X
877118	Room #4	4/1/16	6:20 am	WFP - O		0.521 MG/L	0.008 MG/L	0.002 MG/L				X
877119	Room #5	4/1/16	6:21 am	BB - O		0.001 MG/L						X
877137	Room #6	4/1/16	6:22 am	BB - O		0.018 MG/L	0.001 MG/L	<.001 MG/L				X
877121	Room #7	4/1/16	6:24 am	WFP - O		0.025 MG/L	0.004 MG/L	0.003 MG/L				X
884872	Room #8	4/1/16	6:25 am	WFP - RP BB		0.030 MG/L	0.005 MG/L	0.004 MG/L				X
877123	Room #9	4/1/16	6:27 am	WFP - RP BB		0.009 MG/L						X
877116	Room #10	4/1/16	6:27 am	WFP - O		0.003 MG/L						X
877115	Room #11	4/1/16	6:33 am	WFP - O		0.013 MG/L	0.005 MG/L	0.005 MG/L				X
877117	Room #12	4/1/16	6:31 am	WFP - O		0.069 MG/L	0.004 MG/L	0.002 MG/L				X
877131	Room #13	4/1/16	6:30 am	WFP - O		0.009 MG/L						X
877114	Room #14	4/1/16	6:29 am	WFP - RP BB		0.006 MG/L						X
877125	Room #15	4/1/16	6:34 am	WFP - RP BB		0.005 MG/L						X
877130	Room #16	4/1/16	6:36 am	WFP - RP BB		0.014 MG/L	0.004 MG/L	0.002 MG/L				X
877127	Room #17	4/1/16	6:37 am	WFP - RP BB		0.010 MG/L	0.003 MG/L	0.002 MG/L				X
877129	Room #18	4/1/16	6:38 am	WFP - RP BB		0.012 MG/L	0.002 MG/L	0.001 MG/L				X
877126	Room #19	4/1/16	6:39 am	WFP - O		0.003 MG/L						X
877124	Room #20	4/1/16	6:41 am	WFP - RP BB		0.001 MG/L						X
877138	Room #23	4/1/16	6:45 am	WFP - O		0.013 MG/L	0.003 MG/L	0.003 MG/L				X
877134	WF in Hallway by Boiler Room WF Supply Line Hose Bib	3/31/16	6:19 am	Hallway Water Fountain		0.305 MG/L	0.038 MG/L	0.022 MG/L			0.025 MG/L 0.041 MG/L	NFFI - Repiped from new water source
877132	Water Fountain by nurse	3/31/16	6:16 am	Hallway Water Fountain	0.020 MG/L	0.016 MG/L	<.001 MG/L	0.002 MG/L				NFB
	Water Fountain by nurse	6/10/16	5:54 am			0.048 MG/L	<.001 MG/L					
	Water Fountain by nurse	6/10/16	2:00 pm	After 8 hours		0.036 MG/L						
877133	WF Cafeteria	3/31/16	6:20 am	WFP		0.006 MG/L						NFB
877135	WF Cafeteria	3/31/16	6:21 am	WFC - Elkay		0.009 MG/L						NFB
877136	Cafeteria - Kitchen Sink (triple)	3/31/16	6:40 am	Sink		<.001 MG/L						Signage
884884	Custodial Bathroom Sink	3/18/16	7:00 am	Sink	<.001 MG/L							Signage

Water Sample Key:

FD=First Draw W=Water F=Fountain P=Porcelain C=Chiller S=Sink BB=Bubbler O=Old Fountain Internal Parts RP BB=Replacement Bubbler

Corrective Action Key:

X=Removed NFB=Water Fountain/Bottle Filler with self contained lead filter NFFI=New Water Fountain & Filter Installed FI=Preexisting New Water Fountain lead filter installed

**Morris School District
Drinking Water Analysis
WOODLAND SCHOOL**

Line	Sample Location	FD Date	FD Time	Drinking Source	Test	Results MG/L = Micrograms per Liter			Corrective Action Taken
						First Draw*	1 Minute	5 Minute	
1	Outside WF (back of boiler room)	4/28/16	5:49 am	WF BB		0.015 MG/L	<.001 MG/L	<.001 MG/L	Not in Use
2	Kitchen Sink Island	4/28/16	5:36 am	Sink		0.008 MG/L	<.001 MG/L	<.001 MG/L	Signage
3	Custodian Bathroom Sink	4/28/16	5:39 am	Sink	<.001 MG/L	0.004 MG/L	<.001 MG/L	<.001 MG/L	Signage
4	Nurse's Office Sink	4/28/16	5:43 am	Sink		0.004 MG/L	<.001 MG/L	<.001 MG/L	Signage
5	Teacher's Lunchroom Sink	4/28/16	5:41 am	Sink		<.001 MG/L	<.001 MG/L	<.001 MG/L	Signage
6	Adult Men's Bathroom (Circle)	4/28/16	5:44 am	Sink		0.013 MG/L	0.003 MG/L	<.001 MG/L	Signage
7	Adult Women's Bathroom (Circle)	4/28/16	5:45 am	Sink (left)		0.042 MG/L	0.002 MG/L	<.001 MG/L	Signage
8	Room # 1	4/28/16	5:42 am	BB (Central Brass)		0.013 MG/L	<.001 MG/L	<.001 MG/L	X
9	Room # 3	4/28/16	5:44 am	BB (Elkay)		0.005 MG/L	<.001 MG/L	<.001 MG/L	X
10	Room # 5	4/28/16	5:46 am	Sink		0.004 MG/L	<.001 MG/L	<.001 MG/L	Signage
11	Speech Room (Infrequent Use)	4/28/16	5:52 am	Sink (Central Brass)		0.025 MG/L	0.051 MG/L	0.009 MG/L	Sink turned off
12	Room # 15	4/28/16	5:54 am	BB		0.005 MG/L	<.001 MG/L	<.001 MG/L	X
13	Room # 19	4/28/16	5:58 am	BB		<.001 MG/L	<.001 MG/L	<.001 MG/L	X
14	Room # 21	4/28/16	5:52 am	BB		<.001 MG/L	<.001 MG/L	<.001 MG/L	X
15	Room # 23	4/28/16	5:50 am	BB		<.001 MG/L	<.001 MG/L	<.001 MG/L	X
16	Room # 25	4/28/16	5:48 am	BB		<.001 MG/L	<.001 MG/L	<.001 MG/L	X
17	WFP (back of 19-21) In Wall	4/28/16	—	WFP (Turned off - Leaking)		—	<.001 MG/L	<.001 MG/L	X
18	WFP by Gym (Blue) In Wall	4/28/16	6:02 am	Hallway Water Fountain	0.002 MG/L	<.001 MG/L	<.001 MG/L	0.003 MG/L	NFB
19	WFC Outside Room #1	4/28/16	5:44 am	Hallway Water Fountain	<.001 MG/L	<.001 MG/L	<.001 MG/L	<.001 MG/L	NFB
20	Boy's Bathroom Circle Center Sink	4/28/16	5:40 am	Sink		0.002 MG/L	<.001 MG/L	<.001 MG/L	Signage
21	Girl's Bathroom Circle Sink	4/28/16	5:38 am	Sink		0.028 MG/L	<.001 MG/L	<.001 MG/L	Signage
22	New Fountain Installed on Circle			Hallway Water Fountain					NFB

Water Sample Key:

FD=First Draw W=Water F=Fountain P=Porcelain C=Chiller S=Sink BB=Bubbler O=Old Fountain Internal Parts RP BB=Replacement Bubbler

Corrective Action Key:

X=Removed NFB=Water Fountain/Bottle Filler with self contained lead filter NFFI=New Water Fountain & Filter Installed FI=Preexisting New Water Fountain lead filter installed

**Morris School District
Drinking Water Analysis
SUSSEX AVENUE SCHOOL**

Line	Sample Location	FD Date	FD Time	Drinking Source	Test	Results MG/L = Micrograms per Liter				Corrective Action Taken
						First Draw	1 Minute	5 Minute	Re-Test	
1	Cutodial/Foreperson Bathroom	4/29/16	5:36 am	Sink	<.001 MG/L	0.015 MG/L	0.001 MG/L	<.001 MG/L		Signage
2	5th Grade Boy's Bathroom LL (Center)	4/29/16	5:37 am	Sink (center)		0.009 MG/L	<.001 MG/L	<.001 MG/L		Signage
3	5th Grade Girl's Bathroom LL (Center)	4/29/16	5:38 am	Sink (center)		0.012 MG/L	<.001 MG/L	<.001 MG/L		Signage
4	Adult Women's Bathroom LL	4/29/16	5:40 am	Sink		0.060 MG/L	<.001 MG/L	<.001 MG/L		Signage
5	Adult Men's Bathroom LL	4/29/16	5:40 am	Sink		0.034 MG/L	0.002 MG/L	<.001 MG/L		Signage
6	5th Gr. across from L-4 WFC Oasis (new)	4/29/16	5:42 am	Hallway Water Fountain		<.001 MG/L	0.002 MG/L	<.001 MG/L		NFB
7	Teacher's Lunchroom LL Sink	4/29/16	5:45 am	Sink	0.005 MG/L	0.003 MG/L	<.001 MG/L	<.001 MG/L		Signage
8	Kitchen Bathroom	4/29/16	5:45 am	Sink		0.031 MG/L	0.003 MG/L	0.001 MG/L		Signage
9	Kitchen A (Inside New)	4/29/16	5:48 am	Sink (Inside new)		0.093 MG/L	0.019 MG/L	0.007 MG/L		Sink turned off
10	Kitchen B (Outside Wall-right)	4/29/16	5:48 am	Sink (Outside Wall - right)		0.033 MG/L	<.001 MG/L	<.001 MG/L		Signage
11	3rd Grade Hallway A (WFP-left)	4/29/16	5:49 am	Hallway Water Fountain		0.016 MG/L	0.002 MG/L	<.001 MG/L		NFB
12	3rd Grade Hallway B (WFP-right)	4/29/16	5:49 am	Hallway Water Fountain		0.007 MG/L	<.001 MG/L	0.001 MG/L		X
13	3rd Grade Hallway C (WFP)	4/29/16	5:40 am	Hallway Water Fountain		0.002 MG/L	<.001 MG/L	<.001 MG/L		X
14	3rd Grade Girl's Bathroom	4/29/16	5:39 am	Sink		0.019 MG/L	<.001 MG/L	<.001 MG/L		Signage
15	3rd Grade Boy's Bathroom	4/29/16	5:41 am	Sink		0.008 MG/L	<.001 MG/L	<.001 MG/L		Signage
16	Hallway outside Library A (WFP-high)	4/29/16	5:44 am	Hallway Water Fountain		0.014 MG/L	<.001 MG/L	<.001 MG/L		NFFI
17	Hallway outside Library B (WFP-low) NOT IN USE	—	—	Hallway Water Fountain - OFF		—	—	—		X
18	Library Office Sink	4/29/16	5:46 am	Sink		0.003 MG/L	0.006 MG/L	0.002 MG/L		Signage
19	Room #108 Sink	4/29/16	5:48 am	Sink		0.050 MG/L	<.001 MG/L	<.001 MG/L		Signage
20	Hallway in front of Library Sink (By Room #106)	4/29/16	5:50 am	Sink		0.014 MG/L	0.047 MG/L	<.001 MG/L		Sink turned off
21	Nurse's Office Sink	4/29/16	5:55 am	Sink		0.168 MG/L	<.001 MG/L	<.001 MG/L		Signage
22	Nurse's Bathroom Sink	4/29/16	5:53 am	Sink		0.008 MG/L	<.001 MG/L	<.001 MG/L		Signage
23	Outside Main Office (WFP)	4/29/16	5:52 am	Hallway Water Fountain		0.006 MG/L	<.001 MG/L	<.001 MG/L		NFB
24	Unisex Bathroom by Main Entrance Sink	4/29/16	5:54 am	Sink		0.041 MG/L	0.002 MG/L	<.001 MG/L		Signage
25	Woman's Bathroom by Main Entrance	4/29/16	5:53 am	Sink		0.023 MG/L	<.001 MG/L	<.001 MG/L		Signage
26	WFP Between Rm. 101 & 103 A (left) RP BB	4/29/16	5:51 am	Hallway Water Fountain		0.014 MG/L	0.007 MG/L	0.003 MG/L		NFB
27	WFP Between Rm. 101 & 103 B (right) RP BB	4/29/16	5:50 am	Hallway Water Fountain		0.017 MG/L	0.002 MG/L	0.002 MG/L		X
	WFP Between Rm. 101 & 103 B (right) RP BB	6/10/16	6:00 am			0.013 MG/L	0.005 MG/L			
	WFP Between Rm. 101 & 103 B (right) RP BB	6/10/16	2:00 pm	After 8 hours		0.012 MG/L				
28	Science Room Sink (Room #101)	4/29/16	5:49 am	Sink		0.011 MG/L	0.002 MG/L	<.001 MG/L		Signage
29	Art Room Middle Faucet - Room #100	4/29/16	5:48 am	Sink		0.088 MG/L	0.003 MG/L	0.001 MG/L		Signage
30	Boy's Bathroom by Gym Sink (left)	4/29/16	5:46 am	Sink (left)		0.007 MG/L	<.001 MG/L	<.001 MG/L		Signage
31	Girl's Bathroom by Gym Sink (left)	4/29/16	5:44 am	Sink (left)		0.004 MG/L	<.001 MG/L	<.001 MG/L		Signage
32	Room #102	4/29/16	5:45 am	Sink		<.001 MG/L	<.001 MG/L	<.001 MG/L		Signage
33	Gym Office Sink	4/29/16	5:42 am	Sink		0.108 MG/L	0.006 MG/L	0.001 MG/L		Signage
34	Gym (WFP) RP BB	4/29/16	5:41 am	WFP RP BB	0.009 MG/L	0.014 MG/L	0.008 MG/L	0.003 MG/L		X
35	New Fountain Installed in Gym			Water Fountain						NFFI

**Morris School District
Drinking Water Analysis
ALFRED VAIL**

Line	Sample Location	FD Date	FD Time	Drinking Source	Results MG/L = Micrograms per Liter				Corrective Action Taken	Results After Corrective Action
					Test	First Draw	1 Minute	5 Minute		
1	Kitchen A Sink	4/30/16	5:47 am	Sink		0.007 MG/L	<.001 MG/L	<.001 MG/L	Signage	
2	Kitchen B Triple Sink	4/30/16	5:38 am	Triple Sink		0.009 MG/L	<.001 MG/L	<.001 MG/L	Signage	
3	Cafeteria WFC LK	4/30/16	5:39 am	WFC LK		<.001 MG/L	<.001 MG/L	<.001 MG/L	NFB	
4	Room # 106 (Teacher) Sink	4/30/16	5:40 am	Sink		0.002 MG/L	<.001 MG/L	<.001 MG/L	Signage	
5	Boy's Bathroom Sink	4/30/16	5:41 am	Sink		0.003 MG/L	<.001 MG/L	<.001 MG/L	Signage	
6	Woman's Bathroom Sink	4/30/16	5:42 am	Sink		0.004 MG/L	<.001 MG/L	<.001 MG/L	Signage	
7	Men's Bathroom Sink	4/30/16	5:42 am	Sink	<.001 MG/L	0.012 MG/L	<.001 MG/L	<.001 MG/L	Signage	
8	Girl's Bathroom Sink	4/30/16	5:43 am	Sink		<.001 MG/L	<.001 MG/L	<.001 MG/L	Signage	
9	Room # 105 Sink	4/30/16	5:43 am	Sink		0.013 MG/L	0.002 MG/L	<.001 MG/L	Signage	
10	Room # 103 A Sink (Left)	4/30/16	5:45 am	Sink (Left)		0.007 MG/L	<.001 MG/L	<.001 MG/L	Signage	
11	Room # 103 B WFP	4/30/16	5:45 am	WFP		0.005 MG/L	<.001 MG/L	<.001 MG/L	X	
12	P.E. Office	4/30/16	5:46 am	Sink		0.016 MG/L	0.002 MG/L	<.001 MG/L	Signage	
13	Room # 102 Sink	4/30/16	5:49 am	Sink		0.005 MG/L	<.001 MG/L	<.001 MG/L	Signage	
14	Hall by Gym and Auditorium - WFP RP BB	4/30/16	5:50 am	Hallway Water Fountain	0.002 MG/L	0.004 MG/L	<.001 MG/L	<.001 MG/L	NFB	
15	Hall by Room # 103 - WFP RP BB	4/30/16	5:52 am	Hallway Water Fountain		0.005 MG/L	0.002 MG/L	<.001 MG/L	NFFI	
16	Hall by Room # 101 WFC - Elkay	4/30/16	5:53 am	Hallway Water Fountain		0.002 MG/L	0.002 MG/L	<.001 MG/L	NFFI	
17	Room # 333 (Nurse) A WFC - Elkay	4/30/16	5:55 am	WFC - Elkay		<.001 MG/L	<.001 MG/L	<.001 MG/L	NFFI	
18	Room # 333 (Nurse) B (Sink office)	4/30/16	5:55 am	Sink		0.004 MG/L	<.001 MG/L	<.001 MG/L	Signage	
19	Nurse's Bathroom Sink	4/30/16	5:56 am	Sink		<.001 MG/L	<.001 MG/L	<.001 MG/L	Signage	
20	Room # 117 A BB	4/30/16	5:57 am	BB		<.001 MG/L	<.001 MG/L	<.001 MG/L	X	
21	Room # 117 Bathroom Sink	4/30/16	5:58 am	Sink		<.001 MG/L	<.001 MG/L	<.001 MG/L	Signage	
22	Room # 115 A BB	4/30/16	5:59 am	BB		<.001 MG/L	<.001 MG/L	<.001 MG/L	X	
23	Room # 115 Bathroom Sink	4/30/16	5:59 am	Sink		<.001 MG/L	<.001 MG/L	<.001 MG/L	Signage	
24	Room # 113 A BB	4/30/16	5:40 am	BB		<.001 MG/L	<.001 MG/L	<.001 MG/L	X	
25	Room # 113 Bathroom	4/30/16	5:39 am	Sink		<.001 MG/L	<.001 MG/L	<.001 MG/L	Signage	
26	Room # 111 A BB	4/30/16	5:28 am	BB		<.001 MG/L	<.001 MG/L	<.001 MG/L	X	
27	Room # 111 Bathroom Sink	4/30/16	5:27 am	Sink		0.007 MG/L	<.001 MG/L	<.001 MG/L	Signage	
28	Room # 110 Sink	4/30/16	5:41 am	Sink		0.005 MG/L	0.007 MG/L	0.002 MG/L	Signage	
29	Room # 110 Bathroom Sink	4/30/16	5:42 am	Sink		0.025 MG/L	0.002 MG/L	0.001 MG/L	Signage	
30	Main Office Sink	4/30/16	5:44 am	Sink		<.001 MG/L	<.001 MG/L	<.001 MG/L	Signage	
31	Main Office Bathroom	4/30/16	5:45 am	Sink		<.001 MG/L	<.001 MG/L	<.001 MG/L	Signage	
32	Room # 101 Sink (left)	4/30/16	5:47 am	Sink (Left)		0.003 MG/L	<.001 MG/L	<.001 MG/L	Signage	
33	216/218 Office	4/30/16	5:59 am	Sink		0.017 MG/L	<.001 MG/L	0.002 MG/L	Signage	
34	Hall by Elevator A WFC (High)	4/30/16	5:52 am	Hallway Water Fountain	<.001 MG/L	<.001 MG/L	<.001 MG/L	<.001 MG/L	X	
35	Hall by Elevator B WFC (Low)	4/30/16	5:53 am	Hallway Water Fountain		<.001 MG/L	<.001 MG/L	<.001 MG/L	NFB	
36	Girl's BR (2nd Floor by Art Room) Sink - Right	4/30/16	5:54 am	Sink (right)		<.001 MG/L	<.001 MG/L	<.001 MG/L	Signage	
37	Room # 215 (Art) A BB	4/30/16	5:56 am	BB		<.001 MG/L	<.001 MG/L	<.001 MG/L	X	

38	Room # 215 (Art) B Sink	4/30/16	5:56 am	Sink		0.005 MG/L	<.001 MG/L	<.001 MG/L	Signage	
39	Room # 214 B BB	4/30/16	6:09 am	BB		0.011 MG/L	<.001 MG/L	<.001 MG/L	X	
40	Room # 213 B Sink	4/30/16	6:03 am	Sink		0.003 MG/L	<.001 MG/L	0.002 MG/L	Signage	
41	Room # 212 B BB	4/30/16	6:06 am	BB		0.007 MG/L	0.001 MG/L	0.001 MG/L	X	
42	Bathroom Room # 212	4/30/16	6:07 am	Sink		<.001 MG/L	<.001 MG/L	<.001 MG/L	Signage	
43	Boy's Bathroom (2nd Floor)	4/30/16	6:17 am	Sink		0.007 MG/L	<.001 MG/L	<.001 MG/L	Signage	
44	Room # 211 B BB	4/30/16	6:12 am	BB		0.474 MG/L	<.001 MG/L	<.001 MG/L	X	
45	Room # 211 Bathroom Sink	4/30/16	6:08 am	Sink		0.004 MG/L	0.001 MG/L	<.001 MG/L	Signage	
46	Girl's BR (2nd floor by Rm. 210) Sink - Right	4/30/16	6:07 am	Sink (right)		0.004 MG/L	<.001 MG/L	<.001 MG/L	Signage	
47	Hallway by Room # 210 WFC Oasis (New)	4/30/16	6:06 am	Hallway Water Fountain		<.001 MG/L	0.001 MG/L	<.001 MG/L	FI	
48	Room # 210 Sink	4/30/16	6:05 am	Sink		0.005 MG/L	0.004 MG/L	<.001 MG/L	Signage	
49	Room # 209 Sink	4/30/16	6:11 am	Sink		0.008 MG/L	<.001 MG/L	<.001 MG/L	Signage	
50	Room # 208 BB	4/30/16	6:09 am	BB		0.007 MG/L	<.001 MG/L	<.001 MG/L	X	
51	Bathroom by Room #230	4/30/16	6:20 am	Sink		0.008 MG/L	<.001 MG/L	<.001 MG/L	Signage	
52	Room # 207 A BB	4/30/16	6:05 am	BB		0.004 MG/L	0.002 MG/L	<.001 MG/L	X	
53	Room # 206 A BB (New Push Button)	4/30/16	6:03 am	BB (new push button)		0.039 MG/L	0.001 MG/L	0.002 MG/L	X	
54	Room # 205 A Sink	4/30/16	6:02 am	Sink		0.016 MG/L	0.002 MG/L	0.001 MG/L	Signage	
55	Boy's BR (2nd floor by Rm. 205) Sink (RT)	4/30/16	6:00 am	Sink (right)		0.004 MG/L	<.001 MG/L	<.001 MG/L	Signage	
56	Hallway by Room # 204 WFC LK (new)	4/30/16	5:59 am	Hallway Water Fountain		<.001 MG/L	0.022 MG/L	0.005 MG/L	FI	
57	Closet (204 A) Sink	4/30/16	5:57 am	Sink		0.017 MG/L	0.003 MG/L	0.001 MG/L	Signage	
58	Girl's BR (2nd Floor) Sink by Room #204	4/30/16	5:56 am	Sink		0.013 MG/L	<.001 MG/L	0.001 MG/L	Signage	
59	Greenhouse	4/30/16	5:53 am	Sink		0.004 MG/L	<.001 MG/L	<.001 MG/L	Signage	
60	Room # 203 A BB	4/30/16	5:51 am	BB		0.009 MG/L	0.002 MG/L	<.001 MG/L	X	
61	Room # 202 A Sink BB	4/30/16	5:46 am	BB		0.037 MG/L	0.002 MG/L	<.001 MG/L	X	
62	Room # 201 A BB	4/30/16	5:45 am	BB		0.060 MG/L	0.003 MG/L	0.004 MG/L	X	
63	Room # 217 (Science) A BB	4/30/16	5:40 am	BB		<.001 MG/L	<.001 MG/L	<.001 MG/L	X	
64	Room # 217 (Science) Sink (RT)	4/30/16	5:41 am	Sink (right)		0.079 MG/L	<.001 MG/L	0.003 MG/L	Signage	
65	Room # 217 (Office) Sink	4/30/16	5:42 am	Sink		0.003 MG/L	<.001 MG/L	<.001 MG/L	Signage	
66	Staff Bathroom (2nd Floor)	4/30/16	6:20 am	Sink		<.001 MG/L	<.001 MG/L	<.001 MG/L	Signage	
67	Boy's Bathroom by elevator (Left Sink)	4/30/16	5:55 am	Sink (Left)		<.001 MG/L	<.001 MG/L	<.001 MG/L	Signage	
68	Hallway by Room # 202 WFP	4/30/16	5:50 am	Hallway Water Fountain		0.005 MG/L	0.002 MG/L	0.001 MG/L	X	
69	Room # 311 Sink	4/30/16	6:11 am	Sink		0.005 MG/L	<.001 MG/L	<.001 MG/L	Signage	
70	Room # 304 Sink	4/30/16	6:07 am	Sink		0.012 MG/L	0.001 MG/L	<.001 MG/L	Signage	

Water Sample Key:

FD=First Draw **W**=Water **F**=Fountain **P**=Porcelain **C**=Chiller **S**=Sink **BB**=Bubbler **O**=Old Fountain Internal Parts **RP BB**=Replacement Bubbler

Corrective Action Key:

removed **NFB**=Water Fountain/Bottle Filler with self contained lead filter **NFFI**=New Water Fountain & Filter Installed **FI**=Preexisting New Water Fountain lead filter installed

**Morris School District
Drinking Water Analysis
NORMANDY PARK**

Line	Sample Location	FD Date	FD Time	Drinking Source	Results MG/L = Micrograms per Liter				Corrective Action Taken
					Test	First Draw	1 Minute	5 Minute	
1	Custodial Bathroom Sink	04/27/16	5:40 am	Sink	<.001 MG/L	<.001 MG/L			Signage
2	Adult BR Sink (Main Hall across from kitchen)	04/27/16	5:41 am	Sink		<.001 MG/L			Signage
3	Kitchen Triple Sink	04/27/16	5:43 am	Sink		<.001 MG/L			Signage
4	Kitchen Sink by Lunchroom	04/27/16	5:45 am	Sink		<.001 MG/L			Signage
5	Teacher's Lunchroom Sink	04/27/16	5:48 am	Sink		0.005 MG/L			Signage
6	Girl's Bathroom Sink by Gym (right)	04/27/16	5:49 am	Sink		<.001 MG/L			Signage
7	Boy' Bathroom Sink by Gym	04/27/16	5:51 am	Sink		<.001 MG/L			Signage
8	Nurse Office Sink	04/27/16	5:52 am	Sink		<.001 MG/L			Signage
9	Main Office Bathroom Sink	04/27/16	5:53 am	Sink		<.001 MG/L			Signage
10	WFP Hall by Teacher's Lunch (low flow-not used)	04/27/16	5:55 am	Hallway Water Fountain		0.004 MG/L			NFFI
11	WFP Gym Hall by Girl's Bathroom	04/27/16	5:59 am	Hallway Water Fountain	<.001 MG/L	<.001 MG/L			NFB
12	WF by boy's BR - NOT WORKING	04/27/16	—	—		—			NFFI
13	WFP by Main Office (low flow - not used)	04/27/16	5:58 am	Hallway Water Fountain		0.008 MG/L			NFB
14	Room # 30 Art Room Triple Sink by UV	04/27/16	5:59 am	Sink		0.012 MG/L			Signage
15	Room # 30 WF BB	04/27/16	6:01 am	WF BB		<.001 MG/L			X
16	Room # 5 Sink	04/27/16	6:02 am	Sink		<.001 MG/L			Signage
17	Room # 6 WF BB	04/27/16	6:04 am	WF BB		<.001 MG/L			X
18	Room # 7 Sink	04/27/16	6:05 am	Sink		<.001 MG/L			Signage
19	WFC by Handicap Bathroom	04/27/16	5:43 am	Hallway Water Fountain		<.001 MG/L			NFFI
20	Boy' Bathroom Sink (2/3 Hallway)	04/27/16	5:38 am	Sink		0.003 MG/L			Signage
21	Girl's Bathroom Sink (2/3 Hallway)	04/27/16	5:41 am	Sink		<.001 MG/L			Signage
22	Adult Bathroom (2/3 Hallway)	04/27/16	5:39 am	Sink		0.004 MG/L			Signage
23	Room # 29 Sink	04/27/16	5:44 am	Sink		<.001 MG/L			Signage
24	Room # 8 Sink	04/27/16	5:45 am	Sink		<.001 MG/L			Signage
25	Room # 28 Sink	04/27/16	5:46 am	Sink		<.001 MG/L			Signage
26	Room # 27 Sink	04/27/16	5:48 am	Sink		0.003 MG/L			Signage
27	Room # 27 WF BB	04/27/16	5:49 am	WF BB		<.001 MG/L			X
28	Room # 10 Sink	04/27/16	5:50 am	Sink		<.001 MG/L			Signage
29	Room # 10 WF BB	04/27/16	5:51 am	WF BB		<.001 MG/L			X
30	Room # 11 Sink	04/27/16	5:55 am	Sink		0.003 MG/L			Signage
31	Room # 11 WF BB	04/27/16	5:54 am	WF BB		<.001 MG/L			X
32	Room # 19 Sink	04/27/16	5:58 am	Sink		<.001 MG/L			Signage
33	Room # 19 WF BB	04/27/16	5:58 am	WF BB		<.001 MG/L			X
34	Room # 12 Sink	04/27/16	6:00 am	Sink		<.001 MG/L			Signage
35	Room # 12 WF BB	04/27/16	6:00 am	WF BB		<.001 MG/L			X
36	4/5 Hall WFC Elkay by Room #13	04/27/16	6:02 am	Hallway Water Fountain		<.001 MG/L			NFB
37	Room # 18 Sink	04/27/16	6:03 am	Sink		<.001 MG/L			Signage

38	Room # 18 WF BB	04/27/16	6:03 am	WF BB		<.001 MG/L			X
39	Room # 13 Sink	04/27/16	6:05 am	Sink		0.006 MG/L			Signage
40	Room # 13 WF BB	04/27/16	5:41 am	WF BB		0.002 MG/L			X
41	Room #15 WF BB	04/27/16	6:04 am	WF BB		<.001 MG/L			X
42	Room # 14 Sink A (right)	04/27/16	6:07 am	Sink		0.011 MG/L			Signage
43	Room # 14 WF BB	04/27/16	6:06 am	WF BB		<.001 MG/L			X
44	Room # 23 WF BB	04/27/16	6:01 am	WF BB		<.001 MG/L			X
45	Room #22 WF BB	04/27/16	6:00 am	WF BB		<.001 MG/L			X
46	Room # 24 Sink	04/27/16	5:58 am	Sink		0.002 MG/L			Signage
47	Room # 24 WF BB	04/27/16	5:57 am	WF BB		<.001 MG/L			X
48	Room # 21 Sink	04/27/16	05:55	Sink		<.001 MG/L			Signage
49	Room # 21 WF BB	04/27/16	5:55 am	WF BB		<.001 MG/L			X
50	Room # 25 Sink	04/27/16	5:53 am	Sink		<.001 MG/L			Signage
51	Room # 25 WF BB	04/27/16	5:52 am	WF BB		<.001 MG/L			X
52	Room # 26 WF BB	04/27/16	5:51 am	WF BB		<.001 MG/L			X
53	Boy' Bathroom (K Wing Hall)	04/27/16	5:46 am	Sink		<.001 MG/L			Signage
54	Girl's Bathroom (K Wing Hall)	04/27/16	5:47 am	Sink		<.001 MG/L			Signage
55	K Wing Hall (Left) WFC (by room #26)	04/27/16	5:49 am	Hallway Water Fountain	<.001 MG/L	<.001 MG/L			X
56	K Wing Hall (Right) WFC (by room #26)	04/27/16	5:48 am	Hallway Water Fountain		<.001 MG/L			NFFI

Water Sample Key:

FD=First Draw **W**=Water **F**=Fountain **P**=Porcelain **C**=Chiller **S**=Sink **BB**=Bubbler **O**=Old Fountain Internal Parts **RP BB**=Replacement Bubbler

Corrective Action Key:

X=Removed **NFB**=Water Fountain/Bottle Filler with self contained lead filter **NFFI**=New Water Fountain & Filter Installed **FI**=Preexisting New Water Fountain lead filter installed

**Morris School District
Drinking Water Analysis
THOMAS JEFFERSON**

Line	Sample Location	FD Date	FD Time	Drinking Source	Results MG/L = Micrograms per Liter				Corrective Action Taken
					Test	First Draw	1 Minute	5 Minute	
1	Room # 1 Sink	4/26/2016	5:05 am	Sink		0.021 MG/L			Signage
2	Room # 1 WFP	4/26/2016	5:06 am	WFP		0.012 MG/L			X
3	Room # 2 Sink	4/26/2016	5:08 am	Sink		0.013 MG/L			Signage
4	Room # 2 WFP	4/26/2016	5:08 am	WFP		0.012 MG/L			X
5	Room # 3 Sink	4/26/2016	5:12 am	Sink		0.011 MG/L			Signage
6	Room # 3 WFP (NEW BB)	4/26/2016	5:13 am	WFP (New BB)		0.011 MG/L			X
7	Room # 4 Sink	4/26/2016	5:10 am	Sink		0.008 MG/L			Signage
8	Room # 4 WFP	4/26/2016	5:11 am	WFP		0.005 MG/L			X
9	Room # 5 Sink	4/26/2016	5:21 am	Sink		0.019 MG/L			Signage
10	Room # 5 WFP	4/26/2016	5:20 am	WFP		0.006 MG/L			X
11	Room # 6 Sink	4/26/2016	5:15 am	Sink		0.010 MG/L			Signage
12	Room # 6 WFP	4/26/2016	5:15 am	WFP		0.007 MG/L			X
13	Room # 7 Sink	4/26/2016	5:28 am	Sink		0.014 MG/L			Signage
14	Room # 7 WFP (NEW BB)	4/26/2016	5:30 am	WFP (New BB)		0.008 MG/L			X
15	Room # 8 Sink	4/26/2016	5:24 am	Sink		0.007 MG/L			Signage
16	Room # 8 WFP	4/26/2016	5:26 am	WFP		0.003 MG/L			X
17	Room # 9 Sink	4/26/2016	5:05 am	Sink		0.024 MG/L			Signage
18	Room # 9 WFP (NEW BB)	4/26/2016	5:06 am	WFP (New BB)		0.020 MG/L			X
19	Room # 10 Sink	4/26/2016	5:13 am	Sink		<.001 MG/L			Signage
20	Room # 10 WFP (NEW BB)	4/26/2016	5:14 am	WFP (New BB)		0.004 MG/L			X
21	Room # 11 Sink	4/26/2016	5:11 am	Sink		0.002 MG/L			Signage
22	Room # 11 WFP (NEW BB)	4/26/2016	5:10 am	WFP (New BB)		0.014 MG/L			X
23	Room # 12 Sink	4/26/2016	5:15 am	Sink		0.004 MG/L			Signage
24	Room # 12 WFP (NEW BB)	4/26/2016	5:16 am	WFP (New BB)		<.001 MG/L			X
25	Room # 13 Sink	4/26/2016	5:20 am	Sink		0.010 MG/L			Signage
26	Room # 13 WFP	4/26/2016	5:19 am	WFP		0.008 MG/L			X
27	Room # 14 Sink	4/26/2016	5:23 am	Sink		0.028 MG/L			Signage
28	Room # 14 WFP	4/26/2016	5:22 am	WFP		0.031 MG/L			X
29	Room # 15 Sink	4/26/2016	5:26 am	Sink	0.003 MG/L	0.005 MG/L			Signage
30	Room # 15 WFP (NEW BB)	4/26/2016	5:25 am	WFP (New BB)		0.002 MG/L			X
31	Room # 16 Sink	4/26/2016	5:30 am	Sink		0.006 MG/L			Signage
32	Room # 16 WFP (NEW BB)	4/26/2016	5:31 am	WFP (New BB)		0.002 MG/L			X
33	Room # 17 Sink	4/26/2016	5:06 am	Sink		0.003 MG/L			Signage

34	Room # 17 WFP (NEW BB)	4/26/2016	5:04 am	WFP (New BB)		0.005 MG/L			X
35	Room # 18 Sink	4/26/2016	5:09 am	Sink		0.003 MG/L			Signage
36	Room # 18 WFP	4/26/2016	5:07 am	WFP		0.004 MG/L			X
37	Room # 19 Sink	4/26/2016	5:12 am	Sink		0.019 MG/L			Signage
38	CST - Dr. B Bathroom Sink	4/26/2016	5:20 am	Sink		0.011 MG/L			Signage
39	Art/Music Sink Left	4/26/2016	5:14 am	Sink		0.004 MG/L			Signage
40	Nurse's Office Sink	4/26/2016	5:22 am	Sink		0.009 MG/L			Signage
41	Teacher's Room Lunch Sink	4/26/2016	5:30 am	Sink		0.013 MG/L			Signage
42	Main Office Bathroom Sink	4/26/2016	5:24 am	Sink		0.006 MG/L			Signage
43	Hallway WF A (Out to courtyard Left)	4/26/2016	5:17 am	Hallway Water Fountain	0.002 MG/L	<.001 MG/L			NFB
44	Hallway WF B (Out to courtyard Right)	4/26/2016	5:18 am	Hallway Water Fountain		<.001 MG/L			NFFI
45	Kitchen A Double	4/26/2016	5:35 am	Sink		0.005 MG/L			Signage
46	Kitchen B Handwash	4/26/2016	5:37 am	Sink		<.001 MG/L			Signage
47	Handicap Bathroom by #13	4/26/2016	5:38 am	Sink		<.001 MG/L			Signage
48	Girl's Bathroom by #15	4/26/2016	5:42 am	Sink		0.004 MG/L			Signage
49	Boy's Bathroom by #14	4/26/2016	5:40 am	Sink		0.002 MG/L			Signage
50	Girl's Bathroom by 10-12	4/26/2016	5:35 am	Sink		<.001 MG/L			Signage
51	Boy's Bathroom by 10-12	4/26/2016	5:36 am	Sink		<.001 MG/L			Signage
52	Boy's BR out to courtyard RT Sink	4/26/2016	5:27 am	Sink		<.001 MG/L			Signage
53	Girl's BR out to courtyard LT Sink	4/26/2016	5:28 am	Sink		0.003 MG/L			Signage
54	New Fountain across from Auditorium			Hallway Water Fountain					NFB
55	New Fountain across from Custodial Office			Hallway Water Fountain					NFB

Water Sample Key:

FD=First Draw **W**=Water **F**=Fountain **P**=Porcelain **C**=Chiller **S**=Sink **BB**=Bubbler **O**=Old Fountain Internal Parts **RP BB**=Replacement Bubbler

Corrective Action Key:

X=Removed **NFB**=Water Fountain/Bottle Filler with self contained lead filter **NFFI**=New Water Fountain & Filter Installed **FI**=Preexisting New Water Fountain lead filter installed

**Morris School District
Drinking Water Analysis
ALEXANDER HAMILTON**

					Results MG/L = Micrograms per Liter				
Line	Sample Location	FD Date	FD Time	Drinking Source	Test	First Draw	1 Minute	5 Minute	Corrective Action Taken
1	Room # 1 Sink	4/28/16	5:39 am	Sink		0.006 MG/L			Signage
2	WFP (Not Working)	—	—	WFP (Not Working)		—			X
3	Room # 2 BB	4/28/16	5:45 am	BB		0.010 MG/L			X
4	Room # 2 Sink	4/28/16	5:44 am	Sink		0.006 MG/L			Signage
5	Room # 3 (RIGHT SINK)	4/28/16	5:46 am	Sink		<.001 MG/L			Signage
6	Room # 4 Sink	4/28/16	5:47 am	Sink		0.004 MG/L			Signage
7	Custodial Lunchroom Sink	4/28/16	5:47 am	Sink	<.001 MG/L	0.004 MG/L			Signage
8	Kitchen A (handwashing sink)	4/28/16	5:51 am	Sink		0.015 MG/L			Signage
9	Kitchen B (left faucet cooking area)	4/28/16	5:52 am	Sink		0.004 MG/L			Signage
10	Girl's Room Sink (right)	4/28/16	5:53 am	Sink		0.002 MG/L			Signage
11	Boy's Room Sink (right)	4/28/16	5:54 am	Sink		0.004 MG/L			Signage
12	WFC by Room #9	4/28/16	5:55 am	Hallway Water Fountain	0.002 MG/L	0.003 MG/L			NFB
13	WFC by Custodial Room	4/28/16	5:57 am	Hallway Water Fountain		<.001 MG/L			NFFI
14	Room # 19 WF BB (old)	4/28/16	6:05 am	WF BB (old)		0.005 MG/L			X
15	Room # 18 WF BB (old)	4/28/16	6:05 am	WF BB (old)		0.474 MG/L	0.050 MG/L	0.014 MG/L	X
16	Girl's Room Second Floor by Room #14	4/28/16	5:54 am	Sink		<.001 MG/L			Signage
17	Hallway (2nd Floor by Room #17)	4/28/16	6:05 am	Hallway Water Fountain		<.001 MG/L			NFB - New Water Supply Line Replaced Jan 2014
18	Room # 16 WF BB	4/28/16	6:00 am	WF BB		0.036 MG/L	0.036 MG/L	0.009 MG/L	X
19	Office Sink	4/28/16	5:57 am	Sink		0.009 MG/L			Signage
20	Room # 13 Bathroom Sink	4/28/16	5:50 am	Sink		0.006 MG/L			Signage
21	Second floor by Room #12	4/28/16	5:48 am	Hallway Water Fountain	<.001 MG/L	<.001 MG/L			NFFI
22	Room # 12 Sink	4/28/16	5:44 am	Sink		0.034 MG/L	0.006 MG/L	0.003 MG/L	Signage
23	Room # 11 Sink	4/28/16	5:46 am	Sink		0.022 MG/L	0.019 MG/L	<.001 MG/L	Signage
24	Faculty Room Sink	4/28/16	5:42 am	Sink		0.005 MG/L			Signage
25	Room # 10 Sink	4/28/16	5:41 am	Sink		0.016 MG/L	<.001 MG/L	0.004 MG/L	Signage
26	Room # 21 Sink	4/28/16	5:41 am	Sink		0.019 MG/L	0.003 MG/L	0.004 MG/L	Signage
27	Room # 20 Sink	4/28/16	5:43 am	Sink		0.014 MG/L			Signage
28	Nurse Sink	4/28/16	5:47 am	Sink		0.005 MG/L			Signage
29	Room # 28 WF BB	4/28/16	5:41 am	WF BB		0.020 MG/L	0.022 MG/L	<.001 MG/L	X
30	WFC by Nurse	4/28/16	5:48 am	Hallway Water Fountain		<.001 MG/L			NFFI
31	WFC by Custodial Room (3rd Floor)	4/28/16	6:00 am	Hallway Water Fountain	<.001 MG/L	<.001 MG/L			NFB
32	Girl's Room Center Sink	4/28/16	5:50 am	Sink		0.002 MG/L			Signage
33	Room # 27 WF BB	4/28/16	5:56 am	WF BB		0.038 MG/L	0.033 MG/L	0.004 MG/L	X
34	Room # 29 WF BB	4/28/16	6:04 am	WF BB		0.073 MG/L	0.042 MG/L	0.006 MG/L	X

35	Faculty Bathroom (In stairwell 2)	4/28/16	6:11 am	Sink		0.002 MG/L			Signage
36	Faculty Bathroom (In stairwell 8)	4/28/16	6:05 am	Sink		0.002 MG/L			Signage
37	Room # 30 Sink	4/28/16	6:07 am	Sink		0.010 MG/L			Signage
38	Room # 30 WF (Not Working)	—	—	WF (Not Working)		—			X
39	Boy's Bathroom 3rd Floor Sink (left)	4/28/16	6:01 am	Sink		0.002 MG/L			Signage

Water Sample Key:

FD=First Draw **W**=Water **F**=Fountain **P**=Porcelain **C**=Chiller **S**=Sink **BB**=Bubbler **O**=Old Fountain Internal Parts **RP BB**=Replacement Bubbler

Corrective Action Key:

X=Removed **NFB**=Water Fountain/Bottle Filler with self contained lead filter **NFFI**=New Water Fountain & Filter Installed **FI**=Preexisting New Water Fountain lead filter installed

**Morris School District
Drinking Water Analysis
FRELINGHUYSEN MIDDLE SCHOOL**

Line	Sample Location	FD Date	FD Time	Drinking Source	Results MG/L = Micrograms per Liter				Corrective Action Taken
					Test	First Draw	1 Minute 6/16/16	5 Minute	
1	By boy's locker (by custodian's office) WFP (HT)	05/03/16	5:35 am	WFP (HT)	0.001 MG/L	<.001 MG/L			NFB
2	Women's Faculty (by Rm. 132) Right	05/03/16	5:37 am	Sink		0.003 MG/L			Signage
3	Men's Faculty (by Rm. 132) Right	05/03/16	5:38 am	Sink		0.004 MG/L			Signage
4	Room #132 (Woodshop) Sink	05/03/16	5:39 am	Sink		0.035 MG/L	<.001 MG/L		Signage
5	Room #132 (Woodshop) WFP Old HT	05/03/16	5:40 am	WFP (Old HT)		0.011 MG/L			X
6	Hallway by Room 141 WFP HT	05/03/16	6:07 am	WFP HT		<.001 MG/L			NFFI
7	Cafeteria WFC Elkay	05/03/16	5:43 am	WFC Elkay		0.002 MG/L			NFB
8	Teacher's Lounge	05/03/16	5:44 am	Sink		<.001 MG/L			Signage
9	Kitchen A Dish Sink	05/03/16	6:04 am	Sink		0.003 MG/L			Signage
10	Kitchen B Prep Sink	05/03/16	6:04 am	Sink		0.036 MG/L	0.011 MG/L		Signage
11	Kitchen (bathroom)	05/03/16	6:05 am	Sink		0.009 MG/L			Signage
12	Hallway by Room 129 WFP HT	05/03/16	5:41 am	WFP HT		0.003 MG/L			NFFI
13	Men's Faculty (Across from Rm. 117)	05/03/16	5:48 am	Sink		<.001 MG/L			Signage
14	Hallway by Rm 116 WF(A) Center Left New	05/03/16	5:49 am	Hallway Water Fountain		<.001 MG/L			NFFI
15	Hallway by Rm 116 WF(B) Center Right New	05/03/16	5:49 am	Hallway Water Fountain		<.001 MG/L			NFFI
16	Women's Faculty (across from Rm. 116)	05/03/16	5:50 am	Sink		<.001 MG/L			Signage
17	Boy's Bathroom (next to Rm. 115)	05/03/16	5:51 am	Sink		<.001 MG/L			Signage
18	Room #115 Teacher Island	05/03/16	5:53 am	Sink		0.004 MG/L			Signage
19	Room #114 Left next to door	05/03/16	5:56 am	Sink		0.004 MG/L			Signage
20	Room #112 Right next to door	05/03/16	5:54 am	Sink		0.005 MG/L			Signage
21	Girl's BR (by Rm. 112) Left Center	05/03/16	5:57 am	Sink		<.001 MG/L			Signage
22	Hallway by Room 112 WFC (A) Left	05/03/16	5:58 am	Hallway Water Fountain		<.001 MG/L			NFB
23	Hallway by Room 112 WFC (B)	05/03/16	—	WFC Turned Off		—			X
24	Handicap Bathroom (by room 110)	05/03/16	6:00 am	Sink		<.001 MG/L			Signage
25	Media Center (Inside Technology Office)	05/03/16	6:09 am	Sink		<.001 MG/L			Signage
26	Boy's Bathroom (next to Rm. 128) Right	05/03/16	5:38 am	Sink		0.019 MG/L	<.001 MG/L		Signage
27	Girl's Bathroom (next to Rm. 128) Right	05/03/16	5:37 am	Sink		0.012 MG/L			Signage
28	By Front Offices WFP	05/03/16	5:39 am	Hallway Water Fountain		<.001 MG/L			NFB
29	Front Office Sink	05/03/16	5:44 am	Sink		0.012 MG/L			Signage
30	Nurse's Office Sink A Right	05/03/16	5:47 am	Sink		0.007 MG/L			Signage
31	Nurse's Office Sink B Main Area	05/03/16	5:47 am	Sink		0.007 MG/L			Signage
32	Hallway by Room #145 WFP HT	05/03/16	5:49 am	Hallway Water Fountain		0.003 MG/L			NFFI
33	Girl's Locker Room Left	05/03/16	5:51 am	Sink		0.036 MG/L	0.004 MG/L		Signage
34	Boy's Locker Room Right	05/03/16	5:53 am	Sink		0.004 MG/L			Signage
35	Room #147 (Band Office) Left	05/03/16	5:56 am	Sink		<.001 MG/L			Signage
36	Boy's BR (Outside New Gym) Right Sink	05/03/16	5:57 am	Sink		0.003 MG/L			Signage

37	Girl's BR (Outside New Gym) Right Sink	05/03/16	5:59 am	Sink		<.001 MG/L			Signage
38	Outside New Gym WFC Right (by Rm. #148)	05/03/16	6:00 am	Hallway Water Fountain	<.001 MG/L	<.001 MG/L			NFB
39	Outside New Gym WFC Left (by Rm. #148)	05/03/16	6:19 am	Hallway Water Fountain		<.001 MG/L			X
40	Room #148	05/03/16	6:01 am	Sink		<.001 MG/L			Signage
41	Front of Rm. #149 (single bathroom)	05/03/16	6:05 am	Sink		0.003 MG/L			Signage
42	WF in Sink Room #149 BB	05/03/16	6:03 am	WF BB		<.001 MG/L			X
43	Room #201 Sink A Center Lab	05/03/16	6:16 am	Sink		0.054 MG/L	<.001 MG/L		Signage
44	Room #201 Sink B Teacher Station	05/03/16	6:15 am	Sink		0.087 MG/L	<.001 MG/L		Signage
44A	Hallway by Room #226			Hallway Water Fountain					NFFI
45	Hallway by Room #203 WF	05/03/16	6:10 am	Hallway Water Fountain		0.008 MG/L			X
46	Room #204 Sink B Center	05/03/16	6:09 am	Sink		0.149 MG/L	<.001 MG/L		Signage
47	Girl's Bathroom (next to Rm. 203) Center	05/03/16	6:08 am	Sink		0.716 MG/L	<.001 MG/L		Signage
48	Boy's Bathroom (next to Rm. 204) Center	05/03/16	6:07 am	Sink		0.006 MG/L			Signage
49	Room #205 Sink A Island	05/03/16	6:05 am	Sink		0.019 MG/L	<.001 MG/L		Signage
50	Room #205 Sink B Rear	05/03/16	6:06 am	Sink		0.019 MG/L	<.001 MG/L		Signage
51	Room #207 Sink A Island	05/03/16	6:00 am	Sink		0.037 MG/L	0.005 MG/L		Signage
52	Room #207 Sink B Center	05/03/16	5:59 am	Sink		<.001 MG/L			Signage
53	Room #208 Sink A Island	05/03/16	5:56 am	Sink		0.084 MG/L	<.001 MG/L		Signage
54	Room #208 Sink B Center	05/03/16	5:57 am	Sink		0.003 MG/L			Signage
55	Room #209 Sink A Teacher Area	05/03/16	5:53 am	Sink		0.160 MG/L	0.003 MG/L		Signage
56	Room #209 Sink B Center	05/03/16	5:54 am	Sink		0.081 MG/L	<.001 MG/L		Signage
57	Outside Room #212	05/03/16	5:51 am	Hallway Water Fountain		0.008 MG/L			NFFI
58	Room #213 Right	05/03/16	5:58 am	Sink		0.029 MG/L	<.001 MG/L		Signage
59	Room #214	05/03/16	5:47 am	Sink		0.010 MG/L			Signage
60	Girl's Bathroom (next to Rm. 220) Center	05/03/16	5:41 am	Sink		0.009 MG/L			Signage
61	Boy's Bathroom (next to Rm. 220) Center	05/03/16	5:40 am	Sink		0.032 MG/L	0.005 MG/L		Signage
62	WFP HT (hall by Room #221)	05/03/16	5:46 am	Hallway Water Fountain	<.001 MG/L	0.004 MG/L			NFB
63	Hallway by Room #219	05/03/16	5:43 am	Hallway Water Fountain		<.001 MG/L			NFFI
64	Trailer A (Community School) Sink	05/03/16	6:24 am	Sink		0.002 MG/L			New Structure 7/13
65	Trailer A (Community School) WF A	05/03/16	6:23 am	Hallway Water Fountain		<.001 MG/L			New Structure 7/13
66	Trailer A (Community School) WF B	05/03/16	6:23 am	Hallway Water Fountain		<.001 MG/L			New Structure 7/13
67	Trailer B (Child Study Team) Sink	05/03/16	6:22 am	Sink		<.001 MG/L			New Structure 7/13
68	Trailer B (Child Study Team) WF A	05/03/16	6:22 am	Hallway Water Fountain		<.001 MG/L			New Structure 7/13
69	Trailer B (Child Study Team) WF B	05/03/16	6:22 am	Hallway Water Fountain		<.001 MG/L			New Structure 7/13

Water Sample Key:

FD=First Draw **W**=Water **F**=Fountain **P**=Porcelain **C**=Chiller **S**=Sink **BB**=Bubbler **O**=Old Fountain Internal Parts **RP BB**=Replacement Bubbler

Corrective Action Key:

X=Removed **NFB**=Water Fountain/Bottle Filler with self contained lead filter **NFFI**=New Water Fountain & Filter Installed **FI**=Preexisting New Water Fountain lead filter installed

**Morris School District
Drinking Water Analysis
MORRISTOWN HIGH SCHOOL**

FD Sample #	Line	Sample Location	FD Date	FD Time	Drinking Source	Results MG/L = Micrograms per Liter				Corrective Action Taken
						Test	First Draw	1 Minute	5 Minute	
1	1	Girl's Bathroom #403 (Left Center)	5/5/2016	5:51 am	Sink		0.002 MG/L			Signage
2	2	WF across from Room #405 HT (low flow)	5/5/2016	5:50 am	Hallway Water Fountain		<.001 MG/L			NFFI
3	3	Room # 409 Sink (Far left by office)	5/5/2016	5:48 am	Sink		0.023 MG/L			Signage
4	4	Room # 409 Teacher Island	5/5/2016	5:47 am	Sink		0.061 MG/L			Signage
5	5	Room #409 Office	5/5/2016	5:56 am	Sink		0.026 MG/L			Signage
6	6	WFP next to room #415 (Old - low flow)	5/5/2016	5:45 am	Hallway Water Fountain		<.001 MG/L			NFFI
7	7	WFP next to boy's bathroom (Old)	5/5/2016	5:42 am	Hallway Water Fountain	<.001 MG/L	<.001 MG/L			NFFI
8	8	Boy's Bathroom Center	5/5/2016	5:43 am	Sink		<.001 MG/L			Signage
9	9	Room #429 Sink (far left by windows)	5/5/2016	5:40 am	Sink		0.064 MG/L			Signage
10	10	Room #429 Teacher Island - NOT IN USE	5/5/2016	—	—		—			Signage
11	11	WFP across from Room #441 RP BB	5/5/2016	5:37 am	Hallway Water Fountain		<.001 MG/L			NFB
12	12	WF across from Room #305	5/5/2016	5:46 am	Hallway Water Fountain		<.001 MG/L			NFB
13	13	Faculty BR (next to Rm #313) Left Center	5/5/2016	6:01 am	Sink		<.001 MG/L			Signage
14	14	WF next to Women's Faculty BR (New LK)	5/5/2016	5:45 am	Hallway Water Fountain		<.001 MG/L			NFFI
15	15	WFC next to Room #325	5/5/2016	5:43 am	Hallway Water Fountain		<.001 MG/L			NFB
16	16	Room #337 Sink (right)	5/5/2016	5:42 am	Sink		0.007 MG/L			Signage
17	17	Men's Faculty BR (by Room #341) Center S	5/5/2016	5:40 am	Sink		0.006 MG/L			Signage
18	18	Boy's Bathroom by Room #354 (Right Sink)	5/5/2016	5:51 am	Sink		<.001 MG/L			Signage
19	19	Girl's Bathroom by Room #354 (Center Sink)	5/5/2016	5:52 am	Sink		<.001 MG/L			Signage
20	20	Room #354 Sink (By back wall - Right Sink)	5/5/2016	5:54 am	Sink		0.006 MG/L			Signage
21	21	Room #354 Teacher Island	5/5/2016	5:53 am	Sink		0.016 MG/L			Signage
22	22	Office #354 & 356 (Center Sink Back Wall)	5/5/2016	5:58 am	Sink		0.015 MG/L			Signage
23	23	Room #356 Center Sink Back Wall	5/5/2016	6:00 am	Sink		0.011 MG/L			Signage
24	24	WFC by Room #359	5/5/2016	6:05 am	Hallway Water Fountain	<.001 MG/L	<.001 MG/L			NFFI
25	25	Room #357 (By back wall - Right Sink)	5/5/2016	6:02 am	Sink		0.014 MG/L			Signage
26	26	Room #357 Teacher Island NOT IN USE	5/5/2016	—	—		—			—
27	27	Room #359 (Left Side Sink)	5/5/2016	6:04 am	Sink		<.001 MG/L			Signage
28	28	Office between #359 & 363	5/5/2016	6:02 am	Sink		0.003 MG/L			Signage
29	29	Room #363 Sink (Left side of room)	5/5/2016	6:00 am	Sink		0.003 MG/L			Signage
30	30	Room #363 Teacher Island (Front of room)	5/5/2016	5:59 am	Sink		0.023 MG/L			Signage
31	31	Room #367 Sink (Left)	5/5/2016	5:56 am	Sink		0.005 MG/L			Signage
32	32	Room #368 Island (Back of room - 5 sinks)	5/5/2016	5:53 am	Sink		0.010 MG/L			Signage
33	33	Office behind #368	5/5/2016	5:52 am	Sink		0.021 MG/L			Signage
35	34	Library Lab (Delta)	5/5/2016	5:43 am	Sink		0.008 MG/L			Signage
36	35	Room #387	5/5/2016	5:41 am	Sink		0.018 MG/L			Signage
37	36	WFP across from Room #341 BB	5/5/2016	5:38 am	Hallway Water Fountain		<.001 MG/L			NFFI
38	37	WFP BB across from Room #354	5/5/2016	6:08 am	Hallway Water Fountain		<.001 MG/L			NFB
39	38	Girl's Bathroom #203 (Far Right)	5/11/2016	5:46 am	Sink		<.001 MG/L			Signage

40	39	WFC across from Room #205	5/11/2016	5:44 am	Hallway Water Fountain		<.001 MG/L		NFFI
41	40	Backstage WFC	5/11/2016	5:43 am	WFC		<.001 MG/L		NFFI
42	41	WFC next to Room #215	5/11/2016	5:41 am	Hallway Water Fountain		0.035 MG/L		NFFI
43	42	WFC next to Room #225	5/11/2016	5:40 am	Hallway Water Fountain		<.001 MG/L		NFB
44	43	Boy's Bathroom (Right Sink)	5/11/2016	5:48 am	Sink		0.005 MG/L		Signage
45	44	WF across from Room #241 RP BB	5/11/2016	5:49 am	Hallway Water Fountain		<.001 MG/L		NFFI
47	45	Boy's Bathroom (by security) (Sink Right)	5/11/2016	5:51 am	Sink		<.001 MG/L		Signage
48	46	Girl's Bathroom (by security) (Sink Center)	5/11/2016	5:52 am	Sink		<.001 MG/L		Signage
49	47	Room #254 Sink by Door	5/11/2016	5:55 am	Sink		0.008 MG/L		Signage
50	48	Office between #254 & 256	5/11/2016	5:58 am	Sink		0.008 MG/L		Signage
51	49	Room #256 Sink by Door	5/11/2016	5:57 am	Sink		0.024 MG/L		Signage
52	50	Room #256 Teacher Island NOT USED	5/11/2016	—	—		—		—
53	51	Room #255A (Sink Right)	5/11/2016	6:00 am	Sink		0.015 MG/L		Signage
54	52	Room #257 First Dark Room	5/11/2016	6:07 am	Sink		0.006 MG/L		Signage
55	53	Men's Faculty (by 257)	5/11/2016	6:08 am	Sink		<.001 MG/L		Signage
56	54	Women's Faculty (by 263)	5/11/2016	6:10 am	Sink		<.001 MG/L		Signage
57	55	WFP by Room #254 RP BB	5/11/2016	5:54 am	Hallway Water Fountain		<.001 MG/L		NFB
58	56	WFP by Room #263 Old BB	5/11/2016	6:02 am	Hallway Water Fountain	<.001 MG/L	<.001 MG/L		NFFI
59	57	Room # 265A (Left)	5/11/2016	6:11 am	Sink		0.009 MG/L		Signage
60	58	Room #265B (Center)	5/11/2016	6:13 am	Sink		0.002 MG/L		Signage
61	59	Room #265C (Center)	5/11/2016	6:13 am	Sink		0.004 MG/L		Signage
62	60	Room #269	5/11/2016	6:11 am	Sink		0.004 MG/L		Signage
63	61	Athletic Office	5/11/2016	6:13 am	Sink		0.005 MG/L		Signage
64	62	Nurse's Office	5/11/2016	6:08 am	Sink		0.006 MG/L		Signage
65	63	Bathroom #102	5/11/2016	6:04 am	Sink		<.001 MG/L		Signage
66	64	Bathroom #107 (Right)	5/11/2016	6:02 am	Sink		<.001 MG/L		Signage
67	65	Bathroom #109	5/11/2016	5:57 am	Sink		0.009 MG/L		Signage
68	66	Room #112 NOT WORKING	5/11/2016	—	—		—		—
69	67	Bathroom Under Aud.	5/11/2016	5:54 am	Sink		0.003 MG/L		Signage
70	68	Boy's Dressing Room NOT WORKING	5/11/2016	—	—		—		—
71	69	Girl's Dressing Room (Right)	5/11/2016	5:52 am	Sink		<.001 MG/L		Signage
72	70	Room #140 Kitchen Sink #4	5/11/2016	5:49 am	Sink		0.003 MG/L		Signage
73	71	Room # 140 Kitchen Sink #2	5/11/2016	5:47 am	Sink		0.003 MG/L		Signage
74	72	Room #140 Kitchen Sink Teacher Island	5/11/2016	5:46 am	Sink		0.011 MG/L		Signage
75	73	Maintenance Shop	5/11/2016	5:45 am	Sink		0.003 MG/L		Signage
76	74	Lower Atrium Boy's Bathroom (Right)	5/11/2016	5:44 am	Sink		0.004 MG/L		Signage
77	75	Lower Atrium Girl's Bathroom (Right)	5/11/2016	5:43 am	Sink		0.006 MG/L		Signage
78	76	WFP lower atrium (Elkay)	5/11/2016	5:42 am	Hallway Water Fountain		0.003 MG/L		NFB
79	77	Cafeteria WFC	5/11/2016	5:39 am	WFC		0.002 MG/L		NFB
80	78	Kitchen A (Serving line by warmer)	5/11/2016	5:41 am	Sink		0.004 MG/L		Signage
81	79	Kitchen B (Right sink by office)	5/11/2016	5:43 am	Sink		0.004 MG/L		Signage
82	80	Kitchen C (Sink back corner)	5/11/2016	5:45 am	Sink		0.003 MG/L		Signage
83	81	WF in Custodial Room	5/11/2016	5:53 am	WFC		0.002 MG/L		FI
84	82	Room #162 Band Room (Sink by Door)	5/11/2016	5:50 am	Sink		<.001 MG/L		Signage
85	83	Room #167 WFC by Main Door	5/11/2016	5:51 am	Hallway Water Fountain		<.001 MG/L		NFFI
86	84	Athletic's Boy's Room (Right Sink)	5/11/2016	6:35 am	Sink		0.003 MG/L		Signage

87	85	Athletic's Girl's Room (Middle Sink)	5/11/2016	6:35 am	Sink		0.003 MG/L			Signage
88	86	Athletics Hallway WFC A (Elkay)	5/11/2016	6:01 am	Hallway Water Fountain		<.001 MG/L			NFFI
89	87	Athletics Hallway WFC B (Oasis)	5/11/2016	6:02 am	Hallway Water Fountain	0.007 MG/L	<.001 MG/L			NFB
90	88	Girl's Pool Locker Room (Middle Sink)	5/11/2016	6:05 am	Sink		0.006 MG/L			Signage
91	89	Boy's Pool Locker Room (Right Sink)	5/11/2016	6:06 am	Sink		0.009 MG/L			Signage
92	90	Pool Deck WFC	5/11/2016	6:00 am	WFC		0.012 MG/L			NFFI
93	91	Trainer's Room Sink	5/11/2016	6:18 am	Sink		<.001 MG/L			Signage
94	92	Weight Room Bathroom Sink	5/11/2016	6:07 am	Sink		<.001 MG/L			Signage
95	93	Weight Room WFC	5/11/2016	6:08 am	WFC		0.004 MG/L			NFFI
96	94	Boy's Locker Room (Far Side Right Sink)	5/11/2016	6:18 am	Sink		0.012 MG/L			Signage
97	95	Girl's Locker Room (First Sink Left)	5/11/2016	6:15 am	Sink		0.006 MG/L			Signage
100	96	Outside WF	5/11/2016	6:25 am	BB		0.003 MG/L			

Water Sample Key:

FD=First Draw **W**=Water **F**=Fountain **P**=Porcelain **C**=Chiller **S**=Sink **BB**=Bubbler **O**=Old Fountain Internal Parts **RP BB**=Replacement Bubbler

Corrective Action Key:

X=Removed **NFB**=Water Fountain/Bottle Filler with self contained lead filter **NFFI**=New Water Fountain & Filter Installed **FI**=Preexisting New Water Fountain lead filter installed

**Morris School District
Drinking Water Analysis**

Line	Sample Location	FD Date	FD Time	Drinking Source	Results MG/L = Micrograms per Liter			Corrective Action Taken
					Test	First Draw	1 Minute	
1	Room # 101	7/7/2016	5:44 am	Sink		<.001 MG/L		Signage
2	Room # 102 - Sink in room	7/7/2016	5:56 am	Sink	<.001 MG/L	0.007 MG/L		Signage
3	Nurse's Office	7/7/2016	6:09 am	Sink		0.005 MG/L		Signage
4	Room # 105	7/7/2016	6:02 am	Sink		0.017 MG/L		Signage
5	Room # 105 c	7/7/2016	6:04 am	Sink		0.100 MG/L		Signage
6	Room # 107	7/7/2016	6:04 am	Sink		0.005 MG/L		Signage
7	Room # 108	7/7/2016	5:58 am	Sink		0.002 MG/L		Signage
8	Room # 109 Bathroom Sink	7/7/2016	5:55 am	Sink		<.001 MG/L		Signage
9	Room # 110 Bathroom Sink	7/7/2016	5:54 am	Sink		<.001 MG/L		Signage
10	Room # 110 Classroom Sink	7/7/2016	5:53 am	Sink		0.018 MG/L		Signage
11	Old nurse's office sink	7/7/2016	5:55 am	Sink		0.012 MG/L		Signage
12	Staff bathroom by kitchen	7/7/2016	6:06 am	Sink		0.006 MG/L		Signage
13	Hall (1st Floor) WFC by gym	7/7/2016	6:06 am	Hallway Water Fountain	0.002 MG/L	0.008 MG/L		NFFI
14	Kitchen (triple sink)	7/7/2016	6:06 am	Sink		0.010 MG/L		Signage
15	Student Bathroom by office	7/7/2016	6:00 am	Sink		0.012 MG/L		Signage
16	Ladies Bathroom (2nd Floor by Rm. 201 - Left)	7/7/2016	5:41 am	Sink		0.012 MG/L		Signage
17	Men's Room (2nd Floor) First sink on right	7/7/2016	5:41 am	Sink		0.033 MG/L		Signage
18	Break Room Sink second floor	7/7/2016	5:42 am	Sink		0.002 MG/L		Signage
19	Room # 209 (Payroll)	7/7/2016	5:46 am	Sink		0.019 MG/L		Signage
20	Hall (2nd Floor) WFC by Room 212	7/7/2016	5:43 am	Hallway Water Fountain		0.030 MG/L		NFB
21	Bathroom by HR	7/7/2016	5:46 am	Sink		0.034 MG/L		Signage
22	Ladies Bathroom by payroll (left sink)	7/7/2016	5:49 am	Sink		0.011 MG/L		Signage

Water Sample Key:

FD=First Draw W=Water F=Fountain P=Porcelain C=Chiller S=Sink BB=Bubbler O=Old Fountain Internal Parts RP BB=Replacement Bubbler

Corrective Action Key:

X=Removed NFB=Water Fountain/Bottle Filler with self contained lead filter NFFI=New Water Fountain & Filter Installed FI=Preexisting New Water Fountain lead filter installed

**Morris School District
Drinking Water Analysis
ATHLETIC FIELDS**

FD Sample #	Sample Location	FD Date	FD Time	Drinking Source	Test	Results MG/L = Micrograms per Liter			Corrective Action Taken
						First Draw	1 Minute	5 Minute	
1	Frehlinghuysen Outside Water Fountain	10/4/17	6:00 am	Fountain		0.002 MG/L			None Needed
2	Harter Rd Men's Right Sink	10/4/17	6:20 am	Sink		0.002 MG/L			None Needed
3	Harter Rd Women's Right Sink	10/4/17	6:22 am	Sink		0.002 MG/L			None Needed
4	Harter Rd Parking Lot Water Fountain	10/4/17	4:40 am	Fountain		0.002 MG/L			None Needed