

Room	Dates/Observations
Technology Room	<p>9/17/19: Initial assessment. Dry moisture readings. Ceiling tiles removed in two areas of the room, exposing dry wood above. 4 water stained ceiling tiles.</p> <p>9/18/19: Microbial air sampling conducted in this room. Results did not indicate elevated fungal spore levels.</p> <p>10/1/19: Strong musty odor. New water staining at ceiling tiles and carpet throughout room. Wet readings.</p> <p>10/2/19: Wet moisture readings and positive infrared imagery at upper portions of north wall, upper portion of east wall, entire height of wall at northeast corner, upper portion of south wall, entire height of south wall at southwest corner, upper portion of west wall. No changes to ceiling tile and carpet impacts throughout room.</p> <p>10/10/19: No musty odor. Approximately 78 SF ceiling tiles removed from south portion of room, 128 SF ceiling tiles removed from central portion of room, 160 SF ceiling tiles removed from north portion of room, 20SF drywall removed from upper north section of west wall, 20 SF drywall removed from upper central section of west wall, 70 SF drywall removed from lower south section of west wall, 240 SF drywall (entire wall) removed from south wall, all else intact. Dry moisture readings at front and backside of upper east wall. TRC recommended encapsulate exterior drywall at upper north section of west wall where suspect visible fungal growth was observed; and sand and HEPA vacuum wood framing in this area.</p>

Room	Dates/Observations
<p>Technology Room</p>	<p>10/10/19 (Continued): Wet moisture readings at lower portion of north wall, adjacent to built-in and central east portion of north wall, above built-in. Wet drywall to be removed. Based on residual suspect fungal growth on 3 SF of drywall and wood framing at upper west wall, NW corner and new wet readings at north wall, NE corner, containment will be set in north section of room to isolate this area for additional remediation. Microbial air sampling was performed in the south section of the room. Results for the south section of the indicated elevated <i>Penicillium/Aspergillus</i> levels (3,200 Count/m3).</p> <p>10/12/19: TRC back-on site to visually assess the remediation activities and re-cleaning efforts.</p> <p>10/16/19: Visual clearance received in south and north containments. Microbial air sampling was performed in the north and south sections of the room. Results for the both containment chambers indicated elevated <i>Penicillium/Aspergillus</i> levels (410-570 Count/m3).</p> <p>10/18/19: Plastic installed over the wood framing at the south wall of south containment, sealing off Tech Room from Speech and OFF 2. Plastic covering wall cavities at NE section of north wall and upper west wall within north containment after visual clearance received. Results for the both containment chambers indicated elevated <i>Penicillium/Aspergillus</i> levels (3,600 - 4,700 Count/m3).</p> <p>10/21/19: TRC on-site to re-assess. Negative draw for both containments. Opening in north containment at bottom of north wall NW. SERVPRO removed negative draw from HEPA filtration and allowed air filter to run inside containment without negative draw. Microbial air sampling conducted in both containment chambers. Results did not indicate elevated fungal spore levels in either containment.</p> <p>No asbestos containing materials removed in this room.</p>


Report for:

**Ms. Victoria Shepersky**  
**TRC Solutions, Inc.**  
4105 SE International Way, Suite 505  
Milwaukie, OR 97222

---

Regarding: Project: 362890 West Tualatin ES  
EML ID: 2256569

Approved by:



Operations Manager  
Joshua Cox

Dates of Analysis:

Spore trap analysis: 09-19-2019

Service SOPs: Spore trap analysis (EM-MY-S-1038)  
AIHA-LAP, LLC accredited service, Lab ID #102297

---

All samples were received in acceptable condition unless noted in the Report Comments portion in the body of the report. Due to the nature of the analyses performed, field blank correction of results is not applied. The results relate only to the samples as received. Sample air volume is supplied by the client.

Eurofins EMLab P&K ("the Company") shall have no liability to the client or the client's customer with respect to decisions or recommendations made, actions taken or courses of conduct implemented by either the client or the client's customer as a result of or based upon the Test Results. In no event shall the Company be liable to the client with respect to the Test Results except for the Company's own willful misconduct or gross negligence nor shall the Company be liable for incidental or consequential damages or lost profits or revenues to the fullest extent such liability may be disclaimed by law, even if the Company has been advised of the possibility of such damages, lost profits or lost revenues. In no event shall the Company's liability with respect to the Test Results exceed the amount paid to the Company by the client therefor.

Eurofins EMLab P&K's LabServe® reporting system includes automated fail-safes to ensure that all AIHA-LAP, LLC quality requirements are met and notifications are added to reports when any quality steps remain pending.

Client: TRC Solutions, Inc.  
 C/O: Ms. Victoria Shepersky  
 Re: 362890 West Tualatin ES

Date of Sampling: 09-18-2019  
 Date of Receipt: 09-19-2019  
 Date of Report: 09-19-2019

**SPORE TRAP REPORT: NON-VIABLE METHODOLOGY**

Location:	28956406: Outside Air N @ Gym & Main Bldg				28956442: Principal's Office				28956403: Gym South Portion				28956463: Gym North Portion			
Comments (see below)	None				None				None				None			
Lab ID-Version‡:	10729973-1				10729974-1				10729975-1				10729976-1			
Analysis Date:	09/19/2019				09/19/2019				09/19/2019				09/19/2019			
Sample volume (liters)	75				75				75				75			
Background debris (1-4+)††	1+				3+				4+				4+			
	raw ct.	Count/m3	DL/m3*	%	raw ct.	Count/m3	DL/m3*	%	raw ct.	Count/m3	DL/m3*	%	raw ct.	Count/m3	DL/m3*	%
Hyphal fragments					1	13	13	n/a	2	27	13	n/a	7	93	13	n/a
Pollen																
<b>§ TOTAL FUNGAL SPORES</b>	109	5,400	n/a	100	2	27	n/a	100	18	240	n/a	100	28	370	n/a	100
Alternaria																
Ascospores	34	450	13	8					3	40	13	17				
Basidiospores	42	4,500	110	83					3	40	13	17	4	53	13	14
Botrytis	1	13	13	< 1												
Cercospora																
Chaetomium																
Cladosporium	25	330	13	6	1	13	13	50	6	80	13	33	12	160	13	43
Epicoccum																
Other brown													1	13	13	4
Penicillium/Aspergillus types	5	67	13	1	1	13	13	50	5	67	13	28	9	120	13	32
Smuts, Periconia, Myxomycetes	2	27	13	< 1					1	13	13	6	2	27	13	7
Stachybotrys																

**Comments:**

Spore types listed without a count or data entry were not detected during the course of the analysis for the respective sample, indicating a raw count of <1 spore.

The analytical sensitivity/limit of detection is the Count/m<sup>3</sup> divided by the raw count, expressed in Count/m<sup>3</sup>.

\*The detection limit/limit of detection (DL) per cubic meter (m<sup>3</sup>) has been rounded to two significant figures to reflect analytical precision.

††Background debris indicates the amount of non-biological particulate matter present on the trace (dust in the air) and the resulting visibility for the analyst. It is rated from 1+ (low) to 4+ (high). Counts from areas with 4+ background debris should be regarded as minimal counts and may be higher than reported. It is important to account for samples volumes when evaluating dust levels.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

§ Total Fungal Spores has been rounded to two significant figures to reflect analytical precision.

Client: TRC Solutions, Inc.  
 C/O: Ms. Victoria Shepersky  
 Re: 362890 West Tualatin ES

Date of Sampling: 09-18-2019  
 Date of Receipt: 09-19-2019  
 Date of Report: 09-19-2019

**SPORE TRAP REPORT: NON-VIABLE METHODOLOGY**

Location:	28956428: Stage				28956426: A100				28956429: A102				28956421: Main Corridor N @ A102			
Comments (see below)	None				None				None				None			
Lab ID-Version‡:	10729977-1				10729978-1				10729979-1				10729980-1			
Analysis Date:	09/19/2019				09/19/2019				09/19/2019				09/19/2019			
Sample volume (liters)	75				75				75				75			
Background debris (1-4+)††	4+				4+				4+				4+			
	raw ct.	Count/m3	DL/m3*	%	raw ct.	Count/m3	DL/m3*	%	raw ct.	Count/m3	DL/m3*	%	raw ct.	Count/m3	DL/m3*	%
Hyphal fragments	3	40	13	n/a	10	130	13	n/a	13	170	13	n/a	10	130	13	n/a
Pollen									1	13	13	n/a				
<b>§ TOTAL FUNGAL SPORES</b>	<b>36</b>	<b>480</b>	<b>n/a</b>	<b>100</b>	<b>50</b>	<b>670</b>	<b>n/a</b>	<b>100</b>	<b>93</b>	<b>1,200</b>	<b>n/a</b>	<b>100</b>	<b>66</b>	<b>880</b>	<b>n/a</b>	<b>100</b>
Alternaria					3	40	13	6								
Ascospores	2	27	13	6					1	13	13	1	3	40	13	5
Basidiospores	8	110	13	22	6	80	13	12	3	40	13	3	5	67	13	8
Botrytis																
Chaetomium																
Cladosporium	13	170	13	36	21	280	13	42	53	710	13	57	36	480	13	55
Epicoccum	1	13	13	3												
Other brown									3	40	13	3				
Penicillium/Aspergillus types	12	160	13	33	17	230	13	34	28	370	13	30	17	230	13	26
Pithomyces					1	13	13	2	1	13	13	1				
Rusts									1	13	13	1				
Smuts, Periconia, Myxomycetes					2	27	13	4	3	40	13	3	5	67	13	8
Stachybotrys																

**Comments:**

Spore types listed without a count or data entry were not detected during the course of the analysis for the respective sample, indicating a raw count of <1 spore.

The analytical sensitivity/limit of detection is the Count/m<sup>3</sup> divided by the raw count, expressed in Count/m<sup>3</sup>.

\*The detection limit/limit of detection (DL) per cubic meter (m<sup>3</sup>) has been rounded to two significant figures to reflect analytical precision.

††Background debris indicates the amount of non-biological particulate matter present on the trace (dust in the air) and the resulting visibility for the analyst. It is rated from 1+ (low) to 4+ (high). Counts from areas with 4+ background debris should be regarded as minimal counts and may be higher than reported. It is important to account for samples volumes when evaluating dust levels.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

§ Total Fungal Spores has been rounded to two significant figures to reflect analytical precision.

Client: TRC Solutions, Inc.  
 C/O: Ms. Victoria Shepersky  
 Re: 362890 West Tualatin ES

Date of Sampling: 09-18-2019  
 Date of Receipt: 09-19-2019  
 Date of Report: 09-19-2019

**SPORE TRAP REPORT: NON-VIABLE METHODOLOGY**

Location:	28956420: A104				28956469: A106				28956468: A108				28956720: Main Corridor Center @ Library			
Comments (see below)	None				None				None				None			
Lab ID-Version‡:	10729981-1				10729982-1				10729983-1				10729984-1			
Analysis Date:	09/19/2019				09/19/2019				09/19/2019				09/19/2019			
Sample volume (liters)	75				75				75				75			
Background debris (1-4+)††	3+				4+				3+				4+			
	raw ct.	Count/m3	DL/m3*	%	raw ct.	Count/m3	DL/m3*	%	raw ct.	Count/m3	DL/m3*	%	raw ct.	Count/m3	DL/m3*	%
Hyphal fragments	3	40	13	n/a	8	110	13	n/a	2	27	13	n/a	6	80	13	n/a
Pollen																
<b>§ TOTAL FUNGAL SPORES</b>	19	250	n/a	100	43	570	n/a	100	19	250	n/a	100	51	680	n/a	100
Alternaria																
Ascospores					2	27	13	5	1	13	13	5				
Basidiospores	2	27	13	11	2	27	13	5	2	27	13	11	5	67	13	10
Botrytis	1	13	13	5												
Cercospora																
Chaetomium																
Cladosporium	8	110	13	42	14	190	13	33	8	110	13	42	27	360	13	53
Epicoccum																
Other brown	1	13	13	5	1	13	13	2					1	13	13	2
Penicillium/Aspergillus types	7	93	13	37	23	310	13	53	8	110	13	42	17	230	13	33
Smuts, Periconia, Myxomycetes					1	13	13	2					1	13	13	2
Stachybotrys																

**Comments:**

Spore types listed without a count or data entry were not detected during the course of the analysis for the respective sample, indicating a raw count of <1 spore.

The analytical sensitivity/limit of detection is the Count/m<sup>3</sup> divided by the raw count, expressed in Count/m<sup>3</sup>.

\*The detection limit/limit of detection (DL) per cubic meter (m<sup>3</sup>) has been rounded to two significant figures to reflect analytical precision.

††Background debris indicates the amount of non-biological particulate matter present on the trace (dust in the air) and the resulting visibility for the analyst. It is rated from 1+ (low) to 4+ (high). Counts from areas with 4+ background debris should be regarded as minimal counts and may be higher than reported. It is important to account for samples volumes when evaluating dust levels.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

§ Total Fungal Spores has been rounded to two significant figures to reflect analytical precision.

Client: TRC Solutions, Inc.  
 C/O: Ms. Victoria Shepersky  
 Re: 362890 West Tualatin ES

Date of Sampling: 09-18-2019  
 Date of Receipt: 09-19-2019  
 Date of Report: 09-19-2019

**SPORE TRAP REPORT: NON-VIABLE METHODOLOGY**

Location:	28956443: A110				28956404: A112				28956402: A114				28956444: Main Corridor S @ A116			
Comments (see below)	None				None				None				None			
Lab ID-Version‡:	10729985-1				10729986-1				10729987-1				10729988-1			
Analysis Date:	09/19/2019				09/19/2019				09/19/2019				09/19/2019			
Sample volume (liters)	75				75				75				75			
Background debris (1-4+)††	4+				3+				4+				2+			
	raw ct.	Count/m3	DL/m3*	%	raw ct.	Count/m3	DL/m3*	%	raw ct.	Count/m3	DL/m3*	%	raw ct.	Count/m3	DL/m3*	%
Hyphal fragments	12	160	13	n/a	2	27	13	n/a	9	120	13	n/a	2	27	13	n/a
Pollen	1	13	13	n/a												
<b>§ TOTAL FUNGAL SPORES</b>	<b>41</b>	<b>550</b>	<b>n/a</b>	<b>100</b>	<b>31</b>	<b>410</b>	<b>n/a</b>	<b>100</b>	<b>72</b>	<b>960</b>	<b>n/a</b>	<b>100</b>	<b>45</b>	<b>600</b>	<b>n/a</b>	<b>100</b>
Alternaria																
Ascospores					3	40	13	10	1	13	13	1	8	110	13	18
Basidiospores	2	27	13	5	6	80	13	19	10	130	13	14	23	310	13	51
Botrytis																
Cercospora																
Chaetomium																
Cladosporium	25	330	13	61	13	170	13	42	33	440	13	46	7	93	13	16
Epicoccum																
Other brown					1	13	13	3	1	13	13	1	1	13	13	2
Penicillium/Aspergillus types	13	170	13	32	7	93	13	23	23	310	13	32	6	80	13	13
Pithomyces																
Smuts, Periconia, Myxomycetes	1	13	13	2	1	13	13	3	4	53	13	6				
Stachybotrys																

**Comments:**

Spore types listed without a count or data entry were not detected during the course of the analysis for the respective sample, indicating a raw count of <1 spore.

The analytical sensitivity/limit of detection is the Count/m<sup>3</sup> divided by the raw count, expressed in Count/m<sup>3</sup>.

\*The detection limit/limit of detection (DL) per cubic meter (m<sup>3</sup>) has been rounded to two significant figures to reflect analytical precision.

††Background debris indicates the amount of non-biological particulate matter present on the trace (dust in the air) and the resulting visibility for the analyst. It is rated from 1+ (low) to 4+ (high). Counts from areas with 4+ background debris should be regarded as minimal counts and may be higher than reported. It is important to account for samples volumes when evaluating dust levels.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

§ Total Fungal Spores has been rounded to two significant figures to reflect analytical precision.

Client: TRC Solutions, Inc.  
 C/O: Ms. Victoria Shepersky  
 Re: 362890 West Tualatin ES

Date of Sampling: 09-18-2019  
 Date of Receipt: 09-19-2019  
 Date of Report: 09-19-2019

**SPORE TRAP REPORT: NON-VIABLE METHODOLOGY**

Location:	28956447: A116				28956396: A Hall @ A118				28956439: A118				28862359: A120			
Comments (see below)	None				None				None				None			
Lab ID-Version‡:	10729989-1				10729990-1				10729991-1				10729992-1			
Analysis Date:	09/19/2019				09/19/2019				09/19/2019				09/19/2019			
Sample volume (liters)	75				75				75				75			
Background debris (1-4+)††	2+				2+				2+				2+			
	raw ct.	Count/m3	DL/m3*	%	raw ct.	Count/m3	DL/m3*	%	raw ct.	Count/m3	DL/m3*	%	raw ct.	Count/m3	DL/m3*	%
Hyphal fragments	4	53	13	n/a	1	13	13	n/a	3	40	13	n/a	1	13	13	n/a
Pollen																
<b>§ TOTAL FUNGAL SPORES</b>	<b>88</b>	<b>1,200</b>	<b>n/a</b>	<b>100</b>	<b>94</b>	<b>1,300</b>	<b>n/a</b>	<b>100</b>	<b>45</b>	<b>600</b>	<b>n/a</b>	<b>100</b>	<b>171</b>	<b>2,300</b>	<b>n/a</b>	<b>100</b>
Alternaria					1	13	13	1								
Ascospores	14	190	13	16	16	210	13	17	7	93	13	16	31	410	13	18
Basidiospores	52	690	13	59	49	650	13	52	13	170	13	29	112	1,500	13	65
Botrytis																
Cercospora																
Chaetomium																
Cladosporium	11	150	13	13	11	150	13	12	4	53	13	9	6	80	13	4
Epicoccum																
Other brown																
Penicillium/Aspergillus types	6	80	13	7	17	230	13	18	20	270	13	44	17	230	13	10
Pithomyces	1	13	13	1									1	13	13	1
Smuts, Periconia, Myxomycetes	4	53	13	5					1	13	13	2	4	53	13	2
Stachybotrys																

**Comments:**

Spore types listed without a count or data entry were not detected during the course of the analysis for the respective sample, indicating a raw count of <1 spore.

The analytical sensitivity/limit of detection is the Count/m<sup>3</sup> divided by the raw count, expressed in Count/m<sup>3</sup>.

\*The detection limit/limit of detection (DL) per cubic meter (m<sup>3</sup>) has been rounded to two significant figures to reflect analytical precision.

††Background debris indicates the amount of non-biological particulate matter present on the trace (dust in the air) and the resulting visibility for the analyst. It is rated from 1+ (low) to 4+ (high). Counts from areas with 4+ background debris should be regarded as minimal counts and may be higher than reported. It is important to account for samples volumes when evaluating dust levels.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

§ Total Fungal Spores has been rounded to two significant figures to reflect analytical precision.



Client: TRC Solutions, Inc.  
 C/O: Ms. Victoria Shepersky  
 Re: 362890 West Tualatin ES

Date of Sampling: 09-18-2019  
 Date of Receipt: 09-19-2019  
 Date of Report: 09-19-2019

**SPORE TRAP REPORT: NON-VIABLE METHODOLOGY**

Location:	28956348: A122				28956453: LL10 Music				28956408: Production Rm Off Library				28956709: Tech Rm Off Library			
Comments (see below)	None				None				None				None			
Lab ID-Version‡:	10729993-1				10729994-1				10729995-1				10729996-1			
Analysis Date:	09/19/2019				09/19/2019				09/19/2019				09/19/2019			
Sample volume (liters)	75				75				75				75			
Background debris (1-4+)††	2+				2+				2+				1+			
	raw ct.	Count/m3	DL/m3*	%	raw ct.	Count/m3	DL/m3*	%	raw ct.	Count/m3	DL/m3*	%	raw ct.	Count/m3	DL/m3*	%
Hyphal fragments	3	40	13	n/a	2	27	13	n/a								
Pollen																
<b>§ TOTAL FUNGAL SPORES</b>	58	770	n/a	100	26	350	n/a	100	9	120	n/a	100	9	120	n/a	100
Alternaria																
Ascospores	11	150	13	19	3	40	13	12	1	13	13	11				
Basidiospores	33	440	13	57	10	130	13	38	5	67	13	56	7	93	13	78
Botrytis																
Cercospora																
Chaetomium																
Cladosporium	7	93	13	12	1	13	13	4					1	13	13	11
Epicoccum																
Other brown																
Penicillium/Aspergillus types	6	80	13	10	12	160	13	46	3	40	13	33	1	13	13	11
Pithomyces	1	13	13	2												
Rusts																
Stachybotrys																

**Comments:**

Spore types listed without a count or data entry were not detected during the course of the analysis for the respective sample, indicating a raw count of <1 spore.

The analytical sensitivity/limit of detection is the Count/m<sup>3</sup> divided by the raw count, expressed in Count/m<sup>3</sup>.

\*The detection limit/limit of detection (DL) per cubic meter (m<sup>3</sup>) has been rounded to two significant figures to reflect analytical precision.

††Background debris indicates the amount of non-biological particulate matter present on the trace (dust in the air) and the resulting visibility for the analyst. It is rated from 1+ (low) to 4+ (high). Counts from areas with 4+ background debris should be regarded as minimal counts and may be higher than reported. It is important to account for samples volumes when evaluating dust levels.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

§ Total Fungal Spores has been rounded to two significant figures to reflect analytical precision.

Client: TRC Solutions, Inc.  
 C/O: Ms. Victoria Shepersky  
 Re: 362890 West Tualatin ES

Date of Sampling: 09-18-2019  
 Date of Receipt: 09-19-2019  
 Date of Report: 09-19-2019

**SPORE TRAP REPORT: NON-VIABLE METHODOLOGY**

Location:	28956414: Library North Portion				28956417: Library South Portion				28956451: Resource Rm Off Library			
Comments (see below)	None				None				None			
Lab ID-Version‡:	10729997-1				10729998-1				10729999-1			
Analysis Date:	09/19/2019				09/19/2019				09/19/2019			
Sample volume (liters)	75				75				75			
Background debris (1-4+)††	2+				2+				2+			
	raw ct.	Count/m3	DL/m3*	%	raw ct.	Count/m3	DL/m3*	%	raw ct.	Count/m3	DL/m3*	%
Hyphal fragments									1	13	13	n/a
Pollen												
<b>§ TOTAL FUNGAL SPORES</b>	11	150	n/a	100	8	110	n/a	100	31	410	n/a	100
Alternaria												
Ascospores	2	27	13	18					1	13	13	3
Basidiospores	4	53	13	36	2	27	13	25	16	210	13	52
Botrytis												
Cercospora												
Chaetomium												
Cladosporium	2	27	13	18	1	13	13	13	2	27	13	6
Epicoccum												
Other brown					2	27	13	25				
Penicillium/Aspergillus types	3	40	13	27	3	40	13	38	12	160	13	39
Pithomyces												
Rusts												
Stachybotrys												

**Comments:**

Spore types listed without a count or data entry were not detected during the course of the analysis for the respective sample, indicating a raw count of <1 spore.

The analytical sensitivity/limit of detection is the Count/m<sup>3</sup> divided by the raw count, expressed in Count/m<sup>3</sup>.

\*The detection limit/limit of detection (DL) per cubic meter (m<sup>3</sup>) has been rounded to two significant figures to reflect analytical precision.

††Background debris indicates the amount of non-biological particulate matter present on the trace (dust in the air) and the resulting visibility for the analyst. It is rated from 1+ (low) to 4+ (high). Counts from areas with 4+ background debris should be regarded as minimal counts and may be higher than reported. It is important to account for samples volumes when evaluating dust levels.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

§ Total Fungal Spores has been rounded to two significant figures to reflect analytical precision.

Client: TRC Solutions, Inc.  
 C/O: Ms. Victoria Shepersky  
 Re: 362890 West Tualatin ES

Date of Sampling: 09-18-2019  
 Date of Receipt: 09-19-2019  
 Date of Report: 09-19-2019

**SPORE TRAP REPORT: NON-VIABLE METHODOLOGY**

Location:	28956728: Speech Rm				28956690: Outside Air S @ A114 & A112			
Comments (see below)	None				None			
Lab ID-Version‡:	10730000-1				10730001-1			
Analysis Date:	09/19/2019				09/19/2019			
Sample volume (liters)	75				75			
Background debris (1-4+)††	2+				1+			
	raw ct.	Count/m3	DL/m3*	%	raw ct.	Count/m3	DL/m3*	%
Hyphal fragments	1	13	13	n/a				
Pollen					7	93	13	n/a
<b>§ TOTAL FUNGAL SPORES</b>	19	250	n/a	100	243	26,000	n/a	100
Alternaria								
Ascospores	1	13	13	5	73	970	13	4
Basidiospores	9	120	13	47	136	24,000	180	94
Botrytis								
Cercospora					1	13	13	< 1
Chaetomium								
Cladosporium	7	93	13	37	22	290	13	1
Epicoccum					2	27	13	< 1
Other brown								
Penicillium/Aspergillus types					9	120	13	< 1
Pithomyces								
Smuts, Periconia, Myxomycetes	2	27	13	11				
Stachybotrys								

**Comments:**

Spore types listed without a count or data entry were not detected during the course of the analysis for the respective sample, indicating a raw count of <1 spore.

The analytical sensitivity/limit of detection is the Count/m<sup>3</sup> divided by the raw count, expressed in Count/m<sup>3</sup>.

\*The detection limit/limit of detection (DL) per cubic meter (m<sup>3</sup>) has been rounded to two significant figures to reflect analytical precision.

††Background debris indicates the amount of non-biological particulate matter present on the trace (dust in the air) and the resulting visibility for the analyst. It is rated from 1+ (low) to 4+ (high). Counts from areas with 4+ background debris should be regarded as minimal counts and may be higher than reported. It is important to account for samples volumes when evaluating dust levels.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

§ Total Fungal Spores has been rounded to two significant figures to reflect analytical precision.


Report for:

**Ms. Victoria Shepersky**  
**TRC Solutions, Inc.**  
4105 SE International Way, Suite 505  
Milwaukie, OR 97222

---

Regarding: Project: 362890, West Tualatin View ES  
EML ID: 2273798

Approved by:



Technical Manager  
Justin Ford

Dates of Analysis:  
Spore trap analysis: 10-11-2019

Service SOPs: Spore trap analysis (EM-MY-S-1038)  
AIHA-LAP, LLC accredited service, Lab ID #178599

---

All samples were received in acceptable condition unless noted in the Report Comments portion in the body of the report. Due to the nature of the analyses performed, field blank correction of results is not applied. The results relate only to the samples as received. Sample air volume is supplied by the client.

Eurofins EMLab P&K ("the Company") shall have no liability to the client or the client's customer with respect to decisions or recommendations made, actions taken or courses of conduct implemented by either the client or the client's customer as a result of or based upon the Test Results. In no event shall the Company be liable to the client with respect to the Test Results except for the Company's own willful misconduct or gross negligence nor shall the Company be liable for incidental or consequential damages or lost profits or revenues to the fullest extent such liability may be disclaimed by law, even if the Company has been advised of the possibility of such damages, lost profits or lost revenues. In no event shall the Company's liability with respect to the Test Results exceed the amount paid to the Company by the client therefor.

Eurofins EMLab P&K's LabServe® reporting system includes automated fail-safes to ensure that all AIHA-LAP, LLC quality requirements are met and notifications are added to reports when any quality steps remain pending.

Client: TRC Solutions, Inc.  
 C/O: Ms. Victoria Shepersky  
 Re: 362890, West Tualatin View ES

Date of Sampling: 10-10-2019  
 Date of Receipt: 10-11-2019  
 Date of Report: 10-11-2019

**SPORE TRAP REPORT: NON-VIABLE METHODOLOGY**

Location:	29149522: Outside Air North				29149953: A104				29149543: Production Room				29149946: Technology Room (South)			
Comments (see below)	A				A				A				A			
Lab ID-Version‡:	10811500-1				10811501-1				10811502-1				10811503-1			
Analysis Date:	10/11/2019				10/11/2019				10/11/2019				10/11/2019			
Sample volume (liters)	75				75				75				75			
Background debris (1-4+)††	2+				2+				2+				2+			
	raw ct.	Count/m3	DL/m3*	%	raw ct.	Count/m3	DL/m3*	%	raw ct.	Count/m3	DL/m3*	%	raw ct.	Count/m3	DL/m3*	%
Hypthal fragments	1	13	13	n/a												
Pollen	1	13	13	n/a												
<b>§ TOTAL FUNGAL SPORES</b>	154	2,100	n/a	100	21	280	n/a	100	95	1,300	n/a	100	252	3,400	n/a	100
Alternaria																
Ascospores	28	370	13	18												
Basidiospores	102	1,400	13	66	12	160	13	57					9	120	13	4
Botrytis																
Chaetomium																
Cladosporium	9	120	13	6	2	27	13	10	15	200	13	16	3	40	13	1
Other brown	1	13	13	1												
Penicillium/Aspergillus types	11	150	13	7	7	93	13	33	80	1,100	13	84	240	3,200	13	95
Rusts																
Smuts, Periconia, Myxomycetes	3	40	13	2												
Stachybotrys																
Torula																
Ulocladium																

**Comments:** A) Analysis of replicate sample is delayed.

Spore types listed without a count or data entry were not detected during the course of the analysis for the respective sample, indicating a raw count of <1 spore.

The analytical sensitivity/limit of detection is the Count/m<sup>3</sup> divided by the raw count, expressed in Count/m<sup>3</sup>.

\*The detection limit/limit of detection (DL) per cubic meter (m<sup>3</sup>) has been rounded to two significant figures to reflect analytical precision.

††Background debris indicates the amount of non-biological particulate matter present on the trace (dust in the air) and the resulting visibility for the analyst. It is rated from 1+ (low) to 4+ (high). Counts from areas with 4+ background debris should be regarded as minimal counts and may be higher than reported. It is important to account for samples volumes when evaluating dust levels.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

§ Total Fungal Spores has been rounded to two significant figures to reflect analytical precision.

Client: TRC Solutions, Inc.  
 C/O: Ms. Victoria Shepersky  
 Re: 362890, West Tualatin View ES

Date of Sampling: 10-10-2019  
 Date of Receipt: 10-11-2019  
 Date of Report: 10-11-2019

**SPORE TRAP REPORT: NON-VIABLE METHODOLOGY**

Location:	29149944: A110				29149951: A112				29149958: A114				29149968: A116			
Comments (see below)	A				A				A				A			
Lab ID-Version‡:	10811504-1				10811505-1				10811506-1				10811507-1			
Analysis Date:	10/11/2019				10/11/2019				10/11/2019				10/11/2019			
Sample volume (liters)	75				75				75				75			
Background debris (1-4+)††	1+				1+				2+				2+			
	raw ct.	Count/m3	DL/m3*	%	raw ct.	Count/m3	DL/m3*	%	raw ct.	Count/m3	DL/m3*	%	raw ct.	Count/m3	DL/m3*	%
Hyphal fragments									1	13	13	n/a				
Pollen																
<b>§ TOTAL FUNGAL SPORES</b>	14	190	n/a	100	12	160	n/a	100	74	990	n/a	100	38	510	n/a	100
Alternaria																
Ascospores	3	40	13	21	1	13	13	8	13	170	13	18	4	53	13	11
Basidiospores	6	80	13	43	6	80	13	50	22	290	13	30	18	240	13	47
Botrytis																
Chaetomium																
Cladosporium	1	13	13	7	2	27	13	17					1	13	13	3
Other brown																
Penicillium/Aspergillus types	3	40	13	21	3	40	13	25	38	510	13	51	14	190	13	37
Rusts													1	13	13	3
Smuts, Periconia, Myxomycetes	1	13	13	7					1	13	13	1				
Stachybotrys																
Torula																
Ulocladium																

**Comments:** A) Analysis of replicate sample is delayed.

Spore types listed without a count or data entry were not detected during the course of the analysis for the respective sample, indicating a raw count of <1 spore.

The analytical sensitivity/limit of detection is the Count/m<sup>3</sup> divided by the raw count, expressed in Count/m<sup>3</sup>.

\*The detection limit/limit of detection (DL) per cubic meter (m<sup>3</sup>) has been rounded to two significant figures to reflect analytical precision.

††Background debris indicates the amount of non-biological particulate matter present on the trace (dust in the air) and the resulting visibility for the analyst. It is rated from 1+ (low) to 4+ (high). Counts from areas with 4+ background debris should be regarded as minimal counts and may be higher than reported. It is important to account for samples volumes when evaluating dust levels.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

§ Total Fungal Spores has been rounded to two significant figures to reflect analytical precision.

Client: TRC Solutions, Inc.  
 C/O: Ms. Victoria Shepersky  
 Re: 362890, West Tualatin View ES

Date of Sampling: 10-10-2019  
 Date of Receipt: 10-11-2019  
 Date of Report: 10-11-2019

**SPORE TRAP REPORT: NON-VIABLE METHODOLOGY**

Location:	29149941: A122				29149950: Outside Air South			
Comments (see below)	A				A			
Lab ID-Version‡:	10811508-1				10811509-1			
Analysis Date:	10/11/2019				10/11/2019			
Sample volume (liters)	75				75			
Background debris (1-4+)††	2+				2+			
	raw ct.	Count/m3	DL/m3*	%	raw ct.	Count/m3	DL/m3*	%
Hyphal fragments	1	13	13	n/a	2	27	13	n/a
Pollen								
<b>§ TOTAL FUNGAL SPORES</b>	200	2,700	n/a	100	151	2,000	n/a	100
Alternaria					1	13	13	1
Ascospores	22	290	13	11	30	400	13	20
Basidiospores	35	470	13	18	69	920	13	46
Botrytis					1	13	13	1
Chaetomium								
Cladosporium	27	360	13	14	27	360	13	18
Other brown								
Penicillium/Aspergillus types	116	1,500	13	58	12	160	13	8
Rusts								
Smuts, Periconia, Myxomycetes					11	150	13	7
Stachybotrys								
Torula								
Ulocladium								

**Comments:** A) Analysis of replicate sample is delayed.

Spore types listed without a count or data entry were not detected during the course of the analysis for the respective sample, indicating a raw count of <1 spore.

The analytical sensitivity/limit of detection is the Count/m<sup>3</sup> divided by the raw count, expressed in Count/m<sup>3</sup>.

\*The detection limit/limit of detection (DL) per cubic meter (m<sup>3</sup>) has been rounded to two significant figures to reflect analytical precision.

††Background debris indicates the amount of non-biological particulate matter present on the trace (dust in the air) and the resulting visibility for the analyst. It is rated from 1+ (low) to 4+ (high). Counts from areas with 4+ background debris should be regarded as minimal counts and may be higher than reported. It is important to account for samples volumes when evaluating dust levels.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

§ Total Fungal Spores has been rounded to two significant figures to reflect analytical precision.


Report for:

**Ms. Victoria Shepersky**  
**TRC Solutions, Inc.**  
4105 SE International Way, Suite 505  
Milwaukie, OR 97222

---

Regarding: Project: 362890; West Tualatin View Elementary  
EML ID: 2277919

Approved by:



Operations Manager  
Joshua Cox

Dates of Analysis:

Spore trap analysis: 10-17-2019

Service SOPs: Spore trap analysis (EM-MY-S-1038)  
AIHA-LAP, LLC accredited service, Lab ID #102297

---

All samples were received in acceptable condition unless noted in the Report Comments portion in the body of the report. Due to the nature of the analyses performed, field blank correction of results is not applied. The results relate only to the samples as received. Sample air volume is supplied by the client.

Eurofins EMLab P&K ("the Company") shall have no liability to the client or the client's customer with respect to decisions or recommendations made, actions taken or courses of conduct implemented by either the client or the client's customer as a result of or based upon the Test Results. In no event shall the Company be liable to the client with respect to the Test Results except for the Company's own willful misconduct or gross negligence nor shall the Company be liable for incidental or consequential damages or lost profits or revenues to the fullest extent such liability may be disclaimed by law, even if the Company has been advised of the possibility of such damages, lost profits or lost revenues. In no event shall the Company's liability with respect to the Test Results exceed the amount paid to the Company by the client therefor.

Eurofins EMLab P&K's LabServe® reporting system includes automated fail-safes to ensure that all AIHA-LAP, LLC quality requirements are met and notifications are added to reports when any quality steps remain pending.



Client: TRC Solutions, Inc.  
 C/O: Ms. Victoria Shepersky  
 Re: 362890; West Tualatin View Elementary

Date of Sampling: 10-16-2019  
 Date of Receipt: 10-17-2019  
 Date of Report: 10-17-2019

**SPORE TRAP REPORT: NON-VIABLE METHODOLOGY**

Location:	29149961: Outside Air South				29149957: Main Corridor Boys RR				29149959: Office 2				29149955: Speech Office			
Comments (see below)	None				None				None				None			
Lab ID-Version‡:	10830793-1				10830794-1				10830795-1				10830796-1			
Analysis Date:	10/17/2019				10/17/2019				10/17/2019				10/17/2019			
Sample volume (liters)	75				75				75				75			
Background debris (1-4+)††	< 1+				3+				3+				3+			
	raw ct.	Count/m3	DL/m3*	%	raw ct.	Count/m3	DL/m3*	%	raw ct.	Count/m3	DL/m3*	%	raw ct.	Count/m3	DL/m3*	%
Hyphal fragments									1	13	13	n/a				
Pollen									1	13	13	n/a				
<b>§ TOTAL FUNGAL SPORES</b>	148	10,000	n/a	100	14	190	n/a	100	21	280	n/a	100	29	390	n/a	100
Ascospores	32	4,300	130	43					1	13	13	5	2	27	13	7
Basidiospores	35	4,700	130	47	3	40	13	21	1	13	13	5				
Chaetomium																
Cladosporium	5	67	13	1	3	40	13	21	3	40	13	14				
Epicoccum	1	13	13	< 1												
Penicillium/Aspergillus types	74	990	13	10	7	93	13	50	16	210	13	76	27	360	13	93
Smuts, Periconia, Myxomycetes	1	13	13	< 1	1	13	13	7								
Stachybotrys																
Stemphylium																
Torula																
Ulocladium																
Zygomycetes																

**Comments:**

Spore types listed without a count or data entry were not detected during the course of the analysis for the respective sample, indicating a raw count of <1 spore.

The analytical sensitivity/limit of detection is the Count/m<sup>3</sup> divided by the raw count, expressed in Count/m<sup>3</sup>.

\*The detection limit/limit of detection (DL) per cubic meter (m<sup>3</sup>) has been rounded to two significant figures to reflect analytical precision.

††Background debris indicates the amount of non-biological particulate matter present on the trace (dust in the air) and the resulting visibility for the analyst. It is rated from 1+ (low) to 4+ (high). Counts from areas with 4+ background debris should be regarded as minimal counts and may be higher than reported. It is important to account for samples volumes when evaluating dust levels.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

§ Total Fungal Spores has been rounded to two significant figures to reflect analytical precision.

Client: TRC Solutions, Inc.  
 C/O: Ms. Victoria Shepersky  
 Re: 362890; West Tualatin View Elementary

Date of Sampling: 10-16-2019  
 Date of Receipt: 10-17-2019  
 Date of Report: 10-17-2019

**SPORE TRAP REPORT: NON-VIABLE METHODOLOGY**

Location:	29149962: <b>Tech Room (South)</b>				29149964: <b>Tech Room (North)</b>				29149963: Outside Air North			
Comments (see below)	None				None				None			
Lab ID-Version‡:	10830797-1				10830798-1				10830799-1			
Analysis Date:	10/17/2019				10/17/2019				10/17/2019			
Sample volume (liters)	75				75				75			
Background debris (1-4+)††	3+				4+				< 1+			
	raw ct.	Count/m3	DL/m3*	%	raw ct.	Count/m3	DL/m3*	%	raw ct.	Count/m3	DL/m3*	%
Hyphal fragments	1	13	13	n/a	1	13	13	n/a				
Pollen	1	13	13	n/a								
<b>§ TOTAL FUNGAL SPORES</b>	<b>45</b>	<b>600</b>	<b>n/a</b>	<b>100</b>	<b>48</b>	<b>640</b>	<b>n/a</b>	<b>100</b>	<b>165</b>	<b>2,200</b>	<b>n/a</b>	<b>100</b>
Ascospores					3	40	13	6	33	440	13	20
Basidiospores					2	27	13	4	122	1,600	13	74
Chaetomium					1	13	13	2				
Cladosporium	1	13	13	2	8	110	13	17	2	27	13	1
Epicoccum												
Penicillium/Aspergillus types	43	<b>570</b>	13	96	31	<b>410</b>	13	65	8	110	13	5
Smuts, Periconia, Myxomycetes	1	13	13	2	1	13	13	2				
Stachybotrys					2	27	13	4				
Stemphylium												
Torula												
Ulocladium												
Zygomycetes												

**Comments:**

Spore types listed without a count or data entry were not detected during the course of the analysis for the respective sample, indicating a raw count of <1 spore.

The analytical sensitivity/limit of detection is the Count/m<sup>3</sup> divided by the raw count, expressed in Count/m<sup>3</sup>.

\*The detection limit/limit of detection (DL) per cubic meter (m<sup>3</sup>) has been rounded to two significant figures to reflect analytical precision.

††Background debris indicates the amount of non-biological particulate matter present on the trace (dust in the air) and the resulting visibility for the analyst. It is rated from 1+ (low) to 4+ (high). Counts from areas with 4+ background debris should be regarded as minimal counts and may be higher than reported. It is important to account for samples volumes when evaluating dust levels.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

§ Total Fungal Spores has been rounded to two significant figures to reflect analytical precision.


Report for:

**Ms. Victoria Shepersky**  
**TRC Solutions, Inc.**  
4105 SE International Way, Suite 505  
Milwaukie, OR 97222

---

Regarding: Project: 362890 West Tualatin View ES  
EML ID: 2279835

Approved by:



Operations Manager  
Joshua Cox

Dates of Analysis:

Spore trap analysis: 10-21-2019

Service SOPs: Spore trap analysis (EM-MY-S-1038)  
AIHA-LAP, LLC accredited service, Lab ID #102297

---

All samples were received in acceptable condition unless noted in the Report Comments portion in the body of the report. Due to the nature of the analyses performed, field blank correction of results is not applied. The results relate only to the samples as received. Sample air volume is supplied by the client.

Eurofins EMLab P&K ("the Company") shall have no liability to the client or the client's customer with respect to decisions or recommendations made, actions taken or courses of conduct implemented by either the client or the client's customer as a result of or based upon the Test Results. In no event shall the Company be liable to the client with respect to the Test Results except for the Company's own willful misconduct or gross negligence nor shall the Company be liable for incidental or consequential damages or lost profits or revenues to the fullest extent such liability may be disclaimed by law, even if the Company has been advised of the possibility of such damages, lost profits or lost revenues. In no event shall the Company's liability with respect to the Test Results exceed the amount paid to the Company by the client therefor.

Eurofins EMLab P&K's LabServe® reporting system includes automated fail-safes to ensure that all AIHA-LAP, LLC quality requirements are met and notifications are added to reports when any quality steps remain pending.

Client: TRC Solutions, Inc.  
 C/O: Ms. Victoria Shepersky  
 Re: 362890 West Tualatin View ES

Date of Sampling: 10-18-2019  
 Date of Receipt: 10-21-2019  
 Date of Report: 10-21-2019

**SPORE TRAP REPORT: NON-VIABLE METHODOLOGY**

Location:	29149694: Outside Air East				29149676: <b>Tech Room North</b>				29149679: <b>Tech Room South</b>				29149811: Outside Air West			
Comments (see below)	None				None				None				None			
Lab ID-Version‡:	10840034-1				10840035-1				10840036-1				10840037-1			
Analysis Date:	10/21/2019				10/21/2019				10/21/2019				10/21/2019			
Sample volume (liters)	75				75				75				75			
Background debris (1-4+)††	1+				3+				3+				1+			
	raw ct.	Count/m3	DL/m3*	%	raw ct.	Count/m3	DL/m3*	%	raw ct.	Count/m3	DL/m3*	%	raw ct.	Count/m3	DL/m3*	%
Hyphal fragments									1	13	13	n/a				
Pollen																
<b>§ TOTAL FUNGAL SPORES</b>	333	76,000	n/a	100	176	8,100	n/a	100	180	8,800	n/a	100	317	67,000	n/a	100
Ascospores	54	7,200	130	10	28	370	13	5	19	250	13	3	65	3,500	53	5
Basidiospores	255	68,000	270	90	55	2,900	53	36	91	4,900	53	55	239	64,000	270	95
Chaetomium					1	13	13	< 1								
Cladosporium	11	150	13	< 1	3	40	13	< 1	2	27	13	< 1	9	120	13	< 1
Penicillium/Aspergillus types	13	170	13	< 1	89	<b>4,700</b>	53	59	68	<b>3,600</b>	53	41	4	53	13	< 1
Rusts																
Smuts, Periconia, Myxomycetes																
Stachybotrys																
Stemphylium																
Torula																
Ulocladium																
Zygomycetes																

**Comments:**

Spore types listed without a count or data entry were not detected during the course of the analysis for the respective sample, indicating a raw count of <1 spore.

The analytical sensitivity/limit of detection is the Count/m<sup>3</sup> divided by the raw count, expressed in Count/m<sup>3</sup>.

\*The detection limit/limit of detection (DL) per cubic meter (m<sup>3</sup>) has been rounded to two significant figures to reflect analytical precision.

††Background debris indicates the amount of non-biological particulate matter present on the trace (dust in the air) and the resulting visibility for the analyst. It is rated from 1+ (low) to 4+ (high). Counts from areas with 4+ background debris should be regarded as minimal counts and may be higher than reported. It is important to account for samples volumes when evaluating dust levels.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

§ Total Fungal Spores has been rounded to two significant figures to reflect analytical precision.


Report for:

**Ms. Victoria Shepersky**  
**TRC Solutions, Inc.**  
4105 SE International Way, Suite 505  
Milwaukie, OR 97222

---

Regarding: Project: 362890; West Tualatin View  
EML ID: 2280931

Approved by:



Technical Manager  
Justin Ford

Dates of Analysis:

Spore trap analysis: 10-22-2019

Service SOPs: Spore trap analysis (EM-MY-S-1038)  
AIHA-LAP, LLC accredited service, Lab ID #178599

---

All samples were received in acceptable condition unless noted in the Report Comments portion in the body of the report. Due to the nature of the analyses performed, field blank correction of results is not applied. The results relate only to the samples as received. Sample air volume is supplied by the client.

Eurofins EMLab P&K ("the Company") shall have no liability to the client or the client's customer with respect to decisions or recommendations made, actions taken or courses of conduct implemented by either the client or the client's customer as a result of or based upon the Test Results. In no event shall the Company be liable to the client with respect to the Test Results except for the Company's own willful misconduct or gross negligence nor shall the Company be liable for incidental or consequential damages or lost profits or revenues to the fullest extent such liability may be disclaimed by law, even if the Company has been advised of the possibility of such damages, lost profits or lost revenues. In no event shall the Company's liability with respect to the Test Results exceed the amount paid to the Company by the client therefor.

Eurofins EMLab P&K's LabServe® reporting system includes automated fail-safes to ensure that all AIHA-LAP, LLC quality requirements are met and notifications are added to reports when any quality steps remain pending.

Client: TRC Solutions, Inc.  
 C/O: Ms. Victoria Shepersky  
 Re: 362890; West Tualatin View

Date of Sampling: 10-21-2019  
 Date of Receipt: 10-22-2019  
 Date of Report: 10-22-2019

**SPORE TRAP REPORT: NON-VIABLE METHODOLOGY**

Location:	29149972: Outside Air West				29149999: A118				29149956: Music room (LL10)				29149997: Gymnasium SE			
Comments (see below)	None				None				None				None			
Lab ID-Version‡:	10845678-1				10845679-1				10845680-1				10845681-1			
Analysis Date:	10/22/2019				10/22/2019				10/22/2019				10/22/2019			
Sample volume (liters)	75				75				75				75			
Background debris (1-4+)††	1+				2+				2+				2+			
	raw ct.	Count/m3	DL/m3*	%	raw ct.	Count/m3	DL/m3*	%	raw ct.	Count/m3	DL/m3*	%	raw ct.	Count/m3	DL/m3*	%
Hyphal fragments																
Pollen																
<b>§ TOTAL FUNGAL SPORES</b>	652	8,700	n/a	100	9	120	n/a	100	1	13	n/a	100	6	80	n/a	100
Ascospores	251	3,300	13	38	1	13	13	11								
Basidiospores	388	5,200	13	60	6	80	13	67					5	67	13	83
Chaetomium																
Cladosporium	2	27	13	< 1												
Oidium																
Other brown					1	13	13	11								
Penicillium/Aspergillus types	11	150	13	2	1	13	13	11	1	13	13	100	1	13	13	17
Smuts, Periconia, Myxomycetes																
Stachybotrys																
Stemphylium																
Torula																
Ulocladium																
Zygomycetes																

**Comments:**

Spore types listed without a count or data entry were not detected during the course of the analysis for the respective sample, indicating a raw count of <1 spore.

The analytical sensitivity/limit of detection is the Count/m<sup>3</sup> divided by the raw count, expressed in Count/m<sup>3</sup>.

\*The detection limit/limit of detection (DL) per cubic meter (m<sup>3</sup>) has been rounded to two significant figures to reflect analytical precision.

††Background debris indicates the amount of non-biological particulate matter present on the trace (dust in the air) and the resulting visibility for the analyst. It is rated from 1+ (low) to 4+ (high). Counts from areas with 4+ background debris should be regarded as minimal counts and may be higher than reported. It is important to account for samples volumes when evaluating dust levels.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

§ Total Fungal Spores has been rounded to two significant figures to reflect analytical precision.

Client: TRC Solutions, Inc.  
 C/O: Ms. Victoria Shepersky  
 Re: 362890; West Tualatin View

Date of Sampling: 10-21-2019  
 Date of Receipt: 10-22-2019  
 Date of Report: 10-22-2019

**SPORE TRAP REPORT: NON-VIABLE METHODOLOGY**

Location:	29149969: Gymnasium NW				29149971: Stage				29149977: A Hall Stairwell				29149974: Technology Room South			
Comments (see below)	None				None				None				None			
Lab ID-Version‡:	10845682-1				10845683-1				10845684-1				10845685-1			
Analysis Date:	10/22/2019				10/22/2019				10/22/2019				10/22/2019			
Sample volume (liters)	75				75				75				75			
Background debris (1-4+)††	3+				3+				3+				2+			
	raw ct.	Count/m3	DL/m3*	%	raw ct.	Count/m3	DL/m3*	%	raw ct.	Count/m3	DL/m3*	%	raw ct.	Count/m3	DL/m3*	%
Hyphal fragments	1	13	13	n/a	1	13	13	n/a					1	13	13	n/a
Pollen					1	13	13	n/a								
<b>§ TOTAL FUNGAL SPORES</b>	15	200	n/a	100	19	250	n/a	100	32	430	n/a	100	28	370	n/a	100
Ascospores	3	40	13	20									4	53	13	14
Basidiospores	5	67	13	33	8	110	13	42	24	320	13	75	14	190	13	50
Chaetomium																
Cladosporium	2	27	13	13	4	53	13	21	1	13	13	3	2	27	13	7
Oidium																
Other brown	1	13	13	7												
Penicillium/Aspergillus types	4	53	13	27	7	93	13	37	7	93	13	22	8	110	13	29
Smuts, Periconia, Myxomycetes																
Stachybotrys																
Stemphylium																
Torula																
Ulocladium																
Zygomycetes																

**Comments:**

Spore types listed without a count or data entry were not detected during the course of the analysis for the respective sample, indicating a raw count of <1 spore.

The analytical sensitivity/limit of detection is the Count/m<sup>3</sup> divided by the raw count, expressed in Count/m<sup>3</sup>.

\*The detection limit/limit of detection (DL) per cubic meter (m<sup>3</sup>) has been rounded to two significant figures to reflect analytical precision.

††Background debris indicates the amount of non-biological particulate matter present on the trace (dust in the air) and the resulting visibility for the analyst. It is rated from 1+ (low) to 4+ (high). Counts from areas with 4+ background debris should be regarded as minimal counts and may be higher than reported. It is important to account for samples volumes when evaluating dust levels.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

§ Total Fungal Spores has been rounded to two significant figures to reflect analytical precision.

Client: TRC Solutions, Inc.  
 C/O: Ms. Victoria Shepersky  
 Re: 362890; West Tualatin View

Date of Sampling: 10-21-2019  
 Date of Receipt: 10-22-2019  
 Date of Report: 10-22-2019

**SPORE TRAP REPORT: NON-VIABLE METHODOLOGY**

Location:	29149976: <b>Technology Room North</b>				29149982: Outside Air North			
Comments (see below)	None				None			
Lab ID-Version‡:	10845686-1				10845687-1			
Analysis Date:	10/22/2019				10/22/2019			
Sample volume (liters)	75				75			
Background debris (1-4+)††	3+				2+			
	raw ct.	Count/m3	DL/m3*	%	raw ct.	Count/m3	DL/m3*	%
Hyphal fragments					1	13	13	n/a
Pollen					5	67	13	n/a
<b>§ TOTAL FUNGAL SPORES</b>	28	370	n/a	100	403	5,400	n/a	100
Ascospores	1	13	13	4	244	3,300	13	61
Basidiospores	8	110	13	29	120	1,600	13	30
Chaetomium								
Cladosporium	3	40	13	11	21	280	13	5
Oidium					1	13	13	< 1
Other brown	1	13	13	4				
Penicillium/Aspergillus types	15	200	13	54	17	230	13	4
Smuts, Periconia, Myxomycetes								
Stachybotrys								
Stemphylium								
Torula								
Ulocladium								
Zygomycetes								

**Comments:**

Spore types listed without a count or data entry were not detected during the course of the analysis for the respective sample, indicating a raw count of <1 spore.

The analytical sensitivity/limit of detection is the Count/m<sup>3</sup> divided by the raw count, expressed in Count/m<sup>3</sup>.

\*The detection limit/limit of detection (DL) per cubic meter (m<sup>3</sup>) has been rounded to two significant figures to reflect analytical precision.

††Background debris indicates the amount of non-biological particulate matter present on the trace (dust in the air) and the resulting visibility for the analyst. It is rated from 1+ (low) to 4+ (high). Counts from areas with 4+ background debris should be regarded as minimal counts and may be higher than reported. It is important to account for samples volumes when evaluating dust levels.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

§ Total Fungal Spores has been rounded to two significant figures to reflect analytical precision.



Client: TRC Solutions, Inc.  
C/O: Ms. Victoria Shepersky  
Re: 362890; West Tualatin View

Date of Sampling: 10-21-2019  
Date of Receipt: 10-22-2019  
Date of Report: 10-22-2019

**MoldRANGE™, Local Climate; Extended Outdoor Comparison**  
**Outdoor Location: 29149972, Outside Air West**

Fungi Identified	Outdoor data	Typical Outdoor Data for: October in Oregon† EMLab Local Climate code¹						Typical Outdoor Data for: The entire year in Oregon† EMLab Local Climate code¹					
		A Annual Temp, B Elev., B Rain, B Temp. Range (n‡=171)						A Annual Temp, B Elev., B Rain, B Temp. Range (n‡=2055)					
Project zip code 97225	spores/m3	very low	low	med	high	very high	freq %	very low	low	med	high	very high	freq %
<b>Generally able to grow indoors*</b>													
Alternaria	-	13	13	19	53	80	30	13	13	13	53	67	19
Bipolaris/Drechslera group	-	-	-	-	-	-	4	10	13	13	27	50	2
Chaetomium	-	-	-	-	-	-	5	12	13	13	13	31	5
Cladosporium	27	320	480	1,400	3,300	5,600	99	53	110	430	1,600	3,100	87
Curvularia	-	-	-	-	-	-	2	13	13	13	13	13	1
Nigrospora	-	-	-	-	-	-	3	7	13	13	27	53	2
Other brown	-	13	13	27	53	91	38	13	13	13	53	67	25
Penicillium/Aspergillus types	150	160	290	560	1,800	2,400	98	53	110	320	800	1,500	90
Stachybotrys	-	-	-	-	-	-	1	7	13	13	110	1,000	< 1
Torula	-	-	-	-	-	-	5	13	13	13	40	60	6
<b>Seldom found growing indoors**</b>													
Ascospores	3,300	110	320	1,300	3,700	6,400	98	80	160	530	1,900	3,500	93
Basidiospores	5,200	650	1,700	5,800	13,000	18,000	> 99	200	370	1,400	4,700	8,500	98
Oidium	-	13	13	27	53	110	25	13	13	27	67	130	19
Rusts	-	13	13	13	40	67	36	13	13	20	53	93	22
Smuts, Periconia, Myxomycetes	-	13	13	53	130	260	67	13	13	40	110	220	52
<b>§ TOTAL SPORES/m3</b>	<b>8,700</b>												

¹EMLab Local Climate codes are a climate classification scheme for statewide geographic areas. The MoldRANGE™ Local Climate report uses the sampling location zip code to identify the EMLab Local Climate code in that area. Using information available from the NOAA weather database, the EMLab Local Climate code sharpens the precision of the MoldRANGE™ reporting system, providing more reliable estimates of the range and average concentrations of the different airborne fungal spore types for each region. Additional information on the EMLab Local Climate code system can be found on the last page of this report.

‡The Typical Outdoor Data represents the typical outdoor spore levels across the state for the time period and EMLab Local Climate code indicated. The last column represents the frequency of occurrence. The very low, low, med, high, and very high values represent the 10, 20, 50, 80, and 90 percentile values of the spore type when it is detected. For example, if the frequency of occurrence is 63% and the low value is 53, it would mean that the given spore type is detected 63% of the time and, when detected, 20% of the time it is present in levels above the detection limit and below 53 spores/m3. These values are updated periodically and if not enough data is available to make a statistically meaningful assessment, it is indicated with a dash.

‡ n is the sample size used to calculate the MoldRANGE™ Local Climate data summarized in the table.

\* The spores in this category are generally capable of growing on wet building materials in addition to growing outdoors. Building related growth is dependent upon the fungal type, moisture level, type of material, and other factors. *Cladosporium* is one of the predominant spore types worldwide and is frequently present in high numbers. *Penicillium/Aspergillus* species colonize both outdoor and indoor wet surfaces rapidly and are very easily dispersed. Other genera are usually present in lesser numbers.

\*\* These fungi are generally not found growing on wet building materials. For example, the rusts and smuts are obligate plant pathogens. However, in each group there are notable exceptions. For example, agents of wood decay are members of the basidiomycetes and high counts of a single morphological type of basidiospore on an inside sample should be considered significant.

§ Total Spores/m3 has been rounded to two significant figures to reflect analytical precision.

Client: TRC Solutions, Inc.  
C/O: Ms. Victoria Shepersky  
Re: 362890; West Tualatin View

Date of Sampling: 10-21-2019  
Date of Receipt: 10-22-2019  
Date of Report: 10-22-2019

**MoldRANGE™, Local Climate; Extended Outdoor Comparison**  
**Outdoor Location: 29149982, Outside Air North**

Fungi Identified	Outdoor data	Typical Outdoor Data for: October in Oregon† EMLab Local Climate code¹						Typical Outdoor Data for: The entire year in Oregon† EMLab Local Climate code¹					
		A Annual Temp, B Elev., B Rain, B Temp. Range (n‡=171)						A Annual Temp, B Elev., B Rain, B Temp. Range (n‡=2055)					
Project zip code 97225	spores/m3	very low	low	med	high	very high	freq %	very low	low	med	high	very high	freq %
<b>Generally able to grow indoors*</b>													
Alternaria	-	13	13	19	53	80	30	13	13	13	53	67	19
Bipolaris/Drechslera group	-	-	-	-	-	-	4	10	13	13	27	50	2
Chaetomium	-	-	-	-	-	-	5	12	13	13	13	31	5
Cladosporium	280	320	480	1,400	3,300	5,600	99	53	110	430	1,600	3,100	87
Curvularia	-	-	-	-	-	-	2	13	13	13	13	13	1
Nigrospora	-	-	-	-	-	-	3	7	13	13	27	53	2
Other brown	-	13	13	27	53	91	38	13	13	13	53	67	25
Penicillium/Aspergillus types	230	160	290	560	1,800	2,400	98	53	110	320	800	1,500	90
Stachybotrys	-	-	-	-	-	-	1	7	13	13	110	1,000	< 1
Torula	-	-	-	-	-	-	5	13	13	13	40	60	6
<b>Seldom found growing indoors**</b>													
Ascospores	3,300	110	320	1,300	3,700	6,400	98	80	160	530	1,900	3,500	93
Basidiospores	1,600	650	1,700	5,800	13,000	18,000	> 99	200	370	1,400	4,700	8,500	98
Oidium	13	13	13	27	53	110	25	13	13	27	67	130	19
Rusts	-	13	13	13	40	67	36	13	13	20	53	93	22
Smuts, Periconia, Myxomycetes	-	13	13	53	130	260	67	13	13	40	110	220	52
<b>§ TOTAL SPORES/m3</b>	<b>5,400</b>												

¹EMLab Local Climate codes are a climate classification scheme for statewide geographic areas. The MoldRANGE™ Local Climate report uses the sampling location zip code to identify the EMLab Local Climate code in that area. Using information available from the NOAA weather database, the EMLab Local Climate code sharpens the precision of the MoldRANGE™ reporting system, providing more reliable estimates of the range and average concentrations of the different airborne fungal spore types for each region. Additional information on the EMLab Local Climate code system can be found on the last page of this report.

‡The Typical Outdoor Data represents the typical outdoor spore levels across the state for the time period and EMLab Local Climate code indicated. The last column represents the frequency of occurrence. The very low, low, med, high, and very high values represent the 10, 20, 50, 80, and 90 percentile values of the spore type when it is detected. For example, if the frequency of occurrence is 63% and the low value is 53, it would mean that the given spore type is detected 63% of the time and, when detected, 20% of the time it is present in levels above the detection limit and below 53 spores/m3. These values are updated periodically and if not enough data is available to make a statistically meaningful assessment, it is indicated with a dash.

‡ n is the sample size used to calculate the MoldRANGE™ Local Climate data summarized in the table.

\* The spores in this category are generally capable of growing on wet building materials in addition to growing outdoors. Building related growth is dependent upon the fungal type, moisture level, type of material, and other factors. *Cladosporium* is one of the predominant spore types worldwide and is frequently present in high numbers. *Penicillium/Aspergillus* species colonize both outdoor and indoor wet surfaces rapidly and are very easily dispersed. Other genera are usually present in lesser numbers.

\*\* These fungi are generally not found growing on wet building materials. For example, the rusts and smuts are obligate plant pathogens. However, in each group there are notable exceptions. For example, agents of wood decay are members of the basidiomycetes and high counts of a single morphological type of basidiospore on an inside sample should be considered significant.

§ Total Spores/m3 has been rounded to two significant figures to reflect analytical precision.

Client: TRC Solutions, Inc.  
C/O: Ms. Victoria Shepersky  
Re: 362890; West Tualatin View

Date of Sampling: 10-21-2019  
Date of Receipt: 10-22-2019  
Date of Report: 10-22-2019

---

### Understanding EMLab Local Climate Codes

---

Outdoor airborne spore concentrations are strongly influenced by climate and weather patterns, often resulting in pronounced seasonal and diurnal cycles (Burge 1995). The seasonal climatic changes directly affect the growth cycle of plants, thereby influencing fungal growth, spore maturation, and release cycles. By evaluating outdoor spore concentrations across similar climatic zones rather than for the state as a whole, it is possible to provide a more representative estimate of typical outdoor spore levels and frequency of occurrence for different airborne fungal spore types in a given area.

The EMLab Local Climate code system is a novel and patent pending classification system that uses data from the NOAA - National Oceanic and Atmospheric Administration database to define unique climate regions by state. The following local climate variables, for each statewide zip code, are obtained from NOAA and assigned a letter code of A (above the statewide average for that variable) or B (below the statewide average for that variable):

1. Annual High Temperature
2. Elevation
3. Rainfall/Precipitation
4. Monthly Temperature Range

The result is a 4-character code assigned to each statewide zip code, referred to as the Local Climate Code. Below are some examples of decoded Local Climate Codes:

**AAAA** = Above avg. Annual High Temperature, Above avg. Elevation, Above avg. Rainfall/Precipitation, Above avg. Monthly Temperature Range  
**AABB** = Above avg. Annual High Temperature, Above avg. Elevation, Below avg. Rainfall/Precipitation, Below avg. Monthly Temperature Range  
**BBA A** = Below avg. Annual High Temperature, Below avg. Elevation, Above avg. Rainfall/Precipitation, Above avg. Monthly Temperature Range

The actual outdoor air sample data from matching local climate codes in each state are then compiled in a manner relating typical spore concentrations and frequency of occurrence.

The NOAA local climate variables were selected by mapping data points from a subset of approximately 145,000 weather and geographic database entries to over 80,000 outdoor spore trap samples with known zip codes and assessing them using orthogonal array experimental design techniques. The results were then compared to the typical ranges of spore types found when grouping zip codes using the Koppen-Geiger climatic classification system; a commonly used climatic system that provides an objective numerical definition in terms of climatic elements such as temperature, rainfall, and other seasonal characteristics. The EMLab Local Climate codes showed improved granularity and refinement of the zip code groupings, implying a better representation of the expected range of spore types to be found within an individual zip code.

The values on this report were calculated by obtaining the four variables listed above from the over 585 million data points of weather and geographic information available in the NOAA database, and determining the frequencies and percentile values of spore types by utilizing over 180,000 Eurofins EMLab P&K outdoor spore trap samples with known zip codes.

This report groups statewide zip codes in relation to these EMLab Local Climate codes and summarizes MoldRANGE™ data by month and year within each EMLab Local Climate code.

#### References:

Burge, Harriet, A. Bioaerosols: Boca Raton: Lewis Publishers, pp. 163-171, 1995.

Interpretation of the data contained in this report is left to the client or the persons who conducted the field work. This report is provided for informational and comparative purposes only and should not be relied upon for any other purpose. "Typical outdoor data" are based on the results of the analysis of samples delivered to and analyzed by Eurofins EMLab P&K and assumptions regarding the origins of those samples. Sampling techniques, contaminants infecting samples, unrepresentative samples and other similar or dissimilar factors may affect these results. In addition, Eurofins EMLab P&K may not have received and tested a representative number of samples for every region or time period. Eurofins EMLab P&K hereby disclaims any liability for any and all direct, indirect, punitive, incidental, special or consequential damages arising out of the use or interpretation of the data contained in, or any actions taken or omitted in reliance upon, this report.