

ANALYTICAL REPORT

Job Number: 420-112382-1

SDG Number: Washington Ville CSD - High School

Job Description: Orange-Ulster BOCES

For:

Orange-Ulster BOCES

53 Gibson Road

Goshen, NY 10924

Attention: Jack DeGraw



Meredith W Ruthven

Customer Service Manager

mruthven@envirotestlaboratories.com

11/30/2016

NYSDOH ELAP does not certify for all parameters. EnviroTest Laboratories does hold certification for all analytes where certification is offered by ELAP unless otherwise specified in the Certification Information section of this report. Pursuant to NELAP, this report may not be reproduced, except in full, without written approval of the laboratory. EnviroTest Laboratories Inc. certifies that the analytical results contained herein apply only to the samples tested as received by our laboratory. All questions regarding this report should be directed to the EnviroTest Customer Service Representative.

EnviroTest Laboratories, Inc. Certifications and Approvals: NYSDOH 10142, NJDEP NY015, CTDOEPH PH-0554

Job Narrative
420-J112382-1

Comments

Results are compared to NYSDOH drinking water standards other federal regulations may apply.

No additional comments.

Receipt

All samples were received in good condition within temperature requirements.

Metals

No analytical or quality issues were noted.

METHOD SUMMARY

Client: Orange-Ulster BOCES

Job Number: 420-112382-1

SDG Number: Washington Ville CSD - High School

Description	Lab Location	Method	Preparation Method
Matrix: Water			
ICPMS Metals by 200.8	EnvTest	EPA 200.8 Rev.5.4	
200 Series Drinking Water Prep Determination Step	EnvTest		EPA 200

Lab References:

EnvTest = EnviroTest

Method References:

EPA = US Environmental Protection Agency

METHOD / ANALYST SUMMARY

Client: Orange-Ulster BOCES

Job Number: 420-112382-1

SDG Number: Washington Ville CSD - High School

Method	Analyst	Analyst ID
EPA 200.8 Rev.5.4	Palentino, Gus J	GJP
EPA 200.8 Rev.5.4	Sirico, Derek	DS

SAMPLE SUMMARY

Client: Orange-Ulster BOCES

Job Number: 420-112382-1
SDG Number: Washington Ville CSD - High School

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-112382-1	Outside Faucet Receiving	Drinking Water	10/22/2016 0600	10/27/2016 1030
420-112382-2	Hose Bib next to Ice Machine (right)	Drinking Water	10/22/2016 0605	10/27/2016 1030
420-112382-3	Room 117 Sink	Drinking Water	10/22/2016 0608	10/27/2016 1030
420-112382-4	Room 116 Left Sink	Drinking Water	10/22/2016 0609	10/27/2016 1030
420-112382-5	Room 116 right Sink	Drinking Water	10/22/2016 0609	10/27/2016 1030
420-112382-6	Room 112 men's bathroom Sink	Drinking Water	10/22/2016 0611	10/27/2016 1030
420-112382-7	Room 112 Women's bathroom Sink	Drinking Water	10/22/2016 0611	10/27/2016 1030
420-112382-8	Room 109 Island Sink Front	Drinking Water	10/22/2016 0612	10/27/2016 1030
420-112382-9	Room 109 Island Sink Back	Drinking Water	10/22/2016 0612	10/27/2016 1030
420-112382-10	Room 109 Dark Room left sink w/ hose	Drinking Water	10/22/2016 0615	10/27/2016 1030
420-112382-11	Room 109 Dark Room right sink	Drinking Water	10/22/2016 0615	10/27/2016 1030
420-112382-12	Room 107 Island sink front	Drinking Water	10/22/2016 0617	10/27/2016 1030
420-112382-13	Room 107 Island sink back	Drinking Water	10/22/2016 0617	10/27/2016 1030
420-112382-14	Room 107 wall sink	Drinking Water	10/22/2016 0617	10/27/2016 1030
420-112382-15	104- Kitchen area Sink	Drinking Water	10/22/2016 0617	10/27/2016 1030
420-112382-16	104- Men's Bathroom sink	Drinking Water	10/22/2016 0619	10/27/2016 1030
420-112382-17	104- Women's Bathroom sink	Drinking Water	10/22/2016 0620	10/27/2016 1030
420-112382-18	Room 103 Front Island sink	Drinking Water	10/22/2016 0621	10/27/2016 1030
420-112382-19	Room 103 Back Island sink	Drinking Water	10/22/2016 0621	10/27/2016 1030
420-112382-20	Room 103 Wall Sink	Drinking Water	10/22/2016 0622	10/27/2016 1030
420-112382-21	Room 101 Bathroom sink	Drinking Water	10/22/2016 0624	10/27/2016 1030
420-112382-22	Room 101C1 Sink	Drinking Water	10/22/2016 0625	10/27/2016 1030
420-112382-23	Room 101C Sink	Drinking Water	10/22/2016 0625	10/27/2016 1030
420-112382-24	1st Floor Gold wing by 101 - water fountain	Drinking Water	10/22/2016 0626	10/27/2016 1030
420-112382-25	Room 152 Sink	Drinking Water	10/22/2016 0627	10/27/2016 1030
420-112382-26	Room 160 Sink	Drinking Water	10/22/2016 0629	10/27/2016 1030
420-112382-27	Room 162 Sink #1	Drinking Water	10/22/2016 0630	10/27/2016 1030
420-112382-28	Room 162 Sink #2	Drinking Water	10/22/2016 0630	10/27/2016 1030
420-112382-29	Room 162 Sink #3	Drinking Water	10/22/2016 0630	10/27/2016 1030
420-112382-30	Room 162 Sink #4	Drinking Water	10/22/2016 0630	10/27/2016 1030
420-112382-31	157-Girl's Locker room bathroom left	Drinking Water	10/22/2016 0632	10/27/2016 1030
420-112382-32	159A - P.E. office bathroom sink	Drinking Water	10/22/2016 0636	10/27/2016 1030
420-112382-33	Kitchen Serving line sink by 164	Drinking Water	10/22/2016 0639	10/27/2016 1030
420-112382-34	Kitchen Island sink	Drinking Water	10/22/2016 0640	10/27/2016 1030
420-112382-35	Kitchen Steam table sprayer	Drinking Water	10/22/2016 0641	10/27/2016 1030
420-112382-36	Kitchen 3-Bay left sink	Drinking Water	10/22/2016 0642	10/27/2016 1030

SAMPLE SUMMARY

Client: Orange-Ulster BOCES

Job Number: 420-112382-1
SDG Number: Washington Ville CSD - High School

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-112382-37	Kitchen 3-Bay Sink (sprayer)	Drinking Water	10/22/2016 0642	10/27/2016 1030
420-112382-38	Kitchen 3-Bay Right Sink	Drinking Water	10/22/2016 0642	10/27/2016 1030
420-112382-39	Kitchen hand washing sink	Drinking Water	10/22/2016 0643	10/27/2016 1030
420-112382-40	Kitchen Bathroom Sink	Drinking Water	10/22/2016 0643	10/27/2016 1030
420-112382-41	Kitchen serving line sink by 166	Drinking Water	10/22/2016 0644	10/27/2016 1030
420-112382-42	168 - Food Prep sink	Drinking Water	10/22/2016 0648	10/27/2016 1030
420-112382-43	168 - Hand wash sink	Drinking Water	10/22/2016 0648	10/27/2016 1030
420-112382-44	168 - Food Serving line Faucet	Drinking Water	10/22/2016 0649	10/27/2016 1030
420-112382-45	170D - Bathroom Sink	Drinking Water	10/22/2016 0651	10/27/2016 1030
420-112382-46	171 Sink	Drinking Water	10/22/2016 0651	10/27/2016 1030
420-112382-47	Hall drinking fountain by 180	Drinking Water	10/22/2016 0653	10/27/2016 1030
420-112382-48	Faculty Men's Bathroom by 180 (Right)	Drinking Water	10/22/2016 0655	10/27/2016 1030
420-112382-49	Faculty Men's Bathroom by 180 (left)	Drinking Water	10/22/2016 0655	10/27/2016 1030
420-112382-50	Women's faculty Bathroom by 180 (right)	Drinking Water	10/22/2016 0656	10/27/2016 1030
420-112382-51	Women's faculty Bathroom by 180 (Left)	Drinking Water	10/22/2016 0656	10/27/2016 1030
420-112382-52	Girl's bathroom by 182 sink #1 from left	Drinking Water	10/22/2016 0658	10/27/2016 1030
420-112382-53	Girl's bathroom by 182 sink #2	Drinking Water	10/22/2016 0658	10/27/2016 1030
420-112382-54	Girl's bathroom by 182 sink #3	Drinking Water	10/22/2016 0658	10/27/2016 1030
420-112382-55	Boy's bathroom by 182 sink #1	Drinking Water	10/22/2016 0700	10/27/2016 1030
420-112382-56	Boy's bathroom by 182 sink #2	Drinking Water	10/22/2016 0700	10/27/2016 1030
420-112382-57	Boy's bathroom by 182 sink #3	Drinking Water	10/22/2016 0700	10/27/2016 1030
420-112382-58	184 - Boys locker room bathroom sink #1 (left)	Drinking Water	10/22/2016 0706	10/27/2016 1030
420-112382-59	184 - Boys locker room bathroom sink #2 (right)	Drinking Water	10/22/2016 0706	10/27/2016 1030
420-112382-60	184 - Boy's Team Room right sink	Drinking Water	10/22/2016 0709	10/27/2016 1030
420-112382-61	184 - Boy's Team Room left sink	Drinking Water	10/22/2016 0709	10/27/2016 1030
420-112382-62	184A - P.E. office bathroom sink	Drinking Water	10/22/2016 0711	10/27/2016 1030
420-112382-63	Outside Spigot by 162	Drinking Water	10/22/2016 0712	10/27/2016 1030
420-112382-64	1st Floor Blue Wing Boy's gang bathroom #1	Drinking Water	10/22/2016 0717	10/27/2016 1030
420-112382-65	1st Floor Blue Wing Boy's gang bathroom #2	Drinking Water	10/22/2016 0717	10/27/2016 1030
420-112382-66	1st Floor Blue Wing Boy's gang bathroom #3	Drinking Water	10/22/2016 0717	10/27/2016 1030

SAMPLE SUMMARY

Client: Orange-Ulster BOCES

Job Number: 420-112382-1
SDG Number: Washington Ville CSD - High School

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-112382-67	1st Floor Blue Wing Boy's gang bathroom #4	Drinking Water	10/22/2016 0717	10/27/2016 1030
420-112382-68	1st Floor Blue Wing Boy's gang bathroom #5	Drinking Water	10/22/2016 0717	10/27/2016 1030
420-112382-69	1st Floor Blue Wing Faculty Bathroom on left	Drinking Water	10/22/2016 0712	10/27/2016 1030
420-112382-70	1st Floor Blue Wing Faculty Bathroom on right	Drinking Water	10/22/2016 0712	10/27/2016 1030
420-112382-71	1st Floor Blue Wing water fountain on left	Drinking Water	10/22/2016 0714	10/27/2016 1030
420-112382-72	1st Floor Blue Wing water fountain on right	Drinking Water	10/22/2016 0714	10/27/2016 1030
420-112382-73	1st Floor Blue Wing girl's bathroom #2	Drinking Water	10/22/2016 0716	10/27/2016 1030
420-112382-74	1st Floor Blue Wing girl's bathroom #3	Drinking Water	10/22/2016 0716	10/27/2016 1030
420-112382-75	1st Floor Blue Wing girl's bathroom #4	Drinking Water	10/22/2016 0716	10/27/2016 1030
420-112382-76	1st Floor Blue Wing girl's bathroom #5	Drinking Water	10/22/2016 0718	10/27/2016 1030
420-112382-77	Room 121 Slop Sink	Drinking Water	10/22/2016 0731	10/27/2016 1030
420-112382-78	Room 121 sink #1	Drinking Water	10/22/2016 0731	10/27/2016 1030
420-112382-79	Room 121 Sink #2	Drinking Water	10/22/2016 0732	10/27/2016 1030
420-112382-80	Room 121 Sink #3	Drinking Water	10/22/2016 0732	10/27/2016 1030
420-112382-81	Room 123 Sink	Drinking Water	10/22/2016 0732	10/27/2016 1030
420-112382-82	2nd Floor Gold wing girl's gang bathroom #1	Drinking Water	10/22/2016 0736	10/27/2016 1030
420-112382-83	2nd Floor Gold wing girl's gang bathroom #2	Drinking Water	10/22/2016 0737	10/27/2016 1030
420-112382-84	2nd Floor Gold wing girl's gang bathroom #3	Drinking Water	10/22/2016 0737	10/27/2016 1030
420-112382-85	2nd Floor water fountain by 216	Drinking Water	10/22/2016 0739	10/27/2016 1030
420-112382-86	2nd Floor gold wing boy's gang bathroom #1	Drinking Water	10/22/2016 0740	10/27/2016 1030
420-112382-87	2nd Floor gold wing boy's gang bathroom #2	Drinking Water	10/22/2016 0740	10/27/2016 1030
420-112382-88	2nd Floor gold wing boy's gang bathroom #3	Drinking Water	10/22/2016 0741	10/27/2016 1030
420-112382-89	Water fountain by 202	Drinking Water	10/22/2016 0742	10/27/2016 1030
420-112382-90	2nd Floor blue Wing Boy's gang bathroom #1	Drinking Water	10/22/2016 0747	10/27/2016 1030
420-112382-91	2nd Floor blue Wing Boy's gang bathroom #2	Drinking Water	10/22/2016 0747	10/27/2016 1030
420-112382-92	2nd Floor blue Wing Boy's gang bathroom #3	Drinking Water	10/22/2016 0748	10/27/2016 1030
420-112382-93	2nd Floor blue Wing Boy's gang bathroom #4	Drinking Water	10/22/2016 0748	10/27/2016 1030
420-112382-94	2nd Floor blue Wing Boy's gang bathroom #5	Drinking Water	10/22/2016 0749	10/27/2016 1030
420-112382-95	2nd Floor blue Wing Faculty bathroom on left	Drinking Water	10/22/2016 0752	10/27/2016 1030

SAMPLE SUMMARY

Client: Orange-Ulster BOCES

Job Number: 420-112382-1
SDG Number: Washington Ville CSD - High School

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-112382-96	2nd Floor blue Wing	Drinking Water	10/22/2016 0752	10/27/2016 1030
420-112382-97	Faculty bathroom on right	Drinking Water	10/22/2016 0753	10/27/2016 1030
420-112382-98	Water fountain by 234 on left	Drinking Water	10/22/2016 0754	10/27/2016 1030
420-112382-99	Water fountain by 234 on right	Drinking Water	10/22/2016 0755	10/27/2016 1030
420-112382-100	2nd Floor Blue Wing Girl's gang bathroom #1	Drinking Water	10/22/2016 0755	10/27/2016 1030
420-112382-101	2nd Floor Blue Wing Girl's gang bathroom #2	Drinking Water	10/22/2016 0756	10/27/2016 1030
420-112382-102	2nd Floor Blue Wing Girl's gang bathroom #3	Drinking Water	10/22/2016 0756	10/27/2016 1030
420-112382-103	2nd Floor Blue Wing Girl's gang bathroom #4	Drinking Water	10/22/2016 0756	10/27/2016 1030
420-112382-104	2nd Floor Blue Wing Girl's gang bathroom #5	Drinking Water	10/22/2016 0756	10/27/2016 1030
420-112382-105	Pool 243 locker room water fountain	Drinking Water	10/22/2016 0800	10/27/2016 1030
420-112382-106	243 - Pool Locker room bathroom (left)	Drinking Water	10/22/2016 0801	10/27/2016 1030
420-112382-107	243 - Pool Locker room bathroom (right)	Drinking Water	10/22/2016 0801	10/27/2016 1030
420-112382-108	247 - Boy's pool bathroom locker room (left)	Drinking Water	10/22/2016 0803	10/27/2016 1030
420-112382-109	247 - Boy's pool bathroom locker room (right)	Drinking Water	10/22/2016 0804	10/27/2016 1030
420-112382-110	247 - Boy's pool locker room water fountain	Drinking Water	10/22/2016 0805	10/27/2016 1030
420-112382-111	Girl's pool coaches office bathroom sink	Drinking Water	10/22/2016 0809	10/27/2016 1030
420-112382-112	Boy's pool coaches bathroom sink	Drinking Water	10/22/2016 0810	10/27/2016 1030
420-112382-113	3rd Floor Blue Wing Boy's gang bathroom sink #1	Drinking Water	10/22/2016 0815	10/27/2016 1030
420-112382-114	3rd Floor Blue Wing Boy's gang bathroom sink #2	Drinking Water	10/22/2016 0815	10/27/2016 1030
420-112382-115	3rd Floor Blue Wing Boy's gang bathroom sink #3	Drinking Water	10/22/2016 0815	10/27/2016 1030
420-112382-116	3rd Floor Blue Wing Boy's gang bathroom sink #4	Drinking Water	10/22/2016 0816	10/27/2016 1030
420-112382-117	3rd Floor Blue Wing Boy's gang bathroom sink #5	Drinking Water	10/22/2016 0817	10/27/2016 1030
420-112382-118	3rd Floor Blue Wing Faculty bathroom on left	Drinking Water	10/22/2016 0818	10/27/2016 1030
420-112382-119	3rd Floor Blue Wing Faculty bathroom on right	Drinking Water	10/22/2016 0819	10/27/2016 1030
420-112382-120	3rd Floor water fountain by 332 on left	Drinking Water	10/22/2016 0820	10/27/2016 1030
420-112382-121	3rd Floor water fountain by 332 on right	Drinking Water	10/22/2016 0820	10/27/2016 1030
420-112382-122	3rd Floor Blue Wing girl's gang bathroom #1	Drinking Water	10/22/2016 0821	10/27/2016 1030
420-112382-123	3rd Floor Blue Wing girl's gang bathroom #2	Drinking Water	10/22/2016 0821	10/27/2016 1030

SAMPLE SUMMARY

Client: Orange-Ulster BOCES

Job Number: 420-112382-1
SDG Number: Washington Ville CSD - High School

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-112382-123	3rd Floor Blue Wing girl's gang bathroom #3	Drinking Water	10/22/2016 0822	10/27/2016 1030
420-112382-124	3rd Floor Blue Wing girl's gang bathroom #4	Drinking Water	10/22/2016 0822	10/27/2016 1030
420-112382-125	3rd Floor Blue Wing girl's gang bathroom #5	Drinking Water	10/22/2016 0823	10/27/2016 1030
420-112382-126	343 - Boy's bathroom (right)	Drinking Water	10/22/2016 0827	10/27/2016 1030
420-112382-127	343 - Boy's bathroom (left)	Drinking Water	10/22/2016 0827	10/27/2016 1030
420-112382-128	343 - water fountain	Drinking Water	10/22/2016 0828	10/27/2016 1030
420-112382-129	343 - girl's bathroom (right)	Drinking Water	10/22/2016 0828	10/27/2016 1030
420-112382-130	343 - girl's bathroom (left)	Drinking Water	10/22/2016 0828	10/27/2016 1030
420-112382-131	Gym drinking fountain by 159	Drinking Water	10/22/2016 0835	10/27/2016 1030
420-112382-132	Trainer's office sink	Drinking Water	10/22/2016 0836	10/27/2016 1030
420-112382-133	gym drinking fountain by boy's locker room	Drinking Water	10/22/2016 0803	10/27/2016 1030
420-112382-134	Ice machine Receiving area	Drinking Water	10/22/2016 0601	10/27/2016 1030
420-112382-135	Ice machine Trainer's room	Drinking Water	10/22/2016 0813	10/27/2016 1030
420-112382-136	Room 328 Sink #1	Drinking Water	10/22/2016 0856	10/27/2016 1030
420-112382-137	Room 328 Sink #2	Drinking Water	10/22/2016 0856	10/27/2016 1030
420-112382-138	Room 328 Sink #3	Drinking Water	10/22/2016 0857	10/27/2016 1030
420-112382-139	Room 328 Sink #4	Drinking Water	10/22/2016 0857	10/27/2016 1030
420-112382-140	Room 328 Sink #5	Drinking Water	10/22/2016 0858	10/27/2016 1030
420-112382-141	Room 328 Sink #6	Drinking Water	10/22/2016 0858	10/27/2016 1030
420-112382-142	Room 328 Sink #7	Drinking Water	10/22/2016 0859	10/27/2016 1030
420-112382-143	Room 328 Sink #8	Drinking Water	10/22/2016 0859	10/27/2016 1030
420-112382-144	Room 328 Sink #9	Drinking Water	10/22/2016 0900	10/27/2016 1030
420-112382-145	Room 328 Sink #10	Drinking Water	10/22/2016 0900	10/27/2016 1030
420-112382-146	Room 328 Sink #11	Drinking Water	10/22/2016 0900	10/27/2016 1030
420-112382-147	Room 328 Sink #12	Drinking Water	10/22/2016 0901	10/27/2016 1030
420-112382-148	Room 334 Sink #1	Drinking Water	10/22/2016 0905	10/27/2016 1030
420-112382-149	Room 334 Sink #2	Drinking Water	10/22/2016 0906	10/27/2016 1030
420-112382-150	Room 334 Sink #3	Drinking Water	10/22/2016 0905	10/27/2016 1030
420-112382-151	Room 334 Sink #4	Drinking Water	10/22/2016 0906	10/27/2016 1030
420-112382-152	Room 334 Sink #5	Drinking Water	10/22/2016 0906	10/27/2016 1030
420-112382-153	Room 334 Sink #6	Drinking Water	10/22/2016 0906	10/27/2016 1030
420-112382-154	Room 334 Sink #7	Drinking Water	10/22/2016 0907	10/27/2016 1030
420-112382-155	Room 334 Sink #8	Drinking Water	10/22/2016 0907	10/27/2016 1030
420-112382-156	Room 334 Sink #9	Drinking Water	10/22/2016 0907	10/27/2016 1030
420-112382-157	Room 334 Sink #10	Drinking Water	10/22/2016 0908	10/27/2016 1030
420-112382-158	Room 334 Sink #11	Drinking Water	10/22/2016 0908	10/27/2016 1030
420-112382-159	Room 334 Sink #12	Drinking Water	10/22/2016 0909	10/27/2016 1030
420-112382-160	Room 334 Sink #13	Drinking Water	10/22/2016 0909	10/27/2016 1030
420-112382-161	Room 341 Sink #1	Drinking Water	10/22/2016 0912	10/27/2016 1030
420-112382-162	Room 341 Sink #2	Drinking Water	10/22/2016 0913	10/27/2016 1030

SAMPLE SUMMARY

Client: Orange-Ulster BOCES

Job Number: 420-112382-1
SDG Number: Washington Ville CSD - High School

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-112382-163	3rd Floor Gold Wing Girl's gang bathroom sink #1	Drinking Water	10/22/2016 0755	10/27/2016 1030
420-112382-164	3rd Floor Gold Wing Girl's gang bathroom sink #2	Drinking Water	10/22/2016 0755	10/27/2016 1030
420-112382-165	3rd Floor Gold Wing Girl's gang bathroom sink #3	Drinking Water	10/22/2016 0756	10/27/2016 1030
420-112382-166	Water Fountain by 311	Drinking Water	10/22/2016 0757	10/27/2016 1030
420-112382-167	3rd floor Gold wing Boy's gang bathroom sink #1	Drinking Water	10/22/2016 0757	10/27/2016 1030
420-112382-168	3rd floor Gold wing Boy's gang bathroom sink #2	Drinking Water	10/22/2016 0757	10/27/2016 1030
420-112382-169	3rd floor Gold wing Boy's gang bathroom sink #3	Drinking Water	10/22/2016 0757	10/27/2016 1030
420-112382-170	Room 311 Island sink	Drinking Water	10/22/2016 0801	10/27/2016 1030
420-112382-171	Room 311 back wall Sink #1	Drinking Water	10/22/2016 0801	10/27/2016 1030
420-112382-172	Room 301 back wall Sink #2	Drinking Water	10/22/2016 0801	10/27/2016 1030
420-112382-173	Room 312 Island sink	Drinking Water	10/22/2016 0804	10/27/2016 1030
420-112382-174	Room 312 Left sink	Drinking Water	10/22/2016 0804	10/27/2016 1030
420-112382-175	Room 309 sink	Drinking Water	10/22/2016 0806	10/27/2016 1030
420-112382-176	Room 310 Front Left Sink #1	Drinking Water	10/22/2016 0807	10/27/2016 1030
420-112382-177	Room 310 Front Left Sink #2	Drinking Water	10/22/2016 0807	10/27/2016 1030
420-112382-178	Room 310 Front Right Sink #1	Drinking Water	10/22/2016 0807	10/27/2016 1030
420-112382-179	Room 310 Front Right Sink #2	Drinking Water	10/22/2016 0807	10/27/2016 1030
420-112382-180	Room 310 Back Center Sink #1	Drinking Water	10/22/2016 0809	10/27/2016 1030
420-112382-181	Room 310 Back Center Sink #2	Drinking Water	10/22/2016 0809	10/27/2016 1030
420-112382-182	Room 310 Back right Sink #1	Drinking Water	10/22/2016 0809	10/27/2016 1030
420-112382-183	Room 310 Back right Sink #2	Drinking Water	10/22/2016 0811	10/27/2016 1030
420-112382-184	Room 310 Back Left Sink #1	Drinking Water	10/22/2016 0811	10/27/2016 1030
420-112382-185	Room 310 Back Left Sink #2	Drinking Water	10/22/2016 0811	10/27/2016 1030
420-112382-186	Room 310 Right wall sink	Drinking Water	10/22/2016 0813	10/27/2016 1030
420-112382-187	Room 310 Back wall right sink	Drinking Water	10/22/2016 0813	10/27/2016 1030
420-112382-188	Room 310 Back wall left sink	Drinking Water	10/22/2016 0813	10/27/2016 1030
420-112382-189	Room 309 island sink	Drinking Water	10/22/2016 0815	10/27/2016 1030
420-112382-190	Room 309 Left 1 Front Sink	Drinking Water	10/22/2016 0815	10/27/2016 1030
420-112382-191	Room 309 Left 2 Front Sink	Drinking Water	10/22/2016 0815	10/27/2016 1030
420-112382-192	Room 309 Left 1 Back Sink	Drinking Water	10/22/2016 0815	10/27/2016 1030
420-112382-193	Room 309 Left 2 Back Sink	Drinking Water	10/22/2016 0815	10/27/2016 1030
420-112382-194	Room 309 Left 3 Front Sink	Drinking Water	10/22/2016 0815	10/27/2016 1030

SAMPLE SUMMARY

Client: Orange-Ulster BOCES

Job Number: 420-112382-1
SDG Number: Washington Ville CSD - High School

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-112382-195	Room 309 Left 3 Back Sink	Drinking Water	10/22/2016 0815	10/27/2016 1030
420-112382-196	Room 309 Right 4 Front Sink	Drinking Water	10/22/2016 0819	10/27/2016 1030
420-112382-197	Room 309 Right 4 Back Sink	Drinking Water	10/22/2016 0819	10/27/2016 1030
420-112382-198	Room 309 Right 5 Front Sink	Drinking Water	10/22/2016 0822	10/27/2016 1030
420-112382-199	Room 309 Right 5 Back Sink	Drinking Water	10/22/2016 0822	10/27/2016 1030
420-112382-200	Room 309 Right 6 Front Sink	Drinking Water	10/22/2016 0822	10/27/2016 1030
420-112382-201	Room 309 Right 6 Back Sink	Drinking Water	10/22/2016 0822	10/27/2016 1030
420-112382-202	Room 309 sink by door	Drinking Water	10/22/2016 0822	10/27/2016 1030
420-112382-203	Room 307 Front wall sink	Drinking Water	10/22/2016 0825	10/27/2016 1030
420-112382-204	Room 307 sink #1	Drinking Water	10/22/2016 0826	10/27/2016 1030
420-112382-205	Room 307 sink #2	Drinking Water	10/22/2016 0826	10/27/2016 1030
420-112382-206	Room 307 sink #3	Drinking Water	10/22/2016 0826	10/27/2016 1030
420-112382-207	Room 307 sink #4	Drinking Water	10/22/2016 0826	10/27/2016 1030
420-112382-208	Room 307 sink #5	Drinking Water	10/22/2016 0829	10/27/2016 1030
420-112382-209	Room 307 sink #6	Drinking Water	10/22/2016 0829	10/27/2016 1030
420-112382-210	Room 307 sink #7	Drinking Water	10/22/2016 0829	10/27/2016 1030
420-112382-211	Room 307 sink #8	Drinking Water	10/22/2016 0829	10/27/2016 1030
420-112382-212	Room 307 Back wall sink	Drinking Water	10/22/2016 0829	10/27/2016 1030
420-112382-213	Room 306 Island sink	Drinking Water	10/22/2016 0833	10/27/2016 1030
420-112382-214	Room 306 wall sink	Drinking Water	10/22/2016 0833	10/27/2016 1030
420-112382-215	Room 305 sink	Drinking Water	10/22/2016 0834	10/27/2016 1030
420-112382-216	Room 304 Lab Hood sink	Drinking Water	10/22/2016 0836	10/27/2016 1030
420-112382-217	Room 304 Left 1 Front sink	Drinking Water	10/22/2016 0836	10/27/2016 1030
420-112382-218	Room 304 Left 1 Back sink	Drinking Water	10/22/2016 0836	10/27/2016 1030
420-112382-219	Room 304 Left 2 Front sink	Drinking Water	10/22/2016 0836	10/27/2016 1030
420-112382-220	Room 304 Left 2 Back sink	Drinking Water	10/22/2016 0836	10/27/2016 1030
420-112382-221	Room 304 Left 3 Front sink	Drinking Water	10/22/2016 0836	10/27/2016 1030
420-112382-222	Room 304 Left 3 back sink	Drinking Water	10/22/2016 0836	10/27/2016 1030
420-112382-223	Room 304 Right 4 Front sink	Drinking Water	10/22/2016 0839	10/27/2016 1030
420-112382-224	Room 304 Right 4 Back Sink	Drinking Water	10/22/2016 0839	10/27/2016 1030
420-112382-225	Room 304 Right 5 Front sink	Drinking Water	10/22/2016 0839	10/27/2016 1030
420-112382-226	Room 304 Right 5 back sink	Drinking Water	10/22/2016 0839	10/27/2016 1030
420-112382-227	Room 304 Right 6 Front sink	Drinking Water	10/22/2016 0839	10/27/2016 1030
420-112382-228	Room 304 Right 6 Back sink	Drinking Water	10/22/2016 0839	10/27/2016 1030
420-112382-229	Room 304 sink by door	Drinking Water	10/22/2016 0841	10/27/2016 1030
420-112382-230	Room 303 Island Sink	Drinking Water	10/22/2016 0844	10/27/2016 1030

SAMPLE SUMMARY

Client: Orange-Ulster BOCES

Job Number: 420-112382-1
SDG Number: Washington Ville CSD - High School

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-112382-231	Room 303 Front podium front sink	Drinking Water	10/22/2016 0844	10/27/2016 1030
420-112382-232	Room 303 Front podium Back sink	Drinking Water	10/22/2016 0844	10/27/2016 1030
420-112382-233	Room 303 Left back podium front sink	Drinking Water	10/22/2016 0844	10/27/2016 1030
420-112382-234	Room 303 Left back podium Back sink	Drinking Water	10/22/2016 0844	10/27/2016 1030
420-112382-235	Room 303 Back Right podium Front Sink	Drinking Water	10/22/2016 0853	10/27/2016 1030
420-112382-236	Room 303 Back Right podium Back Sink	Drinking Water	10/22/2016 0853	10/27/2016 1030
420-112382-237	Room 303 Lab hood sink	Drinking Water	10/22/2016 0853	10/27/2016 1030
420-112382-238	Room 302 Island sink	Drinking Water	10/22/2016 0856	10/27/2016 1030
420-112382-239	Room 302 Left Podium front sink	Drinking Water	10/22/2016 0856	10/27/2016 1030
420-112382-240	Room 302 Left Podium back sink	Drinking Water	10/22/2016 0856	10/27/2016 1030
420-112382-241	Room 302 back left podium front sink	Drinking Water	10/22/2016 0856	10/27/2016 1030
420-112382-242	Room 302 Left back podium back sink	Drinking Water	10/22/2016 0856	10/27/2016 1030
420-112382-243	Room 302 Back Right podium front sink	Drinking Water	10/22/2016 0856	10/27/2016 1030
420-112382-244	Room 302 Back Right podium back sink	Drinking Water	10/22/2016 0856	10/27/2016 1030
420-112382-245	Room 302 Left wall sink	Drinking Water	10/22/2016 0856	10/27/2016 1030
420-112382-246	water fountain by 302	Drinking Water	10/22/2016 0859	10/27/2016 1030
420-112382-247	Room 330 sink #1	Drinking Water	10/22/2016 0903	10/27/2016 1030
420-112382-248	Room 330 sink #2	Drinking Water	10/22/2016 0903	10/27/2016 1030
420-112382-249	Room 330 sink #3	Drinking Water	10/22/2016 0903	10/27/2016 1030
420-112382-250	Room 330 sink #4	Drinking Water	10/22/2016 0903	10/27/2016 1030
420-112382-251	Room 330 sink #5	Drinking Water	10/22/2016 0903	10/27/2016 1030
420-112382-252	Room 330 sink #6	Drinking Water	10/22/2016 0903	10/27/2016 1030
420-112382-253	Room 330 sink #7	Drinking Water	10/22/2016 0905	10/27/2016 1030
420-112382-254	Room 330 sink #8	Drinking Water	10/22/2016 0905	10/27/2016 1030
420-112382-255	Room 330 sink #9	Drinking Water	10/22/2016 0905	10/27/2016 1030
420-112382-256	Room 330 sink #10	Drinking Water	10/22/2016 0905	10/27/2016 1030
420-112382-257	Room 330 sink #11	Drinking Water	10/22/2016 0905	10/27/2016 1030
420-112382-258	Room 330 sink #12	Drinking Water	10/22/2016 0905	10/27/2016 1030
420-112382-259	Room 330 Sink #13	Drinking Water	10/22/2016 0905	10/27/2016 1030
420-112382-260	Room 336 Sink #1	Drinking Water	10/22/2016 0911	10/27/2016 1030
420-112382-261	Room 336 Sink #2	Drinking Water	10/22/2016 0911	10/27/2016 1030
420-112382-262	Room 336 Sink #3	Drinking Water	10/22/2016 0911	10/27/2016 1030
420-112382-263	Room 336 Sink #4	Drinking Water	10/22/2016 0911	10/27/2016 1030
420-112382-264	Room 336 Sink #5	Drinking Water	10/22/2016 0911	10/27/2016 1030
420-112382-265	Room 336 Sink #6	Drinking Water	10/22/2016 0911	10/27/2016 1030
420-112382-266	Room 336 Sink #7	Drinking Water	10/22/2016 0913	10/27/2016 1030
420-112382-267	Room 336 Sink #9	Drinking Water	10/22/2016 0913	10/27/2016 1030

SAMPLE SUMMARY

Client: Orange-Ulster BOCES

Job Number: 420-112382-1
SDG Number: Washington Ville CSD - High School

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-112382-268	Room 336 Sink #10	Drinking Water	10/22/2016 0913	10/27/2016 1030
420-112382-269	Room 336 Sink #11	Drinking Water	10/22/2016 0913	10/27/2016 1030
420-112382-270	Room 336 Sink #12	Drinking Water	10/22/2016 0913	10/27/2016 1030
420-112382-271	Room 336 Sink #13	Drinking Water	10/22/2016 0913	10/27/2016 1030

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Outside Faucet Receiving
Lab Sample ID: 420-112382-1

Date Sampled: 10/22/2016 0600
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1024	
Prep Method: 200			Date Prepared:	11/16/2016 1715	
Pb	15.5 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Hose Bib next to Ice Machine (right)
Lab Sample ID: 420-112382-2

Date Sampled: 10/22/2016 0605
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016	1025	
Prep Method: 200			Date Prepared:	11/16/2016	1715	
Pb	79.8	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 117 Sink
Lab Sample ID: 420-112382-3

Date Sampled: 10/22/2016 0608
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	11/17/2016 1025	
Prep Method: 200				Date Prepared:	11/16/2016 1715	
Pb	15.0	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 116 Left Sink
Lab Sample ID: 420-112382-4

Date Sampled: 10/22/2016 0609
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1026	
Prep Method: 200			Date Prepared:	11/16/2016 1715	
Pb	6.23	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 116 right Sink
Lab Sample ID: 420-112382-5

Date Sampled: 10/22/2016 0609
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1027	
Prep Method: 200			Date Prepared:	11/16/2016 1715	
Pb	5.85	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 112 men's bathroom Sink
Lab Sample ID: 420-112382-6

Date Sampled: 10/22/2016 0611
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1028	
Prep Method: 200			Date Prepared:	11/16/2016 1715	
Pb	2.58	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 112 Women's bathroom Sink
Lab Sample ID: 420-112382-7

Date Sampled: 10/22/2016 0611
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1028	
Prep Method: 200			Date Prepared:	11/16/2016 1715	
Pb	3.34	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 109 Island Sink Front
Lab Sample ID: 420-112382-8

Date Sampled: 10/22/2016 0612
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1029	
Prep Method: 200			Date Prepared:	11/16/2016 1715	
Pb	1.00	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 109 Island Sink Back
Lab Sample ID: 420-112382-9

Date Sampled: 10/22/2016 0612
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1032	
Prep Method: 200			Date Prepared:	11/16/2016 1745	
Pb	6.09	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 109 Dark Room left sink w/ hose
Lab Sample ID: 420-112382-10

Date Sampled: 10/22/2016 0615
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	11/17/2016 1035	
Prep Method: 200				Date Prepared:	11/16/2016 1745	
Pb	23.3	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 109 Dark Room right sink
Lab Sample ID: 420-112382-11

Date Sampled: 10/22/2016 0615
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1035	
Prep Method: 200			Date Prepared:	11/16/2016 1745	
Pb	12.2	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 107 Island sink front
Lab Sample ID: 420-112382-12

Date Sampled: 10/22/2016 0617
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1036	
Prep Method: 200			Date Prepared:	11/16/2016 1745	
Pb	7.06	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 107 Island sink back
Lab Sample ID: 420-112382-13

Date Sampled: 10/22/2016 0617
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1037	
Prep Method: 200			Date Prepared:	11/16/2016 1745	
Pb	7.20	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 107 wall sink
Lab Sample ID: 420-112382-14

Date Sampled: 10/22/2016 0617
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 0927	
Prep Method: 200			Date Prepared:	11/16/2016 1745	
Pb	7.02	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: 104- Kitchen area Sink
Lab Sample ID: 420-112382-15

Date Sampled: 10/22/2016 0617
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 0927	
Prep Method: 200			Date Prepared:	11/16/2016 1745	
Pb	1.86	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: 104- Men's Bathroom sink
Lab Sample ID: 420-112382-16

Date Sampled: 10/22/2016 0619
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 0928	
Prep Method: 200			Date Prepared:	11/16/2016 1745	
Pb	8.12	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: 104- Women's Bathroom sink
Lab Sample ID: 420-112382-17

Date Sampled: 10/22/2016 0620
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 0929	
Prep Method: 200			Date Prepared:	11/16/2016 1745	
Pb	6.54	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 103 Front Island sink
Lab Sample ID: 420-112382-18

Date Sampled: 10/22/2016 0621
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 0930	
Prep Method: 200			Date Prepared:	11/16/2016 1745	
Pb	6.52	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 103 Back Island sink
Lab Sample ID: 420-112382-19

Date Sampled: 10/22/2016 0621
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 0930	
Prep Method: 200			Date Prepared:	11/16/2016 1745	
Pb	10.7	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 103 Wall Sink
Lab Sample ID: 420-112382-20

Date Sampled: 10/22/2016 0622
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 0931	
Prep Method: 200			Date Prepared:	11/16/2016 1745	
Pb	3.10	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 101 Bathroom sink
Lab Sample ID: 420-112382-21

Date Sampled: 10/22/2016 0624
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 0932	
Prep Method: 200			Date Prepared:	11/16/2016 1745	
Pb	4.62	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 101C1 Sink
Lab Sample ID: 420-112382-22

Date Sampled: 10/22/2016 0625
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 0933	
Prep Method: 200			Date Prepared:	11/16/2016 1745	
Pb	2.36	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 101C Sink
Lab Sample ID: 420-112382-23

Date Sampled: 10/22/2016 0625
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 0934	
Prep Method: 200			Date Prepared:	11/16/2016 1745	
Pb	7.83	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: 1st Floor Gold wing by 101 - water fountain
Lab Sample ID: 420-112382-24

Date Sampled: 10/22/2016 0626
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 0936	
Prep Method: 200			Date Prepared:	11/16/2016 1745	
Pb	4.67	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 152 Sink
Lab Sample ID: 420-112382-25

Date Sampled: 10/22/2016 0627
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 0937	
Prep Method: 200			Date Prepared:	11/16/2016 1745	
Pb	8.97	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 160 Sink
Lab Sample ID: 420-112382-26

Date Sampled: 10/22/2016 0629
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016	0937	
Prep Method: 200			Date Prepared:	11/16/2016	1745	
Pb	17.0	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 162 Sink #1
Lab Sample ID: 420-112382-27

Date Sampled: 10/22/2016 0630
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 0938	
Prep Method: 200			Date Prepared:	11/16/2016 1745	
Pb	10.1	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 162 Sink #2
Lab Sample ID: 420-112382-28

Date Sampled: 10/22/2016 0630
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016	0939	
Prep Method: 200			Date Prepared:	11/16/2016	1745	
Pb	21.8	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 162 Sink #3
Lab Sample ID: 420-112382-29

Date Sampled: 10/22/2016 0630
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016	0940	
Prep Method: 200			Date Prepared:	11/16/2016	1830	
Pb	20.1	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 162 Sink #4
Lab Sample ID: 420-112382-30

Date Sampled: 10/22/2016 0630
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 0943	
Prep Method: 200			Date Prepared:	11/16/2016 1830	
Pb	7.64	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: 157-Girl's Locker room bathroom left
Lab Sample ID: 420-112382-31

Date Sampled: 10/22/2016 0632
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 0945	
Prep Method: 200			Date Prepared:	11/16/2016 1830	
Pb	3.78	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: 159A - P.E. office bathroom sink
Lab Sample ID: 420-112382-32

Date Sampled: 10/22/2016 0636
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 0946	
Prep Method: 200			Date Prepared:	11/16/2016 1830	
Pb	7.12	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Kitchen Serving line sink by 164
Lab Sample ID: 420-112382-33

Date Sampled: 10/22/2016 0639
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 0947	
Prep Method: 200			Date Prepared:	11/16/2016 1830	
Pb	6.84	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Kitchen Island sink
Lab Sample ID: 420-112382-34

Date Sampled: 10/22/2016 0640
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 0947	
Prep Method: 200			Date Prepared:	11/16/2016 1830	
Pb	4.33	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Kitchen Steam table sprayer
Lab Sample ID: 420-112382-35

Date Sampled: 10/22/2016 0641
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 0948	
Prep Method: 200			Date Prepared:	11/16/2016 1830	
Pb	35.2 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Kitchen 3-Bay left sink
Lab Sample ID: 420-112382-36

Date Sampled: 10/22/2016 0642
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 0949	
Prep Method: 200			Date Prepared:	11/16/2016 1830	
Pb	3.78	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Kitchen 3-Bay Sink (sprayer)
Lab Sample ID: 420-112382-37

Date Sampled: 10/22/2016 0642
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 0950	
Prep Method: 200			Date Prepared:	11/16/2016 1830	
Pb	2.61	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Kitchen 3-Bay Right Sink
Lab Sample ID: 420-112382-38

Date Sampled: 10/22/2016 0642
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4 Prep Method: 200 Pb			Date Analyzed:	11/17/2016	0951	
			Date Prepared:	11/16/2016	1830	
	1.00	U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Kitchen hand washing sink
Lab Sample ID: 420-112382-39

Date Sampled: 10/22/2016 0643
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 0951	
Prep Method: 200			Date Prepared:	11/16/2016 1830	
Pb	11.8	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Kitchen Bathroom Sink
Lab Sample ID: 420-112382-40

Date Sampled: 10/22/2016 0643
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 0952	
Prep Method: 200			Date Prepared:	11/16/2016 1830	
Pb	3.08	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Kitchen serving line sink by 166
Lab Sample ID: 420-112382-41

Date Sampled: 10/22/2016 0644
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 0954	
Prep Method: 200			Date Prepared:	11/16/2016 1830	
Pb	7.49	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: 168 - Food Prep sink
Lab Sample ID: 420-112382-42

Date Sampled: 10/22/2016 0648
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:	11/17/2016 0955		
Prep Method: 200		Date Prepared:	11/16/2016 1830		
Pb	9.93	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: 168 - Hand wash sink
Lab Sample ID: 420-112382-43

Date Sampled: 10/22/2016 0648
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016	0956	
Prep Method: 200			Date Prepared:	11/16/2016	1830	
Pb	44.9	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: 168 - Food Serving line Faucet
Lab Sample ID: 420-112382-44

Date Sampled: 10/22/2016 0649
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 0957	
Prep Method: 200			Date Prepared:	11/16/2016 1830	
Pb	12.2	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: 170D - Bathroom Sink
Lab Sample ID: 420-112382-45

Date Sampled: 10/22/2016 0651
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 0958	
Prep Method: 200			Date Prepared:	11/16/2016 1830	
Pb	7.90	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: 171 Sink
Lab Sample ID: 420-112382-46

Date Sampled: 10/22/2016 0651
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 0958	
Prep Method: 200			Date Prepared:	11/16/2016 1830	
Pb	3.28	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Hall drinking fountain by 180
Lab Sample ID: 420-112382-47

Date Sampled: 10/22/2016 0653
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	11/17/2016 0959	
Prep Method: 200				Date Prepared:	11/16/2016 1830	
Pb	1.00	U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Faculty Men's Bathroom by 180 (Right)
Lab Sample ID: 420-112382-48

Date Sampled: 10/22/2016 0655
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	11/17/2016 1000	
Prep Method: 200				Date Prepared:	11/16/2016 1830	
Pb	46.6	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Faculty Men's Bathroom by 180 (left)
Lab Sample ID: 420-112382-49

Date Sampled: 10/22/2016 0655
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1206	
Prep Method: 200			Date Prepared:	11/17/2016 0927	
Pb	6.68	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Women's faculty Bathroom by 180 (right)
Lab Sample ID: 420-112382-50

Date Sampled: 10/22/2016 0656
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	11/17/2016 1207	
Prep Method: 200				Date Prepared:	11/17/2016 0927	
Pb	60.6	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Women's faculty Bathroom by 180 (Left)
Lab Sample ID: 420-112382-51

Date Sampled: 10/22/2016 0656
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1208	
Prep Method: 200			Date Prepared:	11/17/2016 0927	
Pb	13.1	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Girl's bathroom by 182 sink #1 from left
Lab Sample ID: 420-112382-52

Date Sampled: 10/22/2016 0658
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1209	
Prep Method: 200			Date Prepared:	11/17/2016 0927	
Pb	4.64	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Girl's bathroom by 182 sink #2
Lab Sample ID: 420-112382-53

Date Sampled: 10/22/2016 0658
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1210	
Prep Method: 200			Date Prepared:	11/17/2016 0927	
Pb	2.92	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Girl's bathroom by 182 sink #3
Lab Sample ID: 420-112382-54

Date Sampled: 10/22/2016 0658
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1210	
Prep Method: 200			Date Prepared:	11/17/2016 0927	
Pb	3.37	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Boy's bathroom by 182 sink #1
Lab Sample ID: 420-112382-55

Date Sampled: 10/22/2016 0700
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1211	
Prep Method: 200			Date Prepared:	11/17/2016 0927	
Pb	3.41	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Boy's bathroom by 182 sink #2
Lab Sample ID: 420-112382-56

Date Sampled: 10/22/2016 0700
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1213	
Prep Method: 200			Date Prepared:	11/17/2016 0927	
Pb	5.79	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Boy's bathroom by 182 sink #3
Lab Sample ID: 420-112382-57

Date Sampled: 10/22/2016 0700
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1214	
Prep Method: 200			Date Prepared:	11/17/2016 0927	
Pb	3.86	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: 184 - Boys locker room bathroom sink #1 (left)
Lab Sample ID: 420-112382-58

Date Sampled: 10/22/2016 0706
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1215	
Prep Method: 200			Date Prepared:	11/17/2016 0927	
Pb	3.06	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: 184 - Boys locker room bathroom sink #2 (right)
Lab Sample ID: 420-112382-59

Date Sampled: 10/22/2016 0706
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1216	
Prep Method: 200			Date Prepared:	11/17/2016 0927	
Pb	2.49	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: 184 - Boy's Team Room right sink
Lab Sample ID: 420-112382-60

Date Sampled: 10/22/2016 0709
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1217	
Prep Method: 200			Date Prepared:	11/17/2016 0927	
Pb	2.93	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: 184 - Boy's Team Room left sink
Lab Sample ID: 420-112382-61

Date Sampled: 10/22/2016 0709
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1217	
Prep Method: 200			Date Prepared:	11/17/2016 0927	
Pb	17.0 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: 184A - P.E. office bathroom sink
Lab Sample ID: 420-112382-62

Date Sampled: 10/22/2016 0711
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1218	
Prep Method: 200			Date Prepared:	11/17/2016 0927	
Pb	7.38	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Outside Spigot by 162
Lab Sample ID: 420-112382-63

Date Sampled: 10/22/2016 0712
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1219	
Prep Method: 200			Date Prepared:	11/17/2016 0927	
Pb	5.41	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: 1st Floor Blue Wing Boy's gang bathroom #1
Lab Sample ID: 420-112382-64

Date Sampled: 10/22/2016 0717
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1220	
Prep Method: 200			Date Prepared:	11/17/2016 0927	
Pb	5.24	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: 1st Floor Blue Wing Boy's gang bathroom #2
Lab Sample ID: 420-112382-65

Date Sampled: 10/22/2016 0717
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1220	
Prep Method: 200			Date Prepared:	11/17/2016 0927	
Pb	12.2	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: 1st Floor Blue Wing Boy's gang bathroom #3
Lab Sample ID: 420-112382-66

Date Sampled: 10/22/2016 0717
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1223	
Prep Method: 200			Date Prepared:	11/17/2016 0927	
Pb	10.4	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: 1st Floor Blue Wing Boy's gang bathroom #4
Lab Sample ID: 420-112382-67

Date Sampled: 10/22/2016 0717
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1223	
Prep Method: 200			Date Prepared:	11/17/2016 0927	
Pb	2.71	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: 1st Floor Blue Wing Boy's gang bathroom #5
Lab Sample ID: 420-112382-68

Date Sampled: 10/22/2016 0717
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1224	
Prep Method: 200			Date Prepared:	11/17/2016 1011	
Pb	6.61	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: 1st Floor Blue Wing Faculty Bathroom on left
Lab Sample ID: 420-112382-69

Date Sampled: 10/22/2016 0712
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1227	
Prep Method: 200			Date Prepared:	11/17/2016 1011	
Pb	5.36	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: 1st Floor Blue Wing Faculty Bathroom on right
Lab Sample ID: 420-112382-70

Date Sampled: 10/22/2016 0712
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1228	
Prep Method: 200			Date Prepared:	11/17/2016 1011	
Pb	3.74	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: 1st Floor Blue Wing water fountain on left
Lab Sample ID: 420-112382-71

Date Sampled: 10/22/2016 0714
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1229	
Prep Method: 200			Date Prepared:	11/17/2016 1011	
Pb	1.18	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: 1st Floor Blue Wing water fountain on right
Lab Sample ID: 420-112382-72

Date Sampled: 10/22/2016 0714
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1230	
Prep Method: 200			Date Prepared:	11/17/2016 1011	
Pb	1.57	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: 1st Floor Blue Wing girl's bathroom #2
Lab Sample ID: 420-112382-73

Date Sampled: 10/22/2016 0716
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1232	
Prep Method: 200			Date Prepared:	11/17/2016 1011	
Pb	393 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: 1st Floor Blue Wing girl's bathroom #3
Lab Sample ID: 420-112382-74

Date Sampled: 10/22/2016 0716
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1233	
Prep Method: 200			Date Prepared:	11/17/2016 1011	
Pb	4.94	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: 1st Floor Blue Wing girl's bathroom #4
Lab Sample ID: 420-112382-75

Date Sampled: 10/22/2016 0716
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1234	
Prep Method: 200			Date Prepared:	11/17/2016 1011	
Pb	15.5 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: 1st Floor Blue Wing girl's bathroom #5
Lab Sample ID: 420-112382-76

Date Sampled: 10/22/2016 0718
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1234	
Prep Method: 200			Date Prepared:	11/17/2016 1011	
Pb	23.2 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 121 Slop Sink
Lab Sample ID: 420-112382-77

Date Sampled: 10/22/2016 0731
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1235	
Prep Method: 200			Date Prepared:	11/17/2016 1011	
Pb	4.33	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 121 sink #1
Lab Sample ID: 420-112382-78

Date Sampled: 10/22/2016 0731
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016	1236	
Prep Method: 200			Date Prepared:	11/17/2016	1011	
Pb	19.1	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 121 Sink #2
Lab Sample ID: 420-112382-79

Date Sampled: 10/22/2016 0732
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016	1237	
Prep Method: 200			Date Prepared:	11/17/2016	1011	
Pb	16.4	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 121 Sink #3
Lab Sample ID: 420-112382-80

Date Sampled: 10/22/2016 0732
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016	1237	
Prep Method: 200			Date Prepared:	11/17/2016	1011	
Pb	15.8	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 123 Sink
Lab Sample ID: 420-112382-81

Date Sampled: 10/22/2016 0732
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4 Prep Method: 200 Pb				Date Analyzed:	11/17/2016	1238
				Date Prepared:	11/17/2016	1011
	85.9	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: 2nd Floor Gold wing girl's gang bathroom #1
Lab Sample ID: 420-112382-82

Date Sampled: 10/22/2016 0736
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1239	
Prep Method: 200			Date Prepared:	11/17/2016 1011	
Pb	14.6	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: 2nd Floor Gold wing girl's gang bathroom #2
Lab Sample ID: 420-112382-83

Date Sampled: 10/22/2016 0737
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1241	
Prep Method: 200			Date Prepared:	11/17/2016 1011	
Pb	9.96	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: 2nd Floor Gold wing girl's gang bathroom #3
Lab Sample ID: 420-112382-84

Date Sampled: 10/22/2016 0737
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1242	
Prep Method: 200			Date Prepared:	11/17/2016 1011	
Pb	75.8 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: 2nd Floor water fountain by 216
Lab Sample ID: 420-112382-85

Date Sampled: 10/22/2016 0739
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	11/17/2016 1243	
Prep Method: 200				Date Prepared:	11/17/2016 1011	
Pb	1.00	U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: 2nd Floor gold wing boy's gang bathroom #1
Lab Sample ID: 420-112382-86

Date Sampled: 10/22/2016 0740
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1244	
Prep Method: 200			Date Prepared:	11/17/2016 1011	
Pb	12.8	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: 2nd Floor gold wing boy's gang bathroom #2
Lab Sample ID: 420-112382-87

Date Sampled: 10/22/2016 0740
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1244	
Prep Method: 200			Date Prepared:	11/17/2016 1011	
Pb	4.42	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: 2nd Floor gold wing boy's gang bathroom #3
Lab Sample ID: 420-112382-88

Date Sampled: 10/22/2016 0741
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1245	
Prep Method: 200			Date Prepared:	11/17/2016 1025	
Pb	8.48	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Water fountain by 202
Lab Sample ID: 420-112382-89

Date Sampled: 10/22/2016 0742
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1248	
Prep Method: 200			Date Prepared:	11/17/2016 1025	
Pb	7.30	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: 2nd Floor blue Wing Boy's gang bathroom #1
Lab Sample ID: 420-112382-90

Date Sampled: 10/22/2016 0747
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1251	
Prep Method: 200			Date Prepared:	11/17/2016 1025	
Pb	12.0	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: 2nd Floor blue Wing Boy's gang bathroom #2
Lab Sample ID: 420-112382-91

Date Sampled: 10/22/2016 0747
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1251	
Prep Method: 200			Date Prepared:	11/17/2016 1025	
Pb	8.15	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: 2nd Floor blue Wing Boy's gang bathroom #3
Lab Sample ID: 420-112382-92

Date Sampled: 10/22/2016 0748
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1252	
Prep Method: 200			Date Prepared:	11/17/2016 1025	
Pb	8.47	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: 2nd Floor blue Wing Boy's gang bathroom #4
Lab Sample ID: 420-112382-93

Date Sampled: 10/22/2016 0748
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1253	
Prep Method: 200			Date Prepared:	11/17/2016 1025	
Pb	3.68	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: 2nd Floor blue Wing Boy's gang bathroom #5
Lab Sample ID: 420-112382-94

Date Sampled: 10/22/2016 0749
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1254	
Prep Method: 200			Date Prepared:	11/17/2016 1025	
Pb	6.13	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: 2nd Floor blue Wing Faculty bathroom on left
Lab Sample ID: 420-112382-95

Date Sampled: 10/22/2016 0752
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1254	
Prep Method: 200			Date Prepared:	11/17/2016 1025	
Pb	4.01	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: 2nd Floor blue Wing Faculty bathroom on right
Lab Sample ID: 420-112382-96

Date Sampled: 10/22/2016 0752
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1441	
Prep Method: 200			Date Prepared:	11/17/2016 1025	
Pb	2.84	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Water fountain by 234 on left
Lab Sample ID: 420-112382-97

Date Sampled: 10/22/2016 0753
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1256	
Prep Method: 200			Date Prepared:	11/17/2016 1025	
Pb	1.07	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Water fountain by 234 on right
Lab Sample ID: 420-112382-98

Date Sampled: 10/22/2016 0754
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	11/17/2016 1257	
Prep Method: 200				Date Prepared:	11/17/2016 1025	
Pb	1.00	U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: 2nd Floor Blue Wing Girl's gang bathroom #1
Lab Sample ID: 420-112382-99

Date Sampled: 10/22/2016 0755
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1257	
Prep Method: 200			Date Prepared:	11/17/2016 1025	
Pb	22.6 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: 2nd Floor Blue Wing Girl's gang bathroom #2
Lab Sample ID: 420-112382-100

Date Sampled: 10/22/2016 0755
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1300	
Prep Method: 200			Date Prepared:	11/17/2016 1025	
Pb	2.24	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: 2nd Floor Blue Wing Girl's gang bathroom #3
Lab Sample ID: 420-112382-101

Date Sampled: 10/22/2016 0756
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1301	
Prep Method: 200			Date Prepared:	11/17/2016 1025	
Pb	5.84	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: 2nd Floor Blue Wing Girl's gang bathroom #4
Lab Sample ID: 420-112382-102

Date Sampled: 10/22/2016 0756
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1301	
Prep Method: 200			Date Prepared:	11/17/2016 1025	
Pb	10.6	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: 2nd Floor Blue Wing Girl's gang bathroom #5
Lab Sample ID: 420-112382-103

Date Sampled: 10/22/2016 0756
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1302	
Prep Method: 200			Date Prepared:	11/17/2016 1025	
Pb	16.2 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Pool 243 locker room water fountain
Lab Sample ID: 420-112382-104

Date Sampled: 10/22/2016 0800
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1303	
Prep Method: 200			Date Prepared:	11/17/2016 1025	
Pb	6.54	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: 243 - Pool Locker room bathroom (left)
Lab Sample ID: 420-112382-105

Date Sampled: 10/22/2016 0801
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1304	
Prep Method: 200			Date Prepared:	11/17/2016 1025	
Pb	7.08	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: 243 - Pool Locker room bathroom (right)
Lab Sample ID: 420-112382-106

Date Sampled: 10/22/2016 0801
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1304	
Prep Method: 200			Date Prepared:	11/17/2016 1025	
Pb	6.44	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: 247 - Boy's pool bathroom locker room (left)
Lab Sample ID: 420-112382-107

Date Sampled: 10/22/2016 0803
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1305	
Prep Method: 200			Date Prepared:	11/17/2016 1025	
Pb	8.67	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: 247 - Boy's pool bathroom locker room (right)
Lab Sample ID: 420-112382-108

Date Sampled: 10/22/2016 0804
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1306	
Prep Method: 200			Date Prepared:	11/17/2016 1115	
Pb	5.41	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: 247 - Boy's pool locker room water fountain
Lab Sample ID: 420-112382-109

Date Sampled: 10/22/2016 0805
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1354	
Prep Method: 200			Date Prepared:	11/17/2016 1115	
Pb	2.71	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Girl's pool coaches office bathroom sink
Lab Sample ID: 420-112382-110

Date Sampled: 10/22/2016 0809
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1355	
Prep Method: 200			Date Prepared:	11/17/2016 1115	
Pb	11.5	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Boy's pool coaches bathroom sink
Lab Sample ID: 420-112382-111

Date Sampled: 10/22/2016 0810
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1356	
Prep Method: 200			Date Prepared:	11/17/2016 1115	
Pb	8.99	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: 3rd Floor Blue Wing Boy's gang bathroom sink
Lab Sample ID: 420-112382-112

Date Sampled: 10/22/2016 0815
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1356	
Prep Method: 200			Date Prepared:	11/17/2016 1115	
Pb	10.6	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: 3rd Floor Blue Wing Boy's gang bathroom sink
Lab Sample ID: 420-112382-113

Date Sampled: 10/22/2016 0815
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1357	
Prep Method: 200			Date Prepared:	11/17/2016 1115	
Pb	9.21	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: 3rd Floor Blue Wing Boy's gang bathroom sink
Lab Sample ID: 420-112382-114

Date Sampled: 10/22/2016 0815
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1358	
Prep Method: 200			Date Prepared:	11/17/2016 1115	
Pb	6.95	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: 3rd Floor Blue Wing Boy's gang bathroom sink
Lab Sample ID: 420-112382-115

Date Sampled: 10/22/2016 0816
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1400	
Prep Method: 200			Date Prepared:	11/17/2016 1115	
Pb	4.36	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: 3rd Floor Blue Wing Boy's gang bathroom sink
Lab Sample ID: 420-112382-116

Date Sampled: 10/22/2016 0817
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1401	
Prep Method: 200			Date Prepared:	11/17/2016 1115	
Pb	5.60	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: 3rd Floor Blue Wing Faculty bathroom on left
Lab Sample ID: 420-112382-117

Date Sampled: 10/22/2016 0818
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1402	
Prep Method: 200			Date Prepared:	11/17/2016 1115	
Pb	5.83	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: 3rd Floor Blue Wing Faculty bathroom on right
Lab Sample ID: 420-112382-118

Date Sampled: 10/22/2016 0819
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1403	
Prep Method: 200			Date Prepared:	11/17/2016 1115	
Pb	16.4 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: 3rd Floor water fountain by 332 on left
Lab Sample ID: 420-112382-119

Date Sampled: 10/22/2016 0820
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1403	
Prep Method: 200			Date Prepared:	11/17/2016 1115	
Pb	1.14	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: 3rd Floor water fountain by 332 on right
Lab Sample ID: 420-112382-120

Date Sampled: 10/22/2016 0820
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1404	
Prep Method: 200			Date Prepared:	11/17/2016 1115	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: 3rd Floor Blue Wing girl's gang bathroom #1
Lab Sample ID: 420-112382-121

Date Sampled: 10/22/2016 0821
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1405	
Prep Method: 200			Date Prepared:	11/17/2016 1115	
Pb	4.72	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: 3rd Floor Blue Wing girl's gang bathroom #2
Lab Sample ID: 420-112382-122

Date Sampled: 10/22/2016 0821
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1406	
Prep Method: 200			Date Prepared:	11/17/2016 1115	
Pb	9.17	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: 3rd Floor Blue Wing girl's gang bathroom #3
Lab Sample ID: 420-112382-123

Date Sampled: 10/22/2016 0822
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1406	
Prep Method: 200			Date Prepared:	11/17/2016 1115	
Pb	2.78	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: 3rd Floor Blue Wing girl's gang bathroom #4
Lab Sample ID: 420-112382-124

Date Sampled: 10/22/2016 0822
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1407	
Prep Method: 200			Date Prepared:	11/17/2016 1115	
Pb	9.79	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: 3rd Floor Blue Wing girl's gang bathroom #5
Lab Sample ID: 420-112382-125

Date Sampled: 10/22/2016 0823
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1410	
Prep Method: 200			Date Prepared:	11/17/2016 1115	
Pb	13.1	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: 343 - Boy's bathroom (right)
Lab Sample ID: 420-112382-126

Date Sampled: 10/22/2016 0827
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1410	
Prep Method: 200			Date Prepared:	11/17/2016 1115	
Pb	12.1	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: 343 - Boy's bathroom (left)
Lab Sample ID: 420-112382-127

Date Sampled: 10/22/2016 0827
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1411	
Prep Method: 200			Date Prepared:	11/17/2016 1115	
Pb	7.22	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: 343 - water fountain
Lab Sample ID: 420-112382-128

Date Sampled: 10/22/2016 0828
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1416	
Prep Method: 200			Date Prepared:	11/17/2016 1135	
Pb	1.92	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: 343 - girl's bathroom (right)
Lab Sample ID: 420-112382-129

Date Sampled: 10/22/2016 0828
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1420	
Prep Method: 200			Date Prepared:	11/17/2016 1135	
Pb	10.4	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: 343 - girl's bathroom (left)
Lab Sample ID: 420-112382-130

Date Sampled: 10/22/2016 0828
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1421	
Prep Method: 200			Date Prepared:	11/17/2016 1135	
Pb	8.48	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Gym drinking fountain by 159
Lab Sample ID: 420-112382-131

Date Sampled: 10/22/2016 0835
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1422	
Prep Method: 200			Date Prepared:	11/17/2016 1135	
Pb	1.03	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Trainer's office sink
Lab Sample ID: 420-112382-132

Date Sampled: 10/22/2016 0836
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1423	
Prep Method: 200			Date Prepared:	11/17/2016 1135	
Pb	7.89	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: gym drinking fountain by boy's locker room
Lab Sample ID: 420-112382-133

Date Sampled: 10/22/2016 0803
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1423	
Prep Method: 200			Date Prepared:	11/17/2016 1135	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Ice machine Receiving area
Lab Sample ID: 420-112382-134

Date Sampled: 10/22/2016 0601
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1424	
Prep Method: 200			Date Prepared:	11/17/2016 1135	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Ice machine Trainer's room
Lab Sample ID: 420-112382-135

Date Sampled: 10/22/2016 0813
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	11/17/2016 1425	
Prep Method: 200				Date Prepared:	11/17/2016 1135	
Pb	1.00	U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 328 Sink #1
Lab Sample ID: 420-112382-136

Date Sampled: 10/22/2016 0856
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016	1426	
Prep Method: 200			Date Prepared:	11/17/2016	1135	
Pb	78.9	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 328 Sink #2
Lab Sample ID: 420-112382-137

Date Sampled: 10/22/2016 0856
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1428	
Prep Method: 200			Date Prepared:	11/17/2016 1135	
Pb	76.8 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 328 Sink #3
Lab Sample ID: 420-112382-138

Date Sampled: 10/22/2016 0857
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016	1429	
Prep Method: 200			Date Prepared:	11/17/2016	1135	
Pb	90.1	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 328 Sink #4
Lab Sample ID: 420-112382-139

Date Sampled: 10/22/2016 0857
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016	1430	
Prep Method: 200			Date Prepared:	11/17/2016	1135	
Pb	79.9	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 328 Sink #5
Lab Sample ID: 420-112382-140

Date Sampled: 10/22/2016 0858
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1430	
Prep Method: 200			Date Prepared:	11/17/2016 1135	
Pb	87.1 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 328 Sink #6
Lab Sample ID: 420-112382-141

Date Sampled: 10/22/2016 0858
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1431	
Prep Method: 200			Date Prepared:	11/17/2016 1135	
Pb	84.7 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 328 Sink #7
Lab Sample ID: 420-112382-142

Date Sampled: 10/22/2016 0859
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1432	
Prep Method: 200			Date Prepared:	11/17/2016 1135	
Pb	74.9 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 328 Sink #8
Lab Sample ID: 420-112382-143

Date Sampled: 10/22/2016 0859
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016	1433	
Prep Method: 200			Date Prepared:	11/17/2016	1135	
Pb	72.4	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 328 Sink #9
Lab Sample ID: 420-112382-144

Date Sampled: 10/22/2016 0900
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016	1433	
Prep Method: 200			Date Prepared:	11/17/2016	1135	
Pb	76.9	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 328 Sink #10
Lab Sample ID: 420-112382-145

Date Sampled: 10/22/2016 0900
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1434	
Prep Method: 200			Date Prepared:	11/17/2016 1135	
Pb	90.1 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 328 Sink #11
Lab Sample ID: 420-112382-146

Date Sampled: 10/22/2016 0900
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016	1435	
Prep Method: 200			Date Prepared:	11/17/2016	1135	
Pb	92.8	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 328 Sink #12
Lab Sample ID: 420-112382-147

Date Sampled: 10/22/2016 0901
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/17/2016 1437	
Prep Method: 200			Date Prepared:	11/17/2016 1135	
Pb	74.9 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 334 Sink #1
Lab Sample ID: 420-112382-148

Date Sampled: 10/22/2016 0905
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	11/18/2016 0947	
Prep Method: 200				Date Prepared:	11/17/2016 1535	
Pb	87.6	F V	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 334 Sink #2
Lab Sample ID: 420-112382-149

Date Sampled: 10/22/2016 0906
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016 0955	
Prep Method: 200			Date Prepared:	11/17/2016 1535	
Pb	79.7 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 334 Sink #3
Lab Sample ID: 420-112382-150

Date Sampled: 10/22/2016 0905
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016	0956	
Prep Method: 200			Date Prepared:	11/17/2016	1535	
Pb	84.7	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 334 Sink #4
Lab Sample ID: 420-112382-151

Date Sampled: 10/22/2016 0906
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016 0958	
Prep Method: 200			Date Prepared:	11/17/2016 1535	
Pb	91.2 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 334 Sink #5
Lab Sample ID: 420-112382-152

Date Sampled: 10/22/2016 0906
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016 1000	
Prep Method: 200			Date Prepared:	11/17/2016 1535	
Pb	95.7 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 334 Sink #6
Lab Sample ID: 420-112382-153

Date Sampled: 10/22/2016 0906
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016 1002	
Prep Method: 200			Date Prepared:	11/17/2016 1535	
Pb	97.7 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 334 Sink #7
Lab Sample ID: 420-112382-154

Date Sampled: 10/22/2016 0907
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	11/18/2016 1008	
Prep Method: 200				Date Prepared:	11/17/2016 1535	
Pb	88.6	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 334 Sink #8
Lab Sample ID: 420-112382-155

Date Sampled: 10/22/2016 0907
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016	1009	
Prep Method: 200			Date Prepared:	11/17/2016	1535	
Pb	91.6	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 334 Sink #9
Lab Sample ID: 420-112382-156

Date Sampled: 10/22/2016 0907
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016	1011	
Prep Method: 200			Date Prepared:	11/17/2016	1535	
Pb	90.8	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 334 Sink #10
Lab Sample ID: 420-112382-157

Date Sampled: 10/22/2016 0908
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016	1013	
Prep Method: 200			Date Prepared:	11/17/2016	1535	
Pb	96.5	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 334 Sink #11
Lab Sample ID: 420-112382-158

Date Sampled: 10/22/2016 0908
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	11/18/2016 1015	
Prep Method: 200				Date Prepared:	11/17/2016 1535	
Pb	86.5	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 334 Sink #12
Lab Sample ID: 420-112382-159

Date Sampled: 10/22/2016 0909
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016	1017	
Prep Method: 200			Date Prepared:	11/17/2016	1535	
Pb	107	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 334 Sink #13
Lab Sample ID: 420-112382-160

Date Sampled: 10/22/2016 0909
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	11/18/2016 1019	
Prep Method: 200				Date Prepared:	11/17/2016 1535	
Pb	86.4	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 341 Sink #1
Lab Sample ID: 420-112382-161

Date Sampled: 10/22/2016 0912
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	11/18/2016 1020	
Prep Method: 200				Date Prepared:	11/17/2016 1535	
Pb	83.9	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 341 Sink #2
Lab Sample ID: 420-112382-162

Date Sampled: 10/22/2016 0913
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016	1022	
Prep Method: 200			Date Prepared:	11/17/2016	1535	
Pb	77.9	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: 3rd Floor Gold Wing Girl's gang bathroom sink
Lab Sample ID: 420-112382-163

Date Sampled: 10/22/2016 0755
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016 1024	
Prep Method: 200			Date Prepared:	11/17/2016 1535	
Pb	12.5	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: 3rd Floor Gold Wing Girl's gang bathroom sink
Lab Sample ID: 420-112382-164

Date Sampled: 10/22/2016 0755
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016 1030	
Prep Method: 200			Date Prepared:	11/17/2016 1535	
Pb	13.9	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: 3rd Floor Gold Wing Girl's gang bathroom sink
Lab Sample ID: 420-112382-165

Date Sampled: 10/22/2016 0756
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016 1032	
Prep Method: 200			Date Prepared:	11/17/2016 1535	
Pb	18.0 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Water Fountain by 311
Lab Sample ID: 420-112382-166

Date Sampled: 10/22/2016 0757
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016 1034	
Prep Method: 200			Date Prepared:	11/17/2016 1535	
Pb	1.93	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: 3rd floor Gold wing Boy's gang bathroom sink
Lab Sample ID: 420-112382-167

Date Sampled: 10/22/2016 0757
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016 1035	
Prep Method: 200			Date Prepared:	11/17/2016 1535	
Pb	23.4 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: 3rd floor Gold wing Boy's gang bathroom sink
Lab Sample ID: 420-112382-168

Date Sampled: 10/22/2016 0757
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016 1037	
Prep Method: 200			Date Prepared:	11/17/2016 1600	
Pb	13.2	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: 3rd floor Gold wing Boy's gang bathroom sink
Lab Sample ID: 420-112382-169

Date Sampled: 10/22/2016 0757
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016 1045	
Prep Method: 200			Date Prepared:	11/17/2016 1600	
Pb	4.14	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 311 Island sink
Lab Sample ID: 420-112382-170

Date Sampled: 10/22/2016 0801
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016 1047	
Prep Method: 200			Date Prepared:	11/17/2016 1600	
Pb	177 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 311 back wall Sink #1
Lab Sample ID: 420-112382-171

Date Sampled: 10/22/2016 0801
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016 1052	
Prep Method: 200			Date Prepared:	11/17/2016 1600	
Pb	94.9 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 301 back wall Sink #2
Lab Sample ID: 420-112382-172

Date Sampled: 10/22/2016 0801
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016 1054	
Prep Method: 200			Date Prepared:	11/17/2016 1600	
Pb	112 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 312 Island sink
Lab Sample ID: 420-112382-173

Date Sampled: 10/22/2016 0804
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016 1056	
Prep Method: 200			Date Prepared:	11/17/2016 1600	
Pb	14.0	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 312 Left sink
Lab Sample ID: 420-112382-174

Date Sampled: 10/22/2016 0804
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016	1058	
Prep Method: 200			Date Prepared:	11/17/2016	1600	
Pb	20.9	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 309 sink
Lab Sample ID: 420-112382-175

Date Sampled: 10/22/2016 0806
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	11/18/2016 1100	
Prep Method: 200				Date Prepared:	11/17/2016 1600	
Pb	71.7	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 310 Front Left Sink #1
Lab Sample ID: 420-112382-176

Date Sampled: 10/22/2016 0807
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016 1102	
Prep Method: 200			Date Prepared:	11/17/2016 1600	
Pb	134 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 310 Front Left Sink #2
Lab Sample ID: 420-112382-177

Date Sampled: 10/22/2016 0807
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016 1103	
Prep Method: 200			Date Prepared:	11/17/2016 1600	
Pb	97.8 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 310 Front Right Sink #1
Lab Sample ID: 420-112382-178

Date Sampled: 10/22/2016 0807
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016 1105	
Prep Method: 200			Date Prepared:	11/17/2016 1600	
Pb	109 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 310 Front Right Sink #2
Lab Sample ID: 420-112382-179

Date Sampled: 10/22/2016 0807
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016 1107	
Prep Method: 200			Date Prepared:	11/17/2016 1600	
Pb	134 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 310 Back Center Sink #1
Lab Sample ID: 420-112382-180

Date Sampled: 10/22/2016 0809
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016 1109	
Prep Method: 200			Date Prepared:	11/17/2016 1600	
Pb	97.2 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 310 Back Center Sink #2
Lab Sample ID: 420-112382-181

Date Sampled: 10/22/2016 0809
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016 1115	
Prep Method: 200			Date Prepared:	11/17/2016 1600	
Pb	111 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 310 Back right Sink #1
Lab Sample ID: 420-112382-182

Date Sampled: 10/22/2016 0809
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016 1117	
Prep Method: 200			Date Prepared:	11/17/2016 1600	
Pb	16.2 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 310 Back right Sink #2
Lab Sample ID: 420-112382-183

Date Sampled: 10/22/2016 0811
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016 1119	
Prep Method: 200			Date Prepared:	11/17/2016 1600	
Pb	9.72	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 310 Back Left Sink #1
Lab Sample ID: 420-112382-184

Date Sampled: 10/22/2016 0811
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016	1120	
Prep Method: 200			Date Prepared:	11/17/2016	1600	
Pb	90.3	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 310 Back Left Sink #2
Lab Sample ID: 420-112382-185

Date Sampled: 10/22/2016 0811
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016	1122	
Prep Method: 200			Date Prepared:	11/17/2016	1600	
Pb	107	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 310 Right wall sink
Lab Sample ID: 420-112382-186

Date Sampled: 10/22/2016 0813
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016 1124	
Prep Method: 200			Date Prepared:	11/17/2016 1600	
Pb	29.7 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 310 Back wall right sink
Lab Sample ID: 420-112382-187

Date Sampled: 10/22/2016 0813
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016 1126	
Prep Method: 200			Date Prepared:	11/17/2016 1600	
Pb	127 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 310 Back wall left sink
Lab Sample ID: 420-112382-188

Date Sampled: 10/22/2016 0813
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016 1128	
Prep Method: 200			Date Prepared:	11/17/2016 1620	
Pb	135 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 309 island sink
Lab Sample ID: 420-112382-189

Date Sampled: 10/22/2016 0815
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016	1139	
Prep Method: 200			Date Prepared:	11/17/2016	1620	
Pb	96.3	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 309 Left 1 Front Sink
Lab Sample ID: 420-112382-190

Date Sampled: 10/22/2016 0815
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016 1141	
Prep Method: 200			Date Prepared:	11/17/2016 1620	
Pb	115 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 309 Left 2 Front Sink
Lab Sample ID: 420-112382-191

Date Sampled: 10/22/2016 0815
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	11/18/2016 1143	
Prep Method: 200				Date Prepared:	11/17/2016 1620	
Pb	113	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 309 Left 1 Back Sink
Lab Sample ID: 420-112382-192

Date Sampled: 10/22/2016 0815
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016	1145	
Prep Method: 200			Date Prepared:	11/17/2016	1620	
Pb	129	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 309 Left 2 Back Sink
Lab Sample ID: 420-112382-193

Date Sampled: 10/22/2016 0815
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016 1147	
Prep Method: 200			Date Prepared:	11/17/2016 1620	
Pb	97.2 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 309 Left 3 Front Sink
Lab Sample ID: 420-112382-194

Date Sampled: 10/22/2016 0815
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	11/18/2016 1149	
Prep Method: 200				Date Prepared:	11/17/2016 1620	
Pb	142	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 309 Left 3 Back Sink
Lab Sample ID: 420-112382-195

Date Sampled: 10/22/2016 0815
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	11/18/2016 1151	
Prep Method: 200				Date Prepared:	11/17/2016 1620	
Pb	114	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 309 Right 4 Front Sink
Lab Sample ID: 420-112382-196

Date Sampled: 10/22/2016 0819
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016 1152	
Prep Method: 200			Date Prepared:	11/17/2016 1620	
Pb	108 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 309 Right 4 Back Sink
Lab Sample ID: 420-112382-197

Date Sampled: 10/22/2016 0819
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016 1154	
Prep Method: 200			Date Prepared:	11/17/2016 1620	
Pb	113 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 309 Right 5 Front Sink
Lab Sample ID: 420-112382-198

Date Sampled: 10/22/2016 0822
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	11/18/2016 1200	
Prep Method: 200				Date Prepared:	11/17/2016 1620	
Pb	136	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 309 Right 5 Back Sink
Lab Sample ID: 420-112382-199

Date Sampled: 10/22/2016 0822
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016 1202	
Prep Method: 200			Date Prepared:	11/17/2016 1620	
Pb	113 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 309 Right 6 Front Sink
Lab Sample ID: 420-112382-200

Date Sampled: 10/22/2016 0822
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016 1204	
Prep Method: 200			Date Prepared:	11/17/2016 1620	
Pb	79.3 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 309 Right 6 Back Sink
Lab Sample ID: 420-112382-201

Date Sampled: 10/22/2016 0822
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016 1206	
Prep Method: 200			Date Prepared:	11/17/2016 1620	
Pb	178 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 309 sink by door
Lab Sample ID: 420-112382-202

Date Sampled: 10/22/2016 0822
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016 1208	
Prep Method: 200			Date Prepared:	11/17/2016 1620	
Pb	115 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 307 Front wall sink
Lab Sample ID: 420-112382-203

Date Sampled: 10/22/2016 0825
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016 1210	
Prep Method: 200			Date Prepared:	11/17/2016 1620	
Pb	5.63	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 307 sink #1
Lab Sample ID: 420-112382-204

Date Sampled: 10/22/2016 0826
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016	1211	
Prep Method: 200			Date Prepared:	11/17/2016	1620	
Pb	73.3	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 307 sink #2
Lab Sample ID: 420-112382-205

Date Sampled: 10/22/2016 0826
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016 1213	
Prep Method: 200			Date Prepared:	11/17/2016 1620	
Pb	91.0 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 307 sink #3
Lab Sample ID: 420-112382-206

Date Sampled: 10/22/2016 0826
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4 Prep Method: 200 Pb	Date Analyzed:			11/18/2016	1215	
	Date Prepared:			11/17/2016	1620	
	106	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 307 sink #4
Lab Sample ID: 420-112382-207

Date Sampled: 10/22/2016 0826
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016 1217	
Prep Method: 200			Date Prepared:	11/17/2016 1620	
Pb	85.8 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 307 sink #5
Lab Sample ID: 420-112382-208

Date Sampled: 10/22/2016 0829
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016	1907	
Prep Method: 200			Date Prepared:	11/17/2016	1715	
Pb	65.1	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 307 sink #6
Lab Sample ID: 420-112382-209

Date Sampled: 10/22/2016 0829
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016 1230	
Prep Method: 200			Date Prepared:	11/17/2016 1715	
Pb	80.7 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 307 sink #7
Lab Sample ID: 420-112382-210

Date Sampled: 10/22/2016 0829
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	11/18/2016 1232	
Prep Method: 200				Date Prepared:	11/17/2016 1715	
Pb	89.6	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 307 sink #8
Lab Sample ID: 420-112382-211

Date Sampled: 10/22/2016 0829
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	11/18/2016 1234	
Prep Method: 200				Date Prepared:	11/17/2016 1715	
Pb	138	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 307 Back wall sink
Lab Sample ID: 420-112382-212

Date Sampled: 10/22/2016 0829
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016	1236	
Prep Method: 200			Date Prepared:	11/17/2016	1715	
Pb	158	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 306 Island sink
Lab Sample ID: 420-112382-213

Date Sampled: 10/22/2016 0833
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016	1238	
Prep Method: 200			Date Prepared:	11/17/2016	1715	
Pb	126	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 306 wall sink
Lab Sample ID: 420-112382-214

Date Sampled: 10/22/2016 0833
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	11/18/2016 1240	
Prep Method: 200				Date Prepared:	11/17/2016 1715	
Pb	28.5	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 305 sink
Lab Sample ID: 420-112382-215

Date Sampled: 10/22/2016 0834
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	11/18/2016 1246	
Prep Method: 200				Date Prepared:	11/17/2016 1715	
Pb	47.9	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 304 Lab Hood sink
Lab Sample ID: 420-112382-216

Date Sampled: 10/22/2016 0836
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016 1248	
Prep Method: 200			Date Prepared:	11/17/2016 1715	
Pb	48.6 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 304 Left 1 Front sink
Lab Sample ID: 420-112382-217

Date Sampled: 10/22/2016 0836
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016	1249	
Prep Method: 200			Date Prepared:	11/17/2016	1715	
Pb	98.0	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 304 Left 1 Back sink
Lab Sample ID: 420-112382-218

Date Sampled: 10/22/2016 0836
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	11/18/2016 1251	
Prep Method: 200				Date Prepared:	11/17/2016 1715	
Pb	104	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 304 Left 2 Front sink
Lab Sample ID: 420-112382-219

Date Sampled: 10/22/2016 0836
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016 1253	
Prep Method: 200			Date Prepared:	11/17/2016 1715	
Pb	121 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 304 Left 2 Back sink
Lab Sample ID: 420-112382-220

Date Sampled: 10/22/2016 0836
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	11/18/2016 1255	
Prep Method: 200				Date Prepared:	11/17/2016 1715	
Pb	92.8	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 304 Left 3 Front sink
Lab Sample ID: 420-112382-221

Date Sampled: 10/22/2016 0836
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016	1257	
Prep Method: 200			Date Prepared:	11/17/2016	1715	
Pb	97.3	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 304 Left 3 back sink
Lab Sample ID: 420-112382-222

Date Sampled: 10/22/2016 0836
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016	1259	
Prep Method: 200			Date Prepared:	11/17/2016	1715	
Pb	83.6	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 304 Right 4 Front sink
Lab Sample ID: 420-112382-223

Date Sampled: 10/22/2016 0839
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016	1301	
Prep Method: 200			Date Prepared:	11/17/2016	1715	
Pb	91.9	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 304 Right 4 Back Sink
Lab Sample ID: 420-112382-224

Date Sampled: 10/22/2016 0839
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	11/18/2016 1303	
Prep Method: 200				Date Prepared:	11/17/2016 1715	
Pb	99.5	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 304 Right 5 Front sink
Lab Sample ID: 420-112382-225

Date Sampled: 10/22/2016 0839
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016	1309	
Prep Method: 200			Date Prepared:	11/17/2016	1715	
Pb	92.5	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 304 Right 5 back sink
Lab Sample ID: 420-112382-226

Date Sampled: 10/22/2016 0839
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	11/18/2016 1310	
Prep Method: 200				Date Prepared:	11/17/2016 1715	
Pb	87.2	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 304 Right 6 Front sink
Lab Sample ID: 420-112382-227

Date Sampled: 10/22/2016 0839
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016 1312	
Prep Method: 200			Date Prepared:	11/17/2016 1715	
Pb	84.7 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 304 Right 6 Back sink
Lab Sample ID: 420-112382-228

Date Sampled: 10/22/2016 0839
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016 1450	
Prep Method: 200			Date Prepared:	11/18/2016 0915	
Pb	80.0 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 304 sink by door
Lab Sample ID: 420-112382-229

Date Sampled: 10/22/2016 0841
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016	1455	
Prep Method: 200			Date Prepared:	11/18/2016	0915	
Pb	85.3	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 303 Island Sink
Lab Sample ID: 420-112382-230

Date Sampled: 10/22/2016 0844
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016 1456	
Prep Method: 200			Date Prepared:	11/18/2016 0915	
Pb	9.23	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 303 Front podium front sink
Lab Sample ID: 420-112382-231

Date Sampled: 10/22/2016 0844
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016	1456	
Prep Method: 200			Date Prepared:	11/18/2016	0915	
Pb	85.1	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 303 Front podium Back sink
Lab Sample ID: 420-112382-232

Date Sampled: 10/22/2016 0844
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016 1457	
Prep Method: 200			Date Prepared:	11/18/2016 0915	
Pb	7.35	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 303 Left back podium front sink
Lab Sample ID: 420-112382-233

Date Sampled: 10/22/2016 0844
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016 1458	
Prep Method: 200			Date Prepared:	11/18/2016 0915	
Pb	95.4 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 303 Left back podium Back sink
Lab Sample ID: 420-112382-234

Date Sampled: 10/22/2016 0844
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016	1459	
Prep Method: 200			Date Prepared:	11/18/2016	0915	
Pb	98.3	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 303 Back Right podium Front Sink
Lab Sample ID: 420-112382-235

Date Sampled: 10/22/2016 0853
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016 1459	
Prep Method: 200			Date Prepared:	11/18/2016 0915	
Pb	86.2 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 303 Back Right podium Back Sink
Lab Sample ID: 420-112382-236

Date Sampled: 10/22/2016 0853
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	11/18/2016 1500	
Prep Method: 200				Date Prepared:	11/18/2016 0915	
Pb	83.4	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 303 Lab hood sink
Lab Sample ID: 420-112382-237

Date Sampled: 10/22/2016 0853
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/28/2016 1644	
Prep Method: 200			Date Prepared:	11/21/2016 0830	
Pb	582 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 302 island sink
Lab Sample ID: 420-112382-238

Date Sampled: 10/22/2016 0856
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016	1501	
Prep Method: 200			Date Prepared:	11/18/2016	0915	
Pb	72.5	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 302 Left Podium front sink
Lab Sample ID: 420-112382-239

Date Sampled: 10/22/2016 0856
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016	1502	
Prep Method: 200			Date Prepared:	11/18/2016	0915	
Pb	85.4	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 302 Left Podium back sink
Lab Sample ID: 420-112382-240

Date Sampled: 10/22/2016 0856
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016	1504	
Prep Method: 200			Date Prepared:	11/18/2016	0915	
Pb	218	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 302 back left podium front sink
Lab Sample ID: 420-112382-241

Date Sampled: 10/22/2016 0856
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016	1505	
Prep Method: 200			Date Prepared:	11/18/2016	0915	
Pb	79.2	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 302 Left back podium back sink
Lab Sample ID: 420-112382-242

Date Sampled: 10/22/2016 0856
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016	1506	
Prep Method: 200			Date Prepared:	11/18/2016	0915	
Pb	132	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 302 Back Right podium front sink
Lab Sample ID: 420-112382-243

Date Sampled: 10/22/2016 0856
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016 1506	
Prep Method: 200			Date Prepared:	11/18/2016 0915	
Pb	67.6 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 302 Back Right podium back sink
Lab Sample ID: 420-112382-244

Date Sampled: 10/22/2016 0856
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016	1507	
Prep Method: 200			Date Prepared:	11/18/2016	0915	
Pb	123	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 302 Left wall sink
Lab Sample ID: 420-112382-245

Date Sampled: 10/22/2016 0856
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016	1508	
Prep Method: 200			Date Prepared:	11/18/2016	0915	
Pb	21.0	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: water fountain by 302
Lab Sample ID: 420-112382-246

Date Sampled: 10/22/2016 0859
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016	1509	
Prep Method: 200			Date Prepared:	11/18/2016	0915	
Pb	15.7	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 330 sink #1
Lab Sample ID: 420-112382-247

Date Sampled: 10/22/2016 0903
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016 1510	
Prep Method: 200			Date Prepared:	11/18/2016 0915	
Pb	88.7 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 330 sink #2
Lab Sample ID: 420-112382-248

Date Sampled: 10/22/2016 0903
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016	1510	
Prep Method: 200			Date Prepared:	11/18/2016	0915	
Pb	92.3	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 330 sink #3
Lab Sample ID: 420-112382-249

Date Sampled: 10/22/2016 0903
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016 1511	
Prep Method: 200			Date Prepared:	11/18/2016 0950	
Pb	97.0 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 330 sink #4
Lab Sample ID: 420-112382-250

Date Sampled: 10/22/2016 0903
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016 1516	
Prep Method: 200			Date Prepared:	11/18/2016 0950	
Pb	95.8 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 330 sink #5
Lab Sample ID: 420-112382-251

Date Sampled: 10/22/2016 0903
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016 1517	
Prep Method: 200			Date Prepared:	11/18/2016 0950	
Pb	115 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 330 sink #6
Lab Sample ID: 420-112382-252

Date Sampled: 10/22/2016 0903
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016 1517	
Prep Method: 200			Date Prepared:	11/18/2016 0950	
Pb	92.7 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 330 sink #7
Lab Sample ID: 420-112382-253

Date Sampled: 10/22/2016 0905
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016	1518	
Prep Method: 200			Date Prepared:	11/18/2016	0950	
Pb	106	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 330 sink #8
Lab Sample ID: 420-112382-254

Date Sampled: 10/22/2016 0905
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016	1519	
Prep Method: 200			Date Prepared:	11/18/2016	0950	
Pb	90.4	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 330 sink #9
Lab Sample ID: 420-112382-255

Date Sampled: 10/22/2016 0905
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016 1520	
Prep Method: 200			Date Prepared:	11/18/2016 0950	
Pb	75.8 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 330 sink #10
Lab Sample ID: 420-112382-256

Date Sampled: 10/22/2016 0905
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016 1520	
Prep Method: 200			Date Prepared:	11/18/2016 0950	
Pb	85.4 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 330 sink #11
Lab Sample ID: 420-112382-257

Date Sampled: 10/22/2016 0905
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016	1523	
Prep Method: 200			Date Prepared:	11/18/2016	0950	
Pb	89.3	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 330 sink #12
Lab Sample ID: 420-112382-258

Date Sampled: 10/22/2016 0905
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016	1523	
Prep Method: 200			Date Prepared:	11/18/2016	0950	
Pb	92.4	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 330 Sink #13
Lab Sample ID: 420-112382-259

Date Sampled: 10/22/2016 0905
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	11/18/2016 1524	
Prep Method: 200				Date Prepared:	11/18/2016 0950	
Pb	109	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 336 Sink #1
Lab Sample ID: 420-112382-260

Date Sampled: 10/22/2016 0911
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016	1525	
Prep Method: 200			Date Prepared:	11/18/2016	0950	
Pb	96.7	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 336 Sink #2
Lab Sample ID: 420-112382-261

Date Sampled: 10/22/2016 0911
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016 1526	
Prep Method: 200			Date Prepared:	11/18/2016 0950	
Pb	82.2 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 336 Sink #3
Lab Sample ID: 420-112382-262

Date Sampled: 10/22/2016 0911
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016	1527	
Prep Method: 200			Date Prepared:	11/18/2016	0950	
Pb	107	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 336 Sink #4
Lab Sample ID: 420-112382-263

Date Sampled: 10/22/2016 0911
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	11/18/2016 1527	
Prep Method: 200				Date Prepared:	11/18/2016 0950	
Pb	84.0	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 336 Sink #5
Lab Sample ID: 420-112382-264

Date Sampled: 10/22/2016 0911
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016	1528	
Prep Method: 200			Date Prepared:	11/18/2016	0950	
Pb	115	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 336 Sink #6
Lab Sample ID: 420-112382-265

Date Sampled: 10/22/2016 0911
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016	1529	
Prep Method: 200			Date Prepared:	11/18/2016	0950	
Pb	236	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 336 Sink #7
Lab Sample ID: 420-112382-266

Date Sampled: 10/22/2016 0913
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016 1530	
Prep Method: 200			Date Prepared:	11/18/2016 0950	
Pb	91.3 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 336 Sink #9
Lab Sample ID: 420-112382-267

Date Sampled: 10/22/2016 0913
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016	1532	
Prep Method: 200			Date Prepared:	11/18/2016	0950	
Pb	134	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 336 Sink #10
Lab Sample ID: 420-112382-268

Date Sampled: 10/22/2016 0913
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016	1533	
Prep Method: 200			Date Prepared:	11/18/2016	0950	
Pb	92.5	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 336 Sink #11
Lab Sample ID: 420-112382-269

Date Sampled: 10/22/2016 0913
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016	1534	
Prep Method: 200			Date Prepared:	11/18/2016	1030	
Pb	93.7	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 336 Sink #12
Lab Sample ID: 420-112382-270

Date Sampled: 10/22/2016 0913
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	11/18/2016 1537	
Prep Method: 200				Date Prepared:	11/18/2016 1030	
Pb	113	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112382-1
Sdg Number: Washington Ville CSD - High School

Client Sample ID: Room 336 Sink #13
Lab Sample ID: 420-112382-271

Date Sampled: 10/22/2016 0913
Date Received: 10/27/2016 1030
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/18/2016	1537	
Prep Method: 200			Date Prepared:	11/18/2016	1030	
Pb	87.5	g	ug/L	1.00	1.00	1.0

DATA REPORTING QUALIFIERS

Client: Orange-Ulster BOCES

Job Number:

Sdg Number: Washington Ville CSD - High School

Lab Section	Qualifier	Description
Metals		
	F	MS or MSD exceeds the control limits
	g	Result fails applicable NYS drinking water standards
	U	The analyte was analyzed for but not detected at or above the lowest stated limit.
	V	Serial Dilution exceeds the control limits

Certification Information

Client: Orange-Ulster BOCES

Job Number:

Sdg Number: Washington Ville CSD - High School

The following analytes are Not Part of the ELAP scope of accreditation:

Sulfur, Tungsten, Silicon, Bicarbonate Alkalinity, 7 Day BOD 5210C, 28 Day BOD, Soluble BOD, Carbon Dioxide, Carbonate Alkalinity, CBOD Soluble, Chlorine, Cyanide (WAD), Ferrous Iron, Ferric Iron, Total Nitrogen, Total Organic Nitrogen, Dissolved Oxygen, pH, Phenolphthalein Alkalinity, Solids (Fixed), Solids (Percent), Solids (Percent Moisture), Solids (Percent Volatile), Solids (Volatile Suspended), Temperature, TKN (Soluble), Total Inorganic Carbon, Volatile Acids as Acetic Acid, 2-Aminopyridine, 3-Picoline, 1-Methyl-2-pyrrilidinone, Aziridine, Dimethyl sulfoxide, 1-Chlorohexane, Iron Bacteria, Salmonella, & Sulfur Reducing Bacteria.

The following analytes are Not Part of ELAP Potable Water scope of accreditation:

Cobalt (200.7, 200.8), Tin (200.7), Strontium (200.7), Gold (200.7), Platinum (200.7), Palladium (200.7), Titanium (200.7), Phosphorus (365.3), Nitrate-Nitrite (10-107-4-1C, 353.2), m-Xylene & p-Xylene (502.2, 524), Naphthalene (502.2), o-Xylene (502.2, 524), & Fecal Coliform (9222D).

The following analytes are Not Part of ELAP Solid and Hazardous Waste scope of accreditation:

Ammonia (SM 4500NH3G), TKN (351.2), Phosphorus (365.3), 1,2-Dichloro-1,1,2-trifluoroethane (8260), & Chlorodifluoromethane (8260).

The following analytes are Not Part of ELAP Non Potable Water scope of accreditation:

Dissolved Organic Carbon (5310C), Mecoprop (8151A), & MCPA (8151A).

Definitions and Glossary

Client: Orange-Ulster BOCES

Job Number:

Sdg Number: Washington Ville CSD - High School

Abbreviation	These commonly used abbreviations may or may not be present in this report.
%R	Percent Recovery
DL, RA, RE	Indicates a Dilution, Reanalysis or Reextraction.
EPA	United States Environmental Protection Agency
MDL	Method Detection Limit - an estimate of the minimum amount of a substance that an analytical process can reliably detect. A MDL is analyte- and matrix-specific and may be laboratory-dependent.
ND	Not detected at the reporting limit (or MDL if shown).
QC	Quality Control
RL	Reporting Limit - the minimum levels, concentrations, or quantities of a target variable (e.g., target analyte) that can be reported with a specified degree of confidence.
RPD	Relative Percent Difference - a measure of the relative difference between two points.

Lab Name: EnviroTest Laboratories
Address & Phone: 315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890

PROJECT REFERENCE Washingtonville CSD -High School		PROJECT NO	PROJECT LOCATION		MATERIAL TYPE		REQUIRED ANALYSES						PAGE 1 of 1	
ENVIROTEST PROJECT MANAGER Debra Bayer		P.O. NUMBER	TOWN		OTHER SPECIFY		Terra Core						TURNAROUND TIME	
CLIENT (SITE) PM Jack DeGraw		CLIENT PHONE 845-781-4887	CLIENT FAX		AQUEOUS (WATER)		250ml Plastic Sulfuric Acid						NORMAL	
CLIENT NAME Orange-Ulster BOCES		christy.fischer@oubooces.org		COMPOSITE (C) OR GRAB (G) INDICATE		40ml Vials HCl						QUICK		
CLIENT ADDRESS 53 Gibson Road, Goshen, NY 10924				SOLID OR SEMISOLID		250ml Plastic Nitric Acid						VERBAL		
COMPANY CONTRACTING THIS WORK (if applicable)				OTHER SPECIFY		250ml Plastic Sulfuric Acid						#OF COOLERS		
SAMPLE		TIME		SAMPLE IDENTIFICATION		NUMBER OF CONTAINERS SUBMITTED						REMARKS		
10/22/2016	0600	Outside Faucet receiving		1						Lead (DW 200.8)				
10/22/2016	0603	Hose Biv next to Ice Machine (right)		1						Lead (DW 200.8)				
10/22/2016	0608	Room 117 sink		1						Lead (DW 200.8)				
10/22/2016	0609	Room 116 left sink		1						Lead (DW 200.8)				
10/22/2016	0609	Room 116 right sink		1						Lead (DW 200.8)				
10/22/2016	0611	Room 112 Men's bathroom sink		1						Lead (DW 200.8)				
10/22/2016	0611	Room 112 Women's bathroom sink		1						Lead (DW 200.8)				
10/22/2016	0612	Room 109 Island sink front		1						Lead (DW 200.8)				
10/22/2016	0612	Room 109 Island sink back		1						Lead (DW 200.8)				
10/22/2016	0615	Room 109 Dark Room left sink w/hose		1						Lead (DW 200.8)				
10/22/2016	0615	Room 109 Dark Room right sink		1						Lead (DW 200.8)				
10/22/2016	0617	Room 107 Island sink Front		1						Lead (DW 200.8)				
10/22/2016	0617	Room 107 Island sink Back		1						Lead (DW 200.8)				
RELINQUISHED BY: (SIGNATURE)		DATE	TIME		RECEIVED BY: (SIGNATURE)		COMPANY DATE TIME							
SAMPLED BY: (SIGNATURE)		DATE	TIME		RECEIVED BY: (SIGNATURE)		COMPANY DATE TIME							
RELINQUISHED BY: (SIGNATURE)		DATE	TIME		RECEIVED BY: (SIGNATURE)		COMPANY DATE TIME							
RECEIVED FOR LABORATORY BY: (SIGNATURE)		DATE	TIME		COOLER TEMP (C):		LABORATORY REMARKS: ICE (Y/N) pH CL2							
10/27/16 1030		10/27/16 1030		14.0		12#3								

Lab Name
EnviroTest Laboratories
Address & Phone
315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890

PROJECT REFERENCE Washingtonville CSD - High School		PROJECT NO P.O. NUMBER	PROJECT LOCATION TOWN		MATRIX TYPE		REQUIRED ANALYSES						PAGE 1 of 1	
ENVIROTEST PROJECT MANAGER Debra Bayer		CLIENT PHONE 845-781-4887	CLIENT FAX		OTHER SPECIFY		40ml Vials HCl	250ml Plastic Nitric Acid	250ml Plastic Sulfuric Acid	Liter Plastic	250ml Plastic	Terra Core	Other	
CLIENT (SITE) PM Jack DeGraw		CLIENT NAME Orange-Ulster BOCES		christy.fischer@oubooces.org		COMPOSITE (C) OR GRAB (G) INDICATE		TURNAROUND TIME						
CLIENT ADDRESS 53 Gibson Road, Goshen, NY 10924		SAMPLE IDENTIFICATION		DATE		TIME		NORMAL						
COMPANY CONTRACTING THIS WORK (if applicable)		SAMPLE		DATE		TIME		QUICK						
		10/22/2016		0617				VERBAL						
		10/22/2016		0617				#OF COOLERS						
		10/22/2016		0619				REMARKS						
		10/22/2016		0620				Lead (DW 200.8)						
		10/22/2016		0621				Lead (DW 200.8)						
		10/22/2016		0621				Lead (DW 200.8)						
		10/22/2016		0622				Lead (DW 200.8)						
		10/22/2016		0622				Lead (DW 200.8)						
		10/22/2016		0624				Lead (DW 200.8)						
		10/22/2016		0625				Lead (DW 200.8)						
		10/22/2016		0625				Lead (DW 200.8)						
		10/22/2016		0626				Lead (DW 200.8)						
		10/22/2016		0627				Lead (DW 200.8)						
		10/22/2016		0629				Lead (DW 200.8)						
RELINQUISHED BY: (SIGNATURE) <i>Christy Fischer</i>		COMPANY oubooces		DATE 10/27/16		TIME 1030		RECEIVED BY: (SIGNATURE)						
SAMPLED BY: (SIGNATURE) <i>Matthew Dehert</i>		COMPANY oubooces		DATE 10/22/16		TIME 1000		RECEIVED BY: (SIGNATURE)						
RELINQUISHED BY: (SIGNATURE)		COMPANY		DATE		TIME		RECEIVED BY: (SIGNATURE)						

RECEIVED FOR LABORATORY BY: (SIGNATURE) <i>Debra Bayer</i>	DATE 10/27/16	TIME 1530	CUSTODY INTACT YES NO	Cooler Temp(C): 14.0	LABORATORY REMARKS: ICE (Y/N) pH CL2 Reviewed by
---	------------------	--------------	-----------------------------	-------------------------	--

EnviroTest Laboratories, Inc.

Lab Name: EnviroTest Laboratories
Address & Phone: 315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890

CHAIN OF CUSTODY

112382

REPORT# (Lab Use Only)

933820

PROJECT REFERENCE Washingtonville CSD - High School		PROJECT LOCATION TOWN		MATRIX TYPE		REQUIRED ANALYSES		PAGE 1 of 1	
ENVIROTEST PROJECT MANAGER Debra Bayer		CLIENT PHONE 845-781-4887		CLIENT FAX		40ml Vials HCl 1 Liter Amber HCl 250ml Plastic Nitric Acid 250ml Plastic Sulfuric Acid 1 Liter Plastic 250ml Plastic Terra Core Other Other		TURNAROUND TIME	
CLIENT (SITE) PM Jack DeGraw		CLIENT NAME Orange-Ulster BOCES		christy.fischer@oubooces.org				NORMAL	
CLIENT ADDRESS 53 Gibson Road, Goshen, NY 10924								QUICK	
COMPANY CONTACTING THIS WORK (if applicable)								VERBAL	

DATE	TIME	SAMPLE IDENTIFICATION	COMPOSITE (C) OR GRAB (G) INDICATE	AQUEOUS (WATER)	D (Drinking Water) or V (Waste Water) Indicate	OTHER Specify	NUMBER OF CONTAINERS SUBMITTED								REMARKS
							1	1	1	1	1	1	1	1	
10/22/2016	0630	Room 162 sink #1	G	D			1							Lead (DW 200.8)	
10/22/2016	0630	Room 162 sink #2	G	D			1							Lead (DW 200.8)	
10/22/2016	0630	Room 162 sink #3	G	D			1							Lead (DW 200.8)	
10/22/2016	0630	Room 162 sink #4	G	D			1							Lead (DW 200.8)	
10/22/2016	0632	157-Girl's locker room bathroom left	G	D			1							Lead (DW 200.8)	
10/22/2016	0636	159A - P.E. office bathroom sink	G	D			1							Lead (DW 200.8)	
10/22/2016	0639	Kitchen serving line sink by 164	G	D			1							Lead (DW 200.8)	
10/22/2016	0640	Kitchen Island sink	G	D			1							Lead (DW 200.8)	
10/22/2016	0641	Kitchen steam table sprayer	G	D			1							Lead (DW 200.8)	
10/22/2016	0642	Kitchen 3-Bay left sink	G	D			1							Lead (DW 200.8)	
10/22/2016	0642	Kitchen 3-Bay sink (sprayer)	G	D			1							Lead (DW 200.8)	
10/22/2016	0642	Kitchen 3-Bay right sink	G	D			1							Lead (DW 200.8)	
10/22/2016	0643	Kitchen hand washing sink	G	D			1							Lead (DW 200.8)	

RELINQUISHED BY (SIGNATURE)
Travis P. Dehart

SAMPLED BY (SIGNATURE)
Travis P. Dehart

RELINQUISHED BY (SIGNATURE)
Travis P. Dehart

DATE
10/27/16

DATE
10/27/16

DATE
10/27/16

COMPANY
oubooces

COMPANY
oubooces

COMPANY
oubooces

RECEIVED FOR LABORATORY (SIGNATURE)
Debra Bayer

DATE
10/27/16

CUSTODY INTACT
YES
NO

LABORATORY REMARKS: ICE (V) _____ pH _____ CL2 _____

COOLER TEMP (C): 14.0

REVIEWED BY: 10-27-16

Lab Name
Address & Phone
EnviroTest Laboratories
315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890

PROJECT REFERENCE Washingtonville CSD - High School		PROJECT NO	MATRIX TYPE		REQUIRED ANALYSES		PAGE 1 of 1	
ENVIROTEST PROJECT MANAGER Debra Bayer		P.O. NUMBER	TOWN		250ml Plastic		TURNAROUND TIME	
CLIENT (SITE) PM Jack DeGraw		CLIENT PHONE 845-781-4887	CLIENT FAX		Liter Plastic		NORMAL	
CLIENT NAME Orange-Ulster BOCES		christy.fischer@oubooces.org		250ml Plastic Nitric Acid		QUICK		
CLIENT ADDRESS 53 Gibson Road, Goshen, NY 10924				Liter Amber HCl		VERBAL		
COMPANY CONTRACTING THIS WORK (if applicable)				40ml Vials HCl				
SAMPLE IDENTIFICATION		COMPOSITE (C) OR GRAB (G) INDICATE		OTHER SPECIFY		# OF COOLERS		
DATE	TIME					REMARKS		
10/22/2016	0643	Kitchen Bathroom sink		D		Lead (DW 200.8)		
10/22/2016	0644	Kitchen Serving line sink by 166		D		Lead (DW 200.8)		
10/22/2016	0648	168 - Food Prep sink		D		Lead (DW 200.8)		
10/22/2016	0648	168 - Hand wash sink		D		Lead (DW 200.8)		
10/22/2016	0649	168 - Food Serving line Faucet		D		Lead (DW 200.8)		
10/22/2016	0651	170D - Bathroom sink		D		Lead (DW 200.8)		
10/22/2016	0651	171 Sink		D		Lead (DW 200.8)		
10/22/2016	0653	Hall drinking fountain by 180		D		Lead (DW 200.8)		
10/22/2016	0655	Faculty Men's Bathroom by 180 (right)		D		Lead (DW 200.8)		
10/22/2016	0655	Faculty Men's Bathroom by 180 (left)		D		Lead (DW 200.8)		
10/22/2016	0656	Woman's Faculty Bathroom by 180 (right)		D		Lead (DW 200.8)		
10/22/2016	0656	Woman's Faculty Bathroom by 180 (left)		D		Lead (DW 200.8)		
10/22/2016	0658	Girl's bathroom by 182 sink #1 from left		D		Lead (DW 200.8)		
RELINQUISHED BY (SIGNATURE)		DATE	TIME		COMPANY		RECEIVED BY (SIGNATURE)	
[Signature]		10/27/16	1030		BOCES		[Signature]	
SAMPLED BY (SIGNATURE)		DATE	TIME		COMPANY		RECEIVED BY (SIGNATURE)	
[Signature]		10/27/16	1030		BOCES		[Signature]	
RELINQUISHED BY (SIGNATURE)		DATE	TIME		COMPANY		RECEIVED BY (SIGNATURE)	
[Signature]		10/27/16	1030		BOCES		[Signature]	

RECEIVED FOR LABORATORY BY (SIGNATURE)	DATE	TIME	CUSTODY INTACT	COOLER TEMP (C)	LABORATORY REMARKS	ICE Y N	pH	CL2	Reviewed by
[Signature]	10/27/16	1030	YES	14.0					

[illegible]

EnviroTest Laboratories, Inc.

Lab Name: **EnviroTest Laboratories**
Address & Phone: **315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890**

CHAIN OF CUSTODY

112382

REPORT# (Lab Use Only)

pg 6 of 20

PROJECT REFERENCE Washingtonville CSD - High School		PROJECT NO	PROJECT LOCATION		MATRIX TYPE	REQUIRED ANALYSES					PAGE 1 of 1
ENVIROTEST PROJECT MANAGER Debra Bayer		P.O. NUMBER	TOWN		OTHER SPECIFY	☐ 40ml Vials HCl ☐ 250ml Plastic Nitric Acid ☐ 250ml Plastic Sulfuric Acid ☐ 250ml Plastic ☐ Terra Core ☐ Other					TURNAROUND TIME
CLIENT (SITE) PM Jack DeGraw		CLIENT PHONE 845-781-4887	CLIENT FAX								
CLIENT NAME Orange-Ulster BOCES		christy.fischer@oubooces.org									
CLIENT ADDRESS 53 Gibson Road, Goshen, NY 10924											
COMPANY CONTRACTING THIS WORK (If applicable)											

SAMPLE	SAMPLE IDENTIFICATION		COMPOSITE (C) OR GRAB (G) INDICATE	AQUEOUS (WATER)	SOLID OR SEMISOLID	OTHER SPECIFY	NUMBER OF CONTAINERS SUBMITTED								REMARKS
	DATE	TIME					Total # of Containers	40ml Vials HCl	250ml Plastic Nitric Acid	250ml Plastic Sulfuric Acid	Liter Plastic	250ml Plastic	Terra Core	Other	
66	10/22/2016	0717	G				1						Lead (DW 200.8)		
67	10/22/2016	0717	G				1						Lead (DW 200.8)		
68	10/22/2016	0717	G				1						Lead (DW 200.8)		
69	10/22/2016	0723	G				1						Lead (DW 200.8)		
70	10/22/2016	0723	G				1						Lead (DW 200.8)		
71	10/22/2016	0724	G				1						Lead (DW 200.8)		
72	10/22/2016	0724	G				1						Lead (DW 200.8)		
73	10/22/2016	0726	G				1						Lead (DW 200.8)		
74	10/22/2016	0726	G				1						Lead (DW 200.8)		
75	10/22/2016	0726	G				1						Lead (DW 200.8)		
76	10/22/2016	0728	G				1						Lead (DW 200.8)		
77	10/22/2016	0731	G				1						Lead (DW 200.8)		
78	10/22/2016	0731	G				1						Lead (DW 200.8)		

RELINQUISHED BY: (SIGNATURE) *[Signature]*

SAMPLED BY: (SIGNATURE) *[Signature]*

RELINQUISHED BY: (SIGNATURE) *[Signature]*

DATE: 10/27/16

DATE: 10/27/16

DATE: 10/27/16

COMPANY: **oubooces**

COMPANY: **oubooces**

COMPANY: **oubooces**

RECEIVED FOR LABORATORY BY: (SIGNATURE) *[Signature]*

DATE: 10/27/16

TIME: 1030

CUSTODY INTACT: YES

COOLER TEMP (C): 14.0

LABORATORY REMARKS: ICE N/A pH CL2

Reveled by: *[Signature]*

Reveled by: *[Signature]*

EnviroTest Laboratories
315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890

Lab Name
Address & Phone

PROJECT REFERENCE Washingtonville CSD - High School		PROJECT NO		PROJECT LOCATION		MATRIX TYPE		REQUIRED ANALYSES								PAGE 1 of 1	
ENVIROTEST PROJECT MANAGER Debra Bayer		P.O. NUMBER		TOWN		OTHER SPECIFY		40ml Vials HCl 250ml Plastic Nitric Acid 250ml Plastic Sulfuric Acid Liter Plastic 250ml Plastic Terra Core Other Other								TURNAROUND TIME	
CLIENT (SITE) PM Jack DeGraw		CLIENT PHONE 845-781-4887		CLIENT FAX		COMPOSITE (C) OR GRAB (G) INDICATE		40ml Vials HCl 250ml Plastic Nitric Acid 250ml Plastic Sulfuric Acid Liter Plastic 250ml Plastic Terra Core Other Other								NORMAL	
CLIENT NAME Orange-Ulster BOCES		christy.fischer@oubooces.org				AQUEOUS (WATER)		40ml Vials HCl 250ml Plastic Nitric Acid 250ml Plastic Sulfuric Acid Liter Plastic 250ml Plastic Terra Core Other Other								QUICK	
CLIENT ADDRESS 53 Gibson Road, Goshen, NY 10924						SOLID OR SEMISOLID		40ml Vials HCl 250ml Plastic Nitric Acid 250ml Plastic Sulfuric Acid Liter Plastic 250ml Plastic Terra Core Other Other								VERBAL	
COMPANY CONTRACTING THIS WORK (if applicable)														#OF COOLERS			
SAMPLE		DATE		TIME		SAMPLE IDENTIFICATION		NUMBER OF CONTAINERS SUBMITTED								REMARKS	
10/22/2016		0732				Room 121 Sink #2		1								Lead (DW 200.8)	
10/22/2016		0732				Room 121 Sink #3		1								Lead (DW 200.8)	
10/22/2016		0732				Room 123 sink		1								Lead (DW 200.8)	
10/22/2016		0736				2nd Floor Gold wing girl's gang bathroom #1		1								Lead (DW 200.8)	
10/22/2016		0737				2nd Floor Gold wing girl's gang bathroom #2		1								Lead (DW 200.8)	
10/22/2016		0737				2nd Floor Gold wing girl's gang bathroom #3		1								Lead (DW 200.8)	
10/22/2016		0739				2nd Floor water fountain by 216		1								Lead (DW 200.8)	
10/22/2016		0740				2nd Floor gold wing boy's gang bathroom #1		1								Lead (DW 200.8)	
10/22/2016		0740				2nd Floor gold wing boy's gang bathroom #2		1								Lead (DW 200.8)	
10/22/2016		0741				2nd Floor gold wing boy's gang bathroom #3		1								Lead (DW 200.8)	
10/22/2016		0743				Water Fountain by 202		1								Lead (DW 200.8)	
10/22/2016		0747				2nd Floor Blue wing Boy's gang bathroom #1		1								Lead (DW 200.8)	
10/22/2016		0747				2nd Floor Blue wing Boy's gang bathroom #2		1								Lead (DW 200.8)	
RELINQUISHED BY (SIGNATURE)		DATE		TIME		COMPANY		RECEIVED BY (SIGNATURE)								TIME	
[Signature]		10/27/16		1030		OUBOCES		RECEIVED BY (SIGNATURE)								TIME	
SAMPLE BY (SIGNATURE)		DATE		TIME		COMPANY		RECEIVED BY (SIGNATURE)								TIME	
[Signature]		10/27/16		1000		OUBOCES		RECEIVED BY (SIGNATURE)								TIME	
RELINQUISHED BY (SIGNATURE)		DATE		TIME		COMPANY		RECEIVED BY (SIGNATURE)								TIME	
[Signature]		10/27/16		1000		OUBOCES		RECEIVED BY (SIGNATURE)								TIME	

LABORATORY REMARKS: ICE (Y/N) pH CL2 Reviewed by

Cooler Temp (C): 14.0

RECEIVED FOR LABORATORY BY (SIGNATURE)

4c1
e07
107
001
001
9b
72
9b
4b
9b
9b
9b
9b
9b



EnviroTest Laboratories, Inc.

CHAIN OF CUSTODY

112382

REPORT# (Lab Use Only)

Lab Name: EnviroTest Laboratories
Address & Phone: 315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890

PROJECT REFERENCE		PROJECT NO	PROJECT LOCATION	MATRIX TYPE	REQUIRED ANALYSES								PAGE 1 of 1	
Washingtonville CSD - High School		P.O. NUMBER	TOWN	OTHER SPECIFY	40ml Vials HCl	Liter Amber HCl	250ml Plastic Nitric Acid	250ml Plastic Sulfuric Acid	Liter Plastic	250ml Plastic	Terra Core	Other	Other	
ENVIROTEST PROJECT MANAGER		CLIENT PHONE	CLIENT FAX	COMPOSITE (C) OR GRAB (G) INDICATE	NUMBER OF CONTAINERS SUBMITTED								TURNAROUND TIME	
Debra Bayer		845-781-4887												
CLIENT (SITE) PM		CLIENT NAME		SAMPLE IDENTIFICATION		REMARKS								
Jack DeGraw		Orange-Ulster BOCES		DATE										
Orange-Ulster BOCES		christy.fischer@outboces.org		TIME										
CLIENT ADDRESS		53 Gibson Road, Goshen, NY 10924												
COMPANY CONTRACTING THIS WORK (if applicable)														
105	10/22/2016	0801	243 - Pool locker room bathroom (left)	G	D	1	1	1	1	1	1	1	1	Lead (DW 200.8)
106	10/22/2016	0801	243 - Pool locker room bathroom (right)	G	D	1	1	1	1	1	1	1	1	Lead (DW 200.8)
107	10/22/2016	0803	247 - Boy's pool bathroom locker room (left)	G	D	1	1	1	1	1	1	1	1	Lead (DW 200.8)
108	10/22/2016	0804	247 - Boy's pool bathroom locker room (right)	G	D	1	1	1	1	1	1	1	1	Lead (DW 200.8)
109	10/22/2016	0805	247 - Boy's pool locker room water fountain	G	D	1	1	1	1	1	1	1	1	Lead (DW 200.8)
110	10/22/2016	0809	Girl's pool coaches office bathroom sink	G	D	1	1	1	1	1	1	1	1	Lead (DW 200.8)
111	10/22/2016	0810	Boy's pool coaches bathroom sink	G	D	1	1	1	1	1	1	1	1	Lead (DW 200.8)
112	10/22/2016	0815	3rd Floor Blue wing Boy's gang bathroom #1	G	D	1	1	1	1	1	1	1	1	Lead (DW 200.8)
113	10/22/2016	0815	3rd Floor Blue wing Boy's gang bathroom #2	G	D	1	1	1	1	1	1	1	1	Lead (DW 200.8)
114	10/22/2016	0815	3rd Floor Blue wing Boy's gang bathroom #3	G	D	1	1	1	1	1	1	1	1	Lead (DW 200.8)
115	10/22/2016	0816	3rd Floor Blue wing Boy's gang bathroom #4	G	D	1	1	1	1	1	1	1	1	Lead (DW 200.8)
116	10/22/2016	0817	3rd Floor Blue wing Boy's gang bathroom #5	G	D	1	1	1	1	1	1	1	1	Lead (DW 200.8)
117	10/22/2016	0818	3rd Floor Blue wing Faculty bathroom on left	G	D	1	1	1	1	1	1	1	1	Lead (DW 200.8)
RELINQUISHED BY: (SIGNATURE)				DATE	TIME	RECEIVED BY: (SIGNATURE)		DATE		TIME		COMPANY		
<i>[Signature]</i>				10/27/16	1030	<i>[Signature]</i>		10/27/16		1000		COMPANY		
SAMPLED BY: (SIGNATURE)				DATE	TIME	RECEIVED BY: (SIGNATURE)		DATE		TIME		COMPANY		
<i>[Signature]</i>				10/27/16	1000	<i>[Signature]</i>		10/27/16		1000		COMPANY		
RELINQUISHED BY: (SIGNATURE)				DATE	TIME	RECEIVED BY: (SIGNATURE)		DATE		TIME		COMPANY		
<i>[Signature]</i>				10/27/16	1030	<i>[Signature]</i>		10/27/16		1000		COMPANY		

RECEIVED FOR LABORATORY BY: (SIGNATURE)	DATE	TIME	CUSTODY INTACT	Cooler Temp (C):	LABORATORY REMARKS:	ICE (Y/N)	pH	CL2	Revised by:
<i>[Signature]</i>	10/27/16	1030	YES	14.0					

EnviroTest Laboratories
315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890

PROJECT REFERENCE Washingtonville CSD - High School		PROJECT LOCATION TOWN		MATRIX TYPE		REQUIRED ANALYSES		PAGE 1 of 1	
ENVIROTEST PROJECT MANAGER Debra Bayer		CLIENT PHONE 845-781-4887		COMPOSITE (C) OR GRAB (G) INDICATE		250ml Plastic Nitric Acid		TURNAROUND TIME	
CLIENT (SITE) PM Jack DeGraw		CLIENT FAX		AQUEOUS (WATER)		250ml Plastic Sulfuric Acid		NORMAL	
CLIENT NAME Orange-Ulster BOCES		christy.fischer@oubooces.org		D (Drinking Water) or W (Waste Water) Indicate		40ml Vials HCl		QUICK	
CLIENT ADDRESS 53 Gibson Road, Goshen, NY 10824				OTHER Specify		Liter Amber HCl		VERBAL	
COMPANY CONTRACTING THIS WORK (If applicable)						Total # of Containers		# OF COOLERS	
SAMPLE IDENTIFICATION		SAMPLE		DATE		NUMBER OF CONTAINERS SUBMITTED		REMARKS	
10/22/2016 0819 3rd Floor Blue Wing Faculty bathroom on right		G		D		1		Lead (DW 200.8)	
10/22/2016 0820 3rd Floor Water Fountain by 332 on left		G		D		1		Lead (DW 200.8)	
10/22/2016 0820 3rd Floor water Fountain by 332 on right		G		D		1		Lead (DW 200.8)	
10/22/2016 0821 3rd Floor Blue Wing girl's gang bathroom #1		G		D		1		Lead (DW 200.8)	
10/22/2016 0821 3rd Floor Blue Wing girl's gang bathroom #2		G		D		1		Lead (DW 200.8)	
10/22/2016 0822 3rd Floor Blue Wing girl's gang bathroom #3		G		D		1		Lead (DW 200.8)	
10/22/2016 0822 3rd Floor Blue Wing girl's gang bathroom #4		G		D		1		Lead (DW 200.8)	
10/22/2016 0823 3rd Floor Blue Wing girl's gang bathroom #5		G		D		1		Lead (DW 200.8)	
10/22/2016 0827 343 - Boy's bathroom (right)		G		D		1		Lead (DW 200.8)	
10/22/2016 0827 343 - Boy's bathroom (left)		G		D		1		Lead (DW 200.8)	
10/22/2016 0828 343 - water fountain		G		D		1		Lead (DW 200.8)	
10/22/2016 0828 343 - girl's bathroom (right)		G		D		1		Lead (DW 200.8)	
10/22/2016 0828 343 - girl's bathroom (left)		G		D		1		Lead (DW 200.8)	
RELINQUISHED BY (SIGNATURE) [Signature]		DATE 10/27/16		TIME 1030		RECEIVED BY (SIGNATURE)		COMPANY DATE	
SAMPLED BY (SIGNATURE) [Signature]		DATE 10/27/16		TIME 1000		RECEIVED BY (SIGNATURE)		COMPANY DATE	
RELINQUISHED BY (SIGNATURE) [Signature]		DATE 10/27/16		TIME 1000		RECEIVED BY (SIGNATURE)		COMPANY DATE	

EnviroTest Laboratories, Inc.

CHAIN OF CUSTODY

Lab Name
Address & Phone
EnviroTest Laboratories
315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890

REPORT# (Lab Use Only)

112382

93120820

PROJECT REFERENCE Washingtonville CSD -High School		PROJECT NO		PROJECT LOCATION		MATRIX TYPE		REQUIRED ANALYSES						PAGE 1 of 1	
ENVIROTEST PROJECT MANAGER Debra Bayer		P.O. NUMBER		TOWN		D (Drinking Water) or V (Waste Water) Indicate		250ml Plastic Nitric Acid		250ml Plastic Sulfuric Acid		250ml Plastic		Terra Core	
CLIENT (SITE) PM Jack DeGraw		CLIENT PHONE 845-781-4887		CLIENT FAX		AQUEOUS (WATER)		40ml Amber HCl		250ml Plastic Nitric Acid		250ml Plastic		Other	
CLIENT NAME Orange-Ulster BOCES		christv.fischer@oubooces.org				COMPOSITE (C) OR GRAB (G) INDICATE		Total # of Containers		40ml Amber HCl		250ml Plastic Nitric Acid		Other	
CLIENT ADDRESS 53 Gibson Road, Goshen, NY 10924										250ml Plastic Sulfuric Acid		250ml Plastic		Other	
COMPANY CONTRACTING THIS WORK (if applicable)															
SAMPLE		TIME		SAMPLE IDENTIFICATION											
DATE		TIME													
10/22/2016		0900		Room 328 sink #9		G		1		1		1		Lead (DW 200.8)	
10/22/2016		0900		Room 328 sink #10		G		1		1		1		Lead (DW 200.8)	
10/22/2016		0900		Room 328 sink #11		G		1		1		1		Lead (DW 200.8)	
10/22/2016		0901		Room 328 sink #12		G		1		1		1		Lead (DW 200.8)	
10/22/2016		0905		Room 334 sink #1		G		1		1		1		Lead (DW 200.8)	
10/22/2016		0906		Room 334 sink #2		G		1		1		1		Lead (DW 200.8)	
10/22/2016		0905		Room 334 sink #3		G		1		1		1		Lead (DW 200.8)	
10/22/2016		0906		Room 334 sink #4		G		1		1		1		Lead (DW 200.8)	
10/22/2016		0906		Room 334 sink #5		G		1		1		1		Lead (DW 200.8)	
10/22/2016		0906		Room 334 sink #6		G		1		1		1		Lead (DW 200.8)	
10/22/2016		0907		Room 334 sink #7		G		1		1		1		Lead (DW 200.8)	
10/22/2016		0907		Room 334 sink #8		G		1		1		1		Lead (DW 200.8)	
10/22/2016		0907		Room 334 sink #9		G		1		1		1		Lead (DW 200.8)	
RELINQUISHED BY (SIGNATURE)		DATE		COMPANY		TIME		RECEIVED BY (SIGNATURE)		DATE		COMPANY		TIME	
[Signature]		10/27/16		OUBOCES		1030		[Signature]		10/27/16		OUBOCES		1030	
SAMPLED BY (SIGNATURE)		DATE		COMPANY		TIME		RECEIVED BY (SIGNATURE)		DATE		COMPANY		TIME	
[Signature]		10/22/16		OUBOCES		1000		[Signature]		10/22/16		OUBOCES		1000	
RELINQUISHED BY (SIGNATURE)		DATE		COMPANY		TIME		RECEIVED BY (SIGNATURE)		DATE		COMPANY		TIME	
[Signature]		10/27/16		OUBOCES		1030		[Signature]		10/27/16		OUBOCES		1030	

RECEIVED FOR LABORATORY BY: (SIGNATURE) DATE TIME CUSTODY INTACT YES NO COOLER TEMP(C): 14.0 pH 7.0

[illegible]

EnviroTest Laboratories, Inc.

CHAIN OF CUSTODY

112382

REPORT# (Lab Use Only)

Lab Name
Address & Phone

EnviroTest Laboratories
315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890

PROJECT REFERENCE Washingtonville CSD -High School		PROJECT LOCATION		MATERIAL TYPE		REQUIRED ANALYSES		PAGE 1 of 1	
ENVIROTEST PROJECT MANAGER Debra Bayer		TOWN		OTHER SPECIFY		Other			
CLIENT (SITE) PM Jack DeGraw		CLIENT PHONE 845-781-4887		CLIENT FAX		250ml Plastic Sulfuric Acid		TURNAROUND TIME	
CLIENT NAME Orange-Ulster BOCES		christy.fischer@oubooces.org				250ml Plastic Nitric Acid		NORMAL	
CLIENT ADDRESS 53 Gibson Road, Goshen, NY 10924						40ml Vials HCl		QUICK	
COMPANY CONTRACTING THIS WORK (if applicable)						250ml Plastic Sulfuric Acid		VERBAL	
						250ml Plastic Nitric Acid			
						Liter Amber HCl			
						Liter Plastic			
						250ml Plastic Sulfuric Acid			
						250ml Plastic Nitric Acid			
						Liter Plastic			
						Terra Core			
						Other			
						Other			

DATE	TIME	SAMPLE IDENTIFICATION	COMPOSITE (C) OR GRAB (G) INDICATE		AQUEOUS (WATER)		D (Drinking Water) or W (Waste Water) Indicate		OTHER SPECIFY	NUMBER OF CONTAINERS SUBMITTED	# OF COOLERS	REMARKS
			C	G	W	D	W	D				
10/22/2016	0801	Room 311 Island sink	G							1		Lead (DW 200.8)
10/22/2016	0801	Room 311 Back wall sink #1	G							1		Lead (DW 200.8)
10/22/2016	0801	Room 301 Right Wall sink #2	G							1		Lead (DW 200.8)
10/22/2016	0804	Room 312 Island sink	G							1		Lead (DW 200.8)
10/22/2016	0804	Room 312 Left sink	G							1		Lead (DW 200.8)
10/22/2016	0806	Room 309 sink	G							1		Lead (DW 200.8)
10/22/2016	0807	Room 310 Front left sink #1	G							1		Lead (DW 200.8)
10/22/2016	0807	Room 310 Front left sink #2	G							1		Lead (DW 200.8)
10/22/2016	0807	Room 310 Front Right sink #1	G							1		Lead (DW 200.8)
10/22/2016	0807	Room 310 Front Right sink #2	G							1		Lead (DW 200.8)
10/22/2016	0809	Room 310 Back Center Sink #1	G							1		Lead (DW 200.8)
10/22/2016	0809	Room 310 Back Center Sink #2	G							1		Lead (DW 200.8)
10/22/2016	0809	Room 310 Back Right sink #1	G							1		Lead (DW 200.8)

RELINQUISHED BY (SIGNATURE)	DATE	TIME	RECEIVED BY (SIGNATURE)	DATE	TIME
<i>[Signature]</i>	10/27/16	1030			
SAMPLED BY (SIGNATURE)	DATE	TIME	RECEIVED BY (SIGNATURE)	DATE	TIME
<i>Matthew O. DeGraw</i>	10/22/16	1000			
RELINQUISHED BY (SIGNATURE)	DATE	TIME	RECEIVED BY (SIGNATURE)	DATE	TIME

RECEIVED FOR LABORATORY BY (SIGNATURE)	DATE	TIME	CUSTODY INTACT YES NO	COOLER TEMP (C)	LABORATORY REMARKS
<i>[Signature]</i>	10/27/16	1030	YES	14.0	ICE (Y) N () pH () CL2 ()

Lab Name
Address & Phone
EnviroTest Laboratories
315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890

PAGE 1 of 1
12382

PROJECT REFERENCE	PROJECT NO	PROJECT LOCATION	MATRIX TYPE	REQUIRED ANALYSES	TURNAROUND TIME
Washingtonville CSD - High School	P.O. NUMBER	TOWN	OTHER SPECIFY	Other	
Debra Bayer	CLIENT PHONE	CLIENT FAX	OTHER SPECIFY	Other	
Jack DeGraw	845-781-4887		OTHER SPECIFY	Other	
Orange-Ulster BOCES	christy.fischer@oubooces.org		OTHER SPECIFY	Other	
CLIENT ADDRESS					
53 Gibson Road, Goshen, NY 10924					
COMPANY CONTRACTING THIS WORK (If applicable)					
SAMPLE	DATE	TIME	SAMPLE IDENTIFICATION	COMPOSITE (C) OR GRAB (G) INDICATE	NUMBER OF CONTAINERS SUBMITTED
10/22/2016	0809		Room 310 Back Right sink #2	G	1
10/22/2016	0811		Room 310 Back Left sink #1	G	1
10/22/2016	0811		Room 310 Back Left sink #2	G	1
10/22/2016	0813		Room 310 Right wall sink	G	1
10/22/2016	0813		Room 310 Back wall right sink	G	1
10/22/2016	0813		Room 310 Back wall left sink	G	1
10/22/2016	0815		Room 309 Island sink	G	1
10/22/2016	0815		Room 309 Left 1 Front sink	G	1
10/22/2016	0815		Room 309 Left 2 Front sink	G	1
10/22/2016	0815		Room 309 Left 1 Back sink	G	1
10/22/2016	0815		Room 309 Left 2 Back sink	G	1
10/22/2016	0815		Room 309 Left 3 Front sink	G	1
10/22/2016	0815		Room 309 Left 3 Back sink	G	1
RELINQUISHED BY (SIGNATURE) DATE TIME RECEIVED BY (SIGNATURE) COMPANY DATE TIME					
RELINQUISHED BY (SIGNATURE) DATE TIME RECEIVED BY (SIGNATURE) COMPANY DATE TIME					
RELINQUISHED BY (SIGNATURE) DATE TIME RECEIVED BY (SIGNATURE) COMPANY DATE TIME					

RECEIVED FOR LABORATORY BY (SIGNATURE)	DATE	TIME	CUSTODY INTACT	COOLER TEMP (C)	LABORATORY REMARKS
10/27/16	1030	YES	14.0	ICE (Y/N) pH	CL2
10/27/16	1030	NO			

CHAIN OF CUSTODY

Lab Name: EnviroTest Laboratories
Address & Phone: 315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890

REPORT# (Lab Use Only)

PROJECT REFERENCE Washingtonville CSD - High School		PROJECT LOCATION TOWN		MATRIX TYPE		REQUIRED ANALYSES		PAGE 1 of 1	
ENVIROTEST PROJECT MANAGER Debra Bayer		CLIENT PHONE 845-781-4887		CLIENT FAX		250ml Plastic Nitric Acid		TURNAROUND TIME	
CLIENT (SITE) PM Jack DeGraw		CLIENT NAME Orange-Ulster BOCES		christy.fischer@outboces.org		250ml Plastic Sulfuric Acid		NORMAL	
CLIENT ADDRESS 53 Gibson Road, Goshen, NY 10924		COMPOSITE (C) OR GRAB (G) INDICATE		OTHER SPECIFY		40ml Vials HCl		QUICK	
COMPANY CONTRACTING THIS WORK (If applicable)		SAMPLE IDENTIFICATION		OTHER SPECIFY		250ml Plastic Amber HCl		VERBAL	
DATE		TIME		TIME		NUMBER OF CONTAINERS SUBMITTED		# OF COOLERS	
10/22/2016	0819	Room 309 Right 4 Front sink	G	D	1	1	1	1	Lead (DW 200.8)
10/22/2016	0819	Room 309 Right 4 Back sink	G	D	1	1	1	1	Lead (DW 200.8)
10/22/2016	0822	Room 309 Right 5 Front sink	G	D	1	1	1	1	Lead (DW 200.8)
10/22/2016	0822	Room 309 Right 5 Back sink	G	D	1	1	1	1	Lead (DW 200.8)
10/22/2016	0822	Room 309 Right 6 Front sink	G	D	1	1	1	1	Lead (DW 200.8)
10/22/2016	0822	Room 309 Right 6 Back sink	G	D	1	1	1	1	Lead (DW 200.8)
10/22/2016	0822	Room 309 sink by door	G	D	1	1	1	1	Lead (DW 200.8)
10/22/2016	0825	Room 307 Front wall sink	G	D	1	1	1	1	Lead (DW 200.8)
10/22/2016	0826	Room 307 sink #1	G	D	1	1	1	1	Lead (DW 200.8)
10/22/2016	0826	Room 307 sink #2	G	D	1	1	1	1	Lead (DW 200.8)
10/22/2016	0826	Room 307 sink #3	G	D	1	1	1	1	Lead (DW 200.8)
10/22/2016	0826	Room 307 sink #4	G	D	1	1	1	1	Lead (DW 200.8)
10/22/2016	0829	Room 307 sink #5	G	D	1	1	1	1	Lead (DW 200.8)
RELINQUISHED BY (SIGNATURE) [Signature]		DATE 10/27/14		TIME 1030		RECEIVED BY (SIGNATURE)		COMPANY DATE	
SAMPLED BY (SIGNATURE) [Signature]		DATE 10/22/16		TIME 1000		RECEIVED BY (SIGNATURE)		COMPANY DATE	
RELINQUISHED BY (SIGNATURE) [Signature]		DATE		TIME		RECEIVED BY (SIGNATURE)		COMPANY DATE	
DATE 10/27/16		TIME 1030		CUSTODY INTACT YES NO		Cooler Temp (C): 104.3		LABORATORY REMARKS: ICE (Y/N) pH CL2	

[illegible]

Lab Name: EnviroTest Laboratories
Address & Phone: 315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890

PROJECT REFERENCE Washingtonville CSD - High School		PROJECT NO.	PROJECT LOCATION		MATRIX TYPE	REQUIRED ANALYSES								PAGE 1 of 1	
ENVIROTEST PROJECT MANAGER Debra Bayer		P.O. NUMBER	TOWN		☐ SOLID OR SEMISOLID ☐ D (Drinking Water) or V (Waste Water) Indicate ☐ AQUEOUS (WATER) ☐ COMPOSITE (C) OR GRAB (G) INDICATE OTHER Specify:	40ml Vials HCl	250ml Plastic Nitric Acid	250ml Plastic Sulfuric Acid	Liter Plastic	250ml Plastic	Terra Core	Other	Other	TURNAROUND TIME	
CLIENT (SITE) PM Jack DeGraw		CLIENT PHONE 845-781-4887	CLIENT FAX			Total # of Containers	Liter Amber HCl	250ml Plastic Nitric Acid	250ml Plastic Sulfuric Acid	Liter Plastic	250ml Plastic	Terra Core	Other		Other
CLIENT NAME Orange-Ulster BOCES		christy.fischer@oubooces.org													
CLIENT ADDRESS 53 Gibson Road, Goshen, NY 10924															
COMPANY CONTRACTING THIS WORK (If applicable)															
SAMPLE		DATE		TIME		SAMPLE IDENTIFICATION		COMPOSITE (C) OR GRAB (G) INDICATE		OTHER Specify		NUMBER OF CONTAINERS SUBMITTED		REMARKS	
235	10/22/2016	0853	Room 303 Back right podium front sink	G	D								1	Lead (DW 200.8)	
236	10/22/2016	0853	Room 303 Back right podium back sink	G	D								1	Lead (DW 200.8)	
237	10/22/2016	0853	Room 303 Lab Hood sink	G	D								1	Lead (DW 200.8)	
238	10/22/2016	0856	Room 302 Island sink	G	D								1	Lead (DW 200.8)	
239	10/22/2016	0856	Room 302 Left podium front sink	G	D								1	Lead (DW 200.8)	
240	10/22/2016	0856	Room 302 Left podium back sink	G	D								1	Lead (DW 200.8)	
241	10/22/2016	0856	Room 302 Back Left podium front sink	G	D								1	Lead (DW 200.8)	
242	10/22/2016	0856	Room 302 Back Left podium back sink	G	D								1	Lead (DW 200.8)	
243	10/22/2016	0856	Room 302 Back Right podium front sink	G	D								1	Lead (DW 200.8)	
244	10/22/2016	0856	Room 302 Back Right podium back sink	G	D								1	Lead (DW 200.8)	
245	10/22/2016	0856	Room 302 Left wall sink	G	D								1	Lead (DW 200.8)	
246	10/22/2016	0859	Water Fountain by 302	G	D								1	Lead (DW 200.8)	
247	10/22/2016	0903	Room 330 sink #1	G	D								1	Lead (DW 200.8)	
RELINQUISHED BY: (SIGNATURE)		DATE		TIME		COMPANY		RECEIVED BY: (SIGNATURE)		DATE		TIME			
[Signature]		10/27/16		1030		oubooces		[Signature]		10/23/16		1000			
SAMPLER BY: (SIGNATURE)		DATE		TIME		COMPANY		RECEIVED BY: (SIGNATURE)		DATE		TIME			
[Signature]		10/23/16		1030		oubooces		[Signature]		10/23/16		1000			
RELINQUISHED BY: (SIGNATURE)		DATE		TIME		COMPANY		RECEIVED BY: (SIGNATURE)		DATE		TIME			
[Signature]		10/23/16		1030		oubooces		[Signature]		10/23/16		1000			

RECEIVED FOR LABORATORY BY: (SIGNATURE)	DATE	TIME	CUSTODY INTACT	COOLER TEMP (C)	LABORATORY REMARKS	ICE (Y/N)	pH	CL2	Revised by
[Signature]	10/27/16	1030	YES	14.0	18th	N			

Lab Name: EnviroTest Laboratories
Address & Phone: 315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890

PROJECT REFERENCE Washingtonville CSD - High School		PROJECT NO. P O NUMBER	MATRIX TYPE	REQUIRED ANALYSES		PAGE 1 of 1	
ENVROTEST PROJECT MANAGER Debra Bayer		TOWN	OTHER SPECIFY	40ml Vials HCl	250ml Plastic Nitric Acid	250ml Plastic Sulfuric Acid	TURNAROUND TIME
CLIENT (SITE) PM Jack DeGraw		CLIENT PHONE 845-781-4887		Liter Plastic	Liter Plastic	250ml Plastic	
CLIENT NAME Orange-Ulster BOCES		CLIENT FAX	OTHER SPECIFY	250ml Plastic Nitric Acid	Liter Plastic	Liter Plastic	QUICK
CLIENT ADDRESS 55 Gibson Road, Goshen, NY 10924		christy.fischer@oupoces.org	OTHER SPECIFY	250ml Plastic Nitric Acid	Liter Plastic	Liter Plastic	VERBAL
COMPANY CONTRACTING THIS WORK (if applicable)				250ml Plastic Nitric Acid	Liter Plastic	Liter Plastic	
SAMPLE IDENTIFICATION		DATE	TIME	NUMBER OF CONTAINERS SUBMITTED		REMARKS	
10/22/2016	0903	Room 330 sink #2		1	1	1	Lead (DW 200.8)
10/22/2016	0903	Room 330 sink #3		1	1	1	Lead (DW 200.8)
10/22/2016	0903	Room 330 sink #4		1	1	1	Lead (DW 200.8)
10/22/2016	0903	Room 330 sink #5		1	1	1	Lead (DW 200.8)
10/22/2016	0903	Room 330 sink #6		1	1	1	Lead (DW 200.8)
10/22/2016	0903	Room 330 sink #7		1	1	1	Lead (DW 200.8)
10/22/2016	0903	Room 330 sink #8		1	1	1	Lead (DW 200.8)
10/22/2016	0903	Room 330 sink #9		1	1	1	Lead (DW 200.8)
10/22/2016	0903	Room 330 sink #10		1	1	1	Lead (DW 200.8)
10/22/2016	0903	Room 330 sink #11		1	1	1	Lead (DW 200.8)
10/22/2016	0903	Room 330 sink #12		1	1	1	Lead (DW 200.8)
10/22/2016	0903	Room 330 sink #13		1	1	1	Lead (DW 200.8)
10/22/2016	0911	Room 336 sink #1		1	1	1	Lead (DW 200.8)
RELINQUISHED BY (SIGNATURE)		DATE	TIME	RECEIVED BY (SIGNATURE)		TIME	
[Signature]		10/27/16	1030	[Signature]		TIME	
COMPANY		DATE	TIME	RECEIVED BY (SIGNATURE)		TIME	
[Signature]		10/27/16	1000	[Signature]		TIME	
COMPANY		DATE	TIME	RECEIVED BY (SIGNATURE)		TIME	
[Signature]		10/27/16	1000	[Signature]		TIME	
COMPANY		DATE	TIME	RECEIVED BY (SIGNATURE)		TIME	
[Signature]		10/27/16	1000	[Signature]		TIME	

RECEIVED FOR LABORATORY BY (SIGNATURE)	DATE	TIME	CUSTODY INTACT	COOLER TEMP (C)	LABORATORY REMARKS
[Signature]	10/27/16	1030	YES	14.2	ICE (Y/N) pH CL2
10/27/16 1030					



**EnviroTest
Laboratories, Inc.**

LOGIN SAMPLE RECEIPT CHECK LIST

Client: Orange-Ulster BOCES

Job Number: 420-112382-1

SDG Number: Washington Ville CSD - High School

Login Number: 112382

Question	T/F/NA	Comment
Samples were collected by ETL employee as per SOP-SAM-1	NA	
The cooler's custody seal, if present, is intact.	NA	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	False	
Cooler Temperature is recorded.	True	14.0 C
Cooler Temp. is within method specified range.(0-6 C PW, 0-8 C NPW, or BAC <10 C	False	
If false, was sample received on ice within 6 hours of collection.	False	
Based on above criteria cooler temperature is acceptable.	True	Method does not require cooling
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the sample IDs on the containers and the COC.	True	
Samples are received within Holding Time.	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
VOA sample vials do not have headspace or bubble is <6mm (1/4") in diameter.	NA	
If necessary, staff have been informed of any short hold time or quick TAT needs	True	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	