

ANALYTICAL REPORT

Job Number: 420-112448-1

SDG Number: Washingtonville CSD - Middle School

Job Description: Orange-Ulster BOCES

For:

Orange-Ulster BOCES

53 Gibson Road

Goshen, NY 10924

Attention: Jack DeGraw



Meredith W Ruthven

Customer Service Manager

mruthven@envirotestlaboratories.com

11/30/2016

NYSDOH ELAP does not certify for all parameters. EnviroTest Laboratories does hold certification for all analytes where certification is offered by ELAP unless otherwise specified in the Certification Information section of this report. Pursuant to NELAP, this report may not be reproduced, except in full, without written approval of the laboratory. EnviroTest Laboratories Inc. certifies that the analytical results contained herein apply only to the samples tested as received by our laboratory. All questions regarding this report should be directed to the EnviroTest Customer Service Representative.

EnviroTest Laboratories, Inc. Certifications and Approvals: NYSDOH 10142, NJDEP NY015, CTDOH PH-0554

Job Narrative
420-J112448-1

Comments

Results are compared to NYSDOH drinking water standards other federal regulations may apply.

No additional comments.

Receipt

All samples were received in good condition within temperature requirements.

Metals

No analytical or quality issues were noted.

METHOD SUMMARY

Client: Orange-Ulster BOCES

Job Number: 420-112448-1
SDG Number: Washingtonville CSD - Middle School

Description	Lab Location	Method	Preparation Method
Matrix: Water			
ICPMS Metals by 200.8	EnvTest	EPA 200.8 Rev.5.4	
200 Series Drinking Water Prep Determination Step	EnvTest		EPA 200

Lab References:

EnvTest = EnviroTest

Method References:

EPA = US Environmental Protection Agency

METHOD / ANALYST SUMMARY

Client: Orange-Ulster BOCES

Job Number: 420-112448-1
SDG Number: Washingtonville CSD - Middle School

Method	Analyst	Analyst ID
EPA 200.8 Rev.5.4	Palentino, Gus J	GJP
EPA 200.8 Rev.5.4	Sirico, Derek	DS

SAMPLE SUMMARY

Client: Orange-Ulster BOCES

Job Number: 420-112448-1
SDG Number: Washingtonville CSD - Middle School

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-112448-1	1 Room 192 Sink	Drinking Water	10/22/2016 0607	10/26/2016 1405
420-112448-2	2 Room 193 Sink	Drinking Water	10/22/2016 0609	10/26/2016 1405
420-112448-3	3 Womens Bathroom by 193 Sink 1	Drinking Water	10/22/2016 0610	10/26/2016 1405
420-112448-4	4 Womens Bathroom by 193 Sink 2	Drinking Water	10/22/2016 0610	10/26/2016 1405
420-112448-5	5 Mens Bathroom by 193 Sink 1	Drinking Water	10/22/2016 0611	10/26/2016 1405
420-112448-6	6 Outside Spigot North Side	Drinking Water	10/22/2016 0612	10/26/2016 1405
420-112448-7	7 Mens Locker Room Sink 1	Drinking Water	10/22/2016 0616	10/26/2016 1405
420-112448-8	8 Mens Locker Room Sink 2	Drinking Water	10/22/2016 0616	10/26/2016 1405
420-112448-9	9 Boys Coaches Bathroom Sink	Drinking Water	10/22/2016 0617	10/26/2016 1405
420-112448-10	10 Cafeteria B Fountain	Drinking Water	10/22/2016 0618	10/26/2016 1405
420-112448-11	11 Kitchen Bathroom Sink	Drinking Water	10/22/2016 0620	10/26/2016 1405
420-112448-12	12 Kitchen Sink by Bathroom	Drinking Water	10/22/2016 0621	10/26/2016 1405
420-112448-13	13 Kitchen B Serving Line	Drinking Water	10/22/2016 0621	10/26/2016 1405
420-112448-14	14 Kitchen Back Left Sink 1	Drinking Water	10/22/2016 0624	10/26/2016 1405
420-112448-15	15 Kitchen Back Left Sink 2	Drinking Water	10/22/2016 0624	10/26/2016 1405
420-112448-16	16 Kitchen Back Left Sink 3	Drinking Water	10/22/2016 0624	10/26/2016 1405
420-112448-17	17 Kitchen Left Pot Filler	Drinking Water	10/22/2016 0625	10/26/2016 1405
420-112448-18	18 Kitchen Right Pot Filler	Drinking Water	10/22/2016 0625	10/26/2016 1405
420-112448-19	19 Kitchen Back Right Sink 1	Drinking Water	10/22/2016 0625	10/26/2016 1405
420-112448-20	20 Kitchen Back Rught Sink 2	Drinking Water	10/22/2016 0625	10/26/2016 1405
420-112448-21	21 Kitchen Island Sink	Drinking Water	10/22/2016 0626	10/26/2016 1405
420-112448-22	22 Kitchen A Serving Line Sink	Drinking Water	10/22/2016 0627	10/26/2016 1405
420-112448-23	23 Fountain by Gym	Drinking Water	10/22/2016 0629	10/26/2016 1405
420-112448-24	24 Bottle Filler by Gym	Drinking Water	10/22/2016 0629	10/26/2016 1405
420-112448-25	25 Girls Coaches Bathroom Sink	Drinking Water	10/22/2016 0630	10/26/2016 1405
420-112448-26	26 Girls Locker Room Sink 2	Drinking Water	10/22/2016 0630	10/26/2016 1405
420-112448-27	27 Seventy Wing Fountain	Drinking Water	10/22/2016 0634	10/26/2016 1405
420-112448-28	28 Seventy Wing Girls Bathroom Sink 1	Drinking Water	10/22/2016 0634	10/26/2016 1405
420-112448-29	29 Seventy Wing Girls Bathroom Sink 2	Drinking Water	10/22/2016 0634	10/26/2016 1405
420-112448-30	30 Seventy Wing Girls Bathroom Sink 3	Drinking Water	10/22/2016 0634	10/26/2016 1405
420-112448-31	31 Seventy Wing Handicapped Bathroom Sink	Drinking Water	10/22/2016 0635	10/26/2016 1405
420-112448-32	32 Seventy Wing Boys Bathroom Sink 1	Drinking Water	10/22/2016 0636	10/26/2016 1405

SAMPLE SUMMARY

Client: Orange-Ulster BOCES

Job Number: 420-112448-1
SDG Number: Washingtonville CSD - Middle School

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-112448-33	33 Seventy Wing Boys Bathroom Sink 2	Drinking Water	10/22/2016 0636	10/26/2016 1405
420-112448-34	34 Seventy Wing Boys Bathroom Sink 3	Drinking Water	10/22/2016 0636	10/26/2016 1405
420-112448-35	35 Girls Bathroom by Cafeteria Sink 1	Drinking Water	10/22/2016 0639	10/26/2016 1405
420-112448-36	36 Girls Bathroom by Cafeteria Sink 2	Drinking Water	10/22/2016 0639	10/26/2016 1405
420-112448-37	37 Girls Bathroom by Cafeteria Sink 3	Drinking Water	10/22/2016 0639	10/26/2016 1405
420-112448-38	38 Girls Bathroom by Cafeteria Sink 4	Drinking Water	10/22/2016 0639	10/26/2016 1405
420-112448-39	39 Boys Bathroom by Cafeteria Sink 1	Drinking Water	10/22/2016 0640	10/26/2016 1405
420-112448-40	40 Boys Bathroom by Cafeteria Sink 2	Drinking Water	10/22/2016 0640	10/26/2016 1405
420-112448-41	41 Boys Bathroom by Cafeteria Sink 3	Drinking Water	10/22/2016 0640	10/26/2016 1405
420-112448-42	42 Boys Bathroom by Cafeteria Sink 4	Drinking Water	10/22/2016 0640	10/26/2016 1405
420-112448-43	43 Room 150 Left Sink	Drinking Water	10/22/2016 0643	10/26/2016 1405
420-112448-44	44 Room 150 Right Sink	Drinking Water	10/22/2016 0643	10/26/2016 1405
420-112448-45	45 Room 154 Sink	Drinking Water	10/22/2016 0643	10/26/2016 1405
420-112448-46	46 Room 154 Bathroom Sink	Drinking Water	10/22/2016 0645	10/26/2016 1405
420-112448-47	47 Room 161 Sink	Drinking Water	10/22/2016 0646	10/26/2016 1405
420-112448-48	48 Room 160 Sink	Drinking Water	10/22/2016 0646	10/26/2016 1405
420-112448-49	49 Room 114 Sink 1	Drinking Water	10/22/2016 0651	10/26/2016 1405
420-112448-50	50 Room 114 Sink 2	Drinking Water	10/22/2016 0651	10/26/2016 1405
420-112448-51	51 Room 114 Sink 3	Drinking Water	10/22/2016 0651	10/26/2016 1405
420-112448-52	52 Room 114 Sink 4	Drinking Water	10/22/2016 0651	10/26/2016 1405
420-112448-53	53 Fountain by Candy Room	Drinking Water	10/22/2016 0653	10/26/2016 1405
420-112448-54	54 Stage Sink	Drinking Water	10/22/2016 0654	10/26/2016 1405
420-112448-55	55 Room 113 Bathroom Sink	Drinking Water	10/22/2016 0654	10/26/2016 1405
420-112448-56	56 Room 112 Right Sink	Drinking Water	10/22/2016 0655	10/26/2016 1405
420-112448-57	57 Room 112 Left Sink	Drinking Water	10/22/2016 0655	10/26/2016 1405
420-112448-58	58 Room 105 Sink	Drinking Water	10/22/2016 0657	10/26/2016 1405
420-112448-59	59 Room 104 Bathroom Sink	Drinking Water	10/22/2016 0658	10/26/2016 1405
420-112448-60	60 Mail Room Sink	Drinking Water	10/22/2016 0658	10/26/2016 1405
420-112448-61	61 Main Office Bathroom Sink	Drinking Water	10/22/2016 0659	10/26/2016 1405
420-112448-62	62 Principal Bathroom Sink	Drinking Water	10/22/2016 0659	10/26/2016 1405
420-112448-63	63 Fountain by Nurse	Drinking Water	10/22/2016 0700	10/26/2016 1405
420-112448-64	64 Nurse Handicapped Bathroom Sink	Drinking Water	10/22/2016 0701	10/26/2016 1405
420-112448-65	65 Nurse Sink	Drinking Water	10/22/2016 0701	10/26/2016 1405
420-112448-66	66 Nurses Bathroom Sink	Drinking Water	10/22/2016 0701	10/26/2016 1405
420-112448-67	67 Ice Machine	Drinking Water	10/22/2016 0704	10/26/2016 1405

SAMPLE SUMMARY

Client: Orange-Ulster BOCES

Job Number: 420-112448-1
SDG Number: Washingtonville CSD - Middle School

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-112448-68	68 Room 216 Left Sink	Drinking Water	10/22/2016 0710	10/26/2016 1405
420-112448-69	69 Room 216 Back Left Sink	Drinking Water	10/22/2016 0710	10/26/2016 1405
420-112448-70	70 Room 216 Back Right Sink	Drinking Water	10/22/2016 0710	10/26/2016 1405
420-112448-71	71 Room 214 Sink	Drinking Water	10/22/2016 0712	10/26/2016 1405
420-112448-72	72 Room 213 Sink	Drinking Water	10/22/2016 0712	10/26/2016 1405
420-112448-73	73 Girls Bathroom by Library Sink 1	Drinking Water	10/22/2016 0715	10/26/2016 1405
420-112448-74	74 Girls Bathroom by Library Sink 2	Drinking Water	10/22/2016 0715	10/26/2016 1405
420-112448-75	75 Girls Bathroom by Library Sink 3	Drinking Water	10/22/2016 0715	10/26/2016 1405
420-112448-76	76 Faculty Bathroom Sink by Library	Drinking Water	10/22/2016 0716	10/26/2016 1405
420-112448-77	77 Boys Bathroom by Library Sink 1	Drinking Water	10/22/2016 0716	10/26/2016 1405
420-112448-78	78 Boys Bathroom by Library Sink 2	Drinking Water	10/22/2016 0716	10/26/2016 1405
420-112448-79	79 Boys Bathroom by Library Sink 3	Drinking Water	10/22/2016 0716	10/26/2016 1405
420-112448-80	80 Room 209 Sink	Drinking Water	10/22/2016 0718	10/26/2016 1405
420-112448-81	81 Room 211 Faucet Without Eye Wash	Drinking Water	10/22/2016 0720	10/26/2016 1405
420-112448-82	82 Room 211 Faucet With Eye Wash	Drinking Water	10/22/2016 0720	10/26/2016 1405
420-112448-83	83 Second Floor Psychology Sink	Drinking Water	10/22/2016 0722	10/26/2016 1405
420-112448-84	84 Second Floor Faculty Mens Bathroom Sink	Drinking Water	10/22/2016 0724	10/26/2016 1405
420-112448-85	85 Second Floor Faculty Womens Bathroom Sink	Drinking Water	10/22/2016 0724	10/26/2016 1405
420-112448-86	86 Fountain by 206	Drinking Water	10/22/2016 0725	10/26/2016 1405
420-112448-87	87 Room 206 Sink	Drinking Water	10/22/2016 0726	10/26/2016 1405

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112448-1
Sdg Number: Washingtonville CSD - Middle School

Client Sample ID: 1 Room 192 Sink
Lab Sample ID: 420-112448-1

Date Sampled: 10/22/2016 0607
Date Received: 10/26/2016 1405
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/19/2016 1535	
Prep Method: 200			Date Prepared:	11/18/2016 1700	
Pb	24.0 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112448-1
Sdg Number: Washingtonville CSD - Middle School

Client Sample ID: 2 Room 193 Sink
Lab Sample ID: 420-112448-2

Date Sampled: 10/22/2016 0609
Date Received: 10/26/2016 1405
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 11/19/2016 1537		
Prep Method: 200			Date Prepared: 11/18/2016 1700		
Pb	22.7 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112448-1
Sdg Number: Washingtonville CSD - Middle School

Client Sample ID: 3 Womens Bathroom by 193 Sink 1
Lab Sample ID: 420-112448-3

Date Sampled: 10/22/2016 0610
Date Received: 10/26/2016 1405
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/19/2016 1539	
Prep Method: 200			Date Prepared:	11/18/2016 1700	
Pb	6.90	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112448-1
Sdg Number: Washingtonville CSD - Middle School

Client Sample ID: 4 Womens Bathroom by 193 Sink 2
Lab Sample ID: 420-112448-4

Date Sampled: 10/22/2016 0610
Date Received: 10/26/2016 1405
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/19/2016 1541	
Prep Method: 200			Date Prepared:	11/18/2016 1730	
Pb	23.9 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112448-1
Sdg Number: Washingtonville CSD - Middle School

Client Sample ID: 5 Mens Bathroom by 193 Sink 1
Lab Sample ID: 420-112448-5

Date Sampled: 10/22/2016 0611
Date Received: 10/26/2016 1405
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/19/2016 1548	
Prep Method: 200			Date Prepared:	11/18/2016 1730	
Pb	5.38	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112448-1
Sdg Number: Washingtonville CSD - Middle School

Client Sample ID: 6 Outside Spigot North Side
Lab Sample ID: 420-112448-6

Date Sampled: 10/22/2016 0612
Date Received: 10/26/2016 1405
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/19/2016 1550	
Prep Method: 200			Date Prepared:	11/18/2016 1730	
Pb	20.5 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112448-1
Sdg Number: Washingtonville CSD - Middle School

Client Sample ID: 7 Mens Locker Room Sink 1
Lab Sample ID: 420-112448-7

Date Sampled: 10/22/2016 0616
Date Received: 10/26/2016 1405
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 11/19/2016 1556		
Prep Method: 200			Date Prepared: 11/18/2016 1730		
Pb	2.30	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112448-1
Sdg Number: Washingtonville CSD - Middle School

Client Sample ID: 8 Mens Locker Room Sink 2
Lab Sample ID: 420-112448-8

Date Sampled: 10/22/2016 0616
Date Received: 10/26/2016 1405
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/19/2016 1558	
Prep Method: 200			Date Prepared:	11/18/2016 1730	
Pb	2.74	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112448-1
Sdg Number: Washingtonville CSD - Middle School

Client Sample ID: 9 Boys Coaches Bathroom Sink
Lab Sample ID: 420-112448-9

Date Sampled: 10/22/2016 0617
Date Received: 10/26/2016 1405
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/19/2016 1600	
Prep Method: 200			Date Prepared:	11/18/2016 1730	
Pb	13.9	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112448-1
Sdg Number: Washingtonville CSD - Middle School

Client Sample ID: 10 Cafeteria B Fountain
Lab Sample ID: 420-112448-10

Date Sampled: 10/22/2016 0618
Date Received: 10/26/2016 1405
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/19/2016 1601	
Prep Method: 200			Date Prepared:	11/18/2016 1730	
Pb	3.62	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112448-1
Sdg Number: Washingtonville CSD - Middle School

Client Sample ID: 11 Kitchen Bathroom Sink
Lab Sample ID: 420-112448-11

Date Sampled: 10/22/2016 0620
Date Received: 10/26/2016 1405
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 11/19/2016 1603		
Prep Method: 200			Date Prepared: 11/18/2016 1730		
Pb	6.81	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112448-1
Sdg Number: Washingtonville CSD - Middle School

Client Sample ID: 12 Kitchen Sink by Bathroom
Lab Sample ID: 420-112448-12

Date Sampled: 10/22/2016 0621
Date Received: 10/26/2016 1405
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/19/2016 1605	
Prep Method: 200			Date Prepared:	11/18/2016 1730	
Pb	12.2	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112448-1
Sdg Number: Washingtonville CSD - Middle School

Client Sample ID: 13 Kitchen B Serving Line
Lab Sample ID: 420-112448-13

Date Sampled: 10/22/2016 0621
Date Received: 10/26/2016 1405
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1325	
Prep Method: 200			Date Prepared:	11/18/2016 1730	
Pb	14.7	ug/L	2.00	2.00	2.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112448-1
Sdg Number: Washingtonville CSD - Middle School

Client Sample ID: 14 Kitchen Back Left Sink 1
Lab Sample ID: 420-112448-14

Date Sampled: 10/22/2016 0624
Date Received: 10/26/2016 1405
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/19/2016 1609	
Prep Method: 200			Date Prepared:	11/18/2016 1730	
Pb	18.4 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112448-1
Sdg Number: Washingtonville CSD - Middle School

Client Sample ID: 15 Kitchen Back Left Sink 2
Lab Sample ID: 420-112448-15

Date Sampled: 10/22/2016 0624
Date Received: 10/26/2016 1405
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 11/19/2016 1611		
Prep Method: 200			Date Prepared: 11/18/2016 1730		
Pb	20.0 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112448-1
Sdg Number: Washingtonville CSD - Middle School

Client Sample ID: 16 Kitchen Back Left Sink 3
Lab Sample ID: 420-112448-16

Date Sampled: 10/22/2016 0624
Date Received: 10/26/2016 1405
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/19/2016 1613	
Prep Method: 200			Date Prepared:	11/18/2016 1730	
Pb	11.9	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112448-1
Sdg Number: Washingtonville CSD - Middle School

Client Sample ID: 17 Kitchen Left Pot Filler
Lab Sample ID: 420-112448-17

Date Sampled: 10/22/2016 0625
Date Received: 10/26/2016 1405
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 11/19/2016 1618		
Prep Method: 200			Date Prepared: 11/18/2016 1730		
Pb	48.4 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112448-1
Sdg Number: Washingtonville CSD - Middle School

Client Sample ID: 18 Kitchen Right Pot Filler
Lab Sample ID: 420-112448-18

Date Sampled: 10/22/2016 0625
Date Received: 10/26/2016 1405
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 11/19/2016 1620		
Prep Method: 200			Date Prepared: 11/18/2016 1730		
Pb	20.9 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112448-1
Sdg Number: Washingtonville CSD - Middle School

Client Sample ID: 19 Kitchen Back Right Sink 1
Lab Sample ID: 420-112448-19

Date Sampled: 10/22/2016 0625
Date Received: 10/26/2016 1405
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/19/2016 1622	
Prep Method: 200			Date Prepared:	11/18/2016 1730	
Pb	6.45	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112448-1
Sdg Number: Washingtonville CSD - Middle School

Client Sample ID: 20 Kitchen Back Rught Sink 2
Lab Sample ID: 420-112448-20

Date Sampled: 10/22/2016 0625
Date Received: 10/26/2016 1405
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/19/2016 1624	
Prep Method: 200			Date Prepared:	11/18/2016 1730	
Pb	5.20	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112448-1
Sdg Number: Washingtonville CSD - Middle School

Client Sample ID: 21 Kitchen Island Sink
Lab Sample ID: 420-112448-21

Date Sampled: 10/22/2016 0626
Date Received: 10/26/2016 1405
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 11/19/2016 1626		
Prep Method: 200			Date Prepared: 11/18/2016 1730		
Pb	14.0	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112448-1
Sdg Number: Washingtonville CSD - Middle School

Client Sample ID: 22 Kitchen A Serving Line Sink
Lab Sample ID: 420-112448-22

Date Sampled: 10/22/2016 0627
Date Received: 10/26/2016 1405
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/19/2016 1628	
Prep Method: 200			Date Prepared:	11/18/2016 1730	
Pb	11.6	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112448-1
Sdg Number: Washingtonville CSD - Middle School

Client Sample ID: 23 Fountain by Gym
Lab Sample ID: 420-112448-23

Date Sampled: 10/22/2016 0629
Date Received: 10/26/2016 1405
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 11/19/2016 1630		
Prep Method: 200			Date Prepared: 11/18/2016 1730		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112448-1
Sdg Number: Washingtonville CSD - Middle School

Client Sample ID: 24 Bottle Filler by Gym
Lab Sample ID: 420-112448-24

Date Sampled: 10/22/2016 0629
Date Received: 10/26/2016 1405
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/19/2016 1632	
Prep Method: 200			Date Prepared:	11/18/2016 1810	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112448-1
Sdg Number: Washingtonville CSD - Middle School

Client Sample ID: 25 Girls Coaches Bathroom Sink
Lab Sample ID: 420-112448-25

Date Sampled: 10/22/2016 0630
Date Received: 10/26/2016 1405
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/19/2016 1643	
Prep Method: 200			Date Prepared:	11/18/2016 1810	
Pb	8.03	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112448-1
Sdg Number: Washingtonville CSD - Middle School

Client Sample ID: 26 Girls Locker Room Sink 2
Lab Sample ID: 420-112448-26

Date Sampled: 10/22/2016 0630
Date Received: 10/26/2016 1405
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/19/2016 1645	
Prep Method: 200			Date Prepared:	11/18/2016 1810	
Pb	3.29	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112448-1
Sdg Number: Washingtonville CSD - Middle School

Client Sample ID: 27 Seventy Wing Fountain
Lab Sample ID: 420-112448-27

Date Sampled: 10/22/2016 0634
Date Received: 10/26/2016 1405
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 11/19/2016 1647		
Prep Method: 200			Date Prepared: 11/18/2016 1810		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112448-1
Sdg Number: Washingtonville CSD - Middle School

Client Sample ID: 28 Seventy Wing Girls Bathroom Sink 1
Lab Sample ID: 420-112448-28

Date Sampled: 10/22/2016 0634
Date Received: 10/26/2016 1405
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/19/2016 1649	
Prep Method: 200			Date Prepared:	11/18/2016 1810	
Pb	18.7 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112448-1
Sdg Number: Washingtonville CSD - Middle School

Client Sample ID: 29 Seventy Wing Girls Bathroom Sink 2
Lab Sample ID: 420-112448-29

Date Sampled: 10/22/2016 0634
Date Received: 10/26/2016 1405
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/19/2016 1651	
Prep Method: 200			Date Prepared:	11/18/2016 1810	
Pb	5.37	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112448-1
Sdg Number: Washingtonville CSD - Middle School

Client Sample ID: 30 Seventy Wing Girls Bathroom Sink 3
Lab Sample ID: 420-112448-30

Date Sampled: 10/22/2016 0634
Date Received: 10/26/2016 1405
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/19/2016 1653	
Prep Method: 200			Date Prepared:	11/18/2016 1810	
Pb	4.30	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112448-1
Sdg Number: Washingtonville CSD - Middle School

Client Sample ID: 31 Seventy Wing Handicapped Bathroom Sink
Lab Sample ID: 420-112448-31

Date Sampled: 10/22/2016 0635
Date Received: 10/26/2016 1405
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/19/2016 1655	
Prep Method: 200			Date Prepared:	11/18/2016 1810	
Pb	2.13	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112448-1
Sdg Number: Washingtonville CSD - Middle School

Client Sample ID: 32 Seventy Wing Boys Bathroom Sink 1
Lab Sample ID: 420-112448-32

Date Sampled: 10/22/2016 0636
Date Received: 10/26/2016 1405
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/19/2016 1656	
Prep Method: 200			Date Prepared:	11/18/2016 1810	
Pb	8.10	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112448-1
Sdg Number: Washingtonville CSD - Middle School

Client Sample ID: 33 Seventy Wing Boys Bathroom Sink 2
Lab Sample ID: 420-112448-33

Date Sampled: 10/22/2016 0636
Date Received: 10/26/2016 1405
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/19/2016 1658	
Prep Method: 200			Date Prepared:	11/18/2016 1810	
Pb	3.62	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112448-1
Sdg Number: Washingtonville CSD - Middle School

Client Sample ID: 34 Seventy Wing Boys Bathroom Sink 3
Lab Sample ID: 420-112448-34

Date Sampled: 10/22/2016 0636
Date Received: 10/26/2016 1405
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/19/2016 1704	
Prep Method: 200			Date Prepared:	11/18/2016 1810	
Pb	11.4	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112448-1
Sdg Number: Washingtonville CSD - Middle School

Client Sample ID: 35 Girls Bathroom by Cafeteria Sink 1
Lab Sample ID: 420-112448-35

Date Sampled: 10/22/2016 0639
Date Received: 10/26/2016 1405
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/19/2016 1706	
Prep Method: 200			Date Prepared:	11/18/2016 1810	
Pb	5.51	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112448-1
Sdg Number: Washingtonville CSD - Middle School

Client Sample ID: 36 Girls Bathroom by Cafeteria Sink 2
Lab Sample ID: 420-112448-36

Date Sampled: 10/22/2016 0639
Date Received: 10/26/2016 1405
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/19/2016 1708	
Prep Method: 200			Date Prepared:	11/18/2016 1810	
Pb	3.29	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112448-1
Sdg Number: Washingtonville CSD - Middle School

Client Sample ID: 37 Girls Bathroom by Cafeteria Sink 3
Lab Sample ID: 420-112448-37

Date Sampled: 10/22/2016 0639
Date Received: 10/26/2016 1405
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 11/19/2016 1710		
Prep Method: 200			Date Prepared: 11/18/2016 1810		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112448-1
Sdg Number: Washingtonville CSD - Middle School

Client Sample ID: 38 Girls Bathroom by Cafeteria Sink 4
Lab Sample ID: 420-112448-38

Date Sampled: 10/22/2016 0639
Date Received: 10/26/2016 1405
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/19/2016 1712	
Prep Method: 200			Date Prepared:	11/18/2016 1810	
Pb	1.94	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112448-1
Sdg Number: Washingtonville CSD - Middle School

Client Sample ID: 39 Boys Bathroom by Cafeteria Sink 1
Lab Sample ID: 420-112448-39

Date Sampled: 10/22/2016 0640
Date Received: 10/26/2016 1405
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/19/2016 1714	
Prep Method: 200			Date Prepared:	11/18/2016 1810	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112448-1
Sdg Number: Washingtonville CSD - Middle School

Client Sample ID: 40 Boys Bathroom by Cafeteria Sink 2
Lab Sample ID: 420-112448-40

Date Sampled: 10/22/2016 0640
Date Received: 10/26/2016 1405
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/19/2016 1715	
Prep Method: 200			Date Prepared:	11/18/2016 1810	
Pb	2.53	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112448-1
Sdg Number: Washingtonville CSD - Middle School

Client Sample ID: 41 Boys Bathroom by Cafeteria Sink 3
Lab Sample ID: 420-112448-41

Date Sampled: 10/22/2016 0640
Date Received: 10/26/2016 1405
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/19/2016 1717	
Prep Method: 200			Date Prepared:	11/18/2016 1810	
Pb	2.57	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112448-1
Sdg Number: Washingtonville CSD - Middle School

Client Sample ID: 42 Boys Bathroom by Cafeteria Sink 4
Lab Sample ID: 420-112448-42

Date Sampled: 10/22/2016 0640
Date Received: 10/26/2016 1405
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/19/2016 1719	
Prep Method: 200			Date Prepared:	11/18/2016 1810	
Pb	2.90	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112448-1
Sdg Number: Washingtonville CSD - Middle School

Client Sample ID: 43 Room 150 Left Sink
Lab Sample ID: 420-112448-43

Date Sampled: 10/22/2016 0643
Date Received: 10/26/2016 1405
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 11/19/2016 1721		
Prep Method: 200			Date Prepared: 11/18/2016 1810		
Pb	4.78	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112448-1
Sdg Number: Washingtonville CSD - Middle School

Client Sample ID: 44 Room 150 Right Sink
Lab Sample ID: 420-112448-44

Date Sampled: 10/22/2016 0643
Date Received: 10/26/2016 1405
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/19/2016 1727	
Prep Method: 200			Date Prepared:	11/18/2016 1750	
Pb	5.05	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112448-1
Sdg Number: Washingtonville CSD - Middle School

Client Sample ID: 45 Room 154 Sink
Lab Sample ID: 420-112448-45

Date Sampled: 10/22/2016 0643
Date Received: 10/26/2016 1405
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/19/2016 1735	
Prep Method: 200			Date Prepared:	11/18/2016 1750	
Pb	2.16	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112448-1
Sdg Number: Washingtonville CSD - Middle School

Client Sample ID: 46 Room 154 Bathroom Sink
Lab Sample ID: 420-112448-46

Date Sampled: 10/22/2016 0645
Date Received: 10/26/2016 1405
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 11/19/2016 1736		
Prep Method: 200			Date Prepared: 11/18/2016 1750		
Pb	21.5 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112448-1
Sdg Number: Washingtonville CSD - Middle School

Client Sample ID: 47 Room 161 Sink
Lab Sample ID: 420-112448-47

Date Sampled: 10/22/2016 0646
Date Received: 10/26/2016 1405
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 11/19/2016 1738		
Prep Method: 200			Date Prepared: 11/18/2016 1750		
Pb	6.41	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112448-1
Sdg Number: Washingtonville CSD - Middle School

Client Sample ID: 48 Room 160 Sink
Lab Sample ID: 420-112448-48

Date Sampled: 10/22/2016 0646
Date Received: 10/26/2016 1405
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/19/2016 1740	
Prep Method: 200			Date Prepared:	11/18/2016 1750	
Pb	5.41	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112448-1
Sdg Number: Washingtonville CSD - Middle School

Client Sample ID: 49 Room 114 Sink 1
Lab Sample ID: 420-112448-49

Date Sampled: 10/22/2016 0651
Date Received: 10/26/2016 1405
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/19/2016 1742	
Prep Method: 200			Date Prepared:	11/18/2016 1750	
Pb	10.6	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112448-1
Sdg Number: Washingtonville CSD - Middle School

Client Sample ID: 50 Room 114 Sink 2
Lab Sample ID: 420-112448-50

Date Sampled: 10/22/2016 0651
Date Received: 10/26/2016 1405
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/19/2016 1744	
Prep Method: 200			Date Prepared:	11/18/2016 1750	
Pb	4.28	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112448-1
Sdg Number: Washingtonville CSD - Middle School

Client Sample ID: 51 Room 114 Sink 3
Lab Sample ID: 420-112448-51

Date Sampled: 10/22/2016 0651
Date Received: 10/26/2016 1405
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 11/19/2016 1750		
Prep Method: 200			Date Prepared: 11/18/2016 1750		
Pb	26.6 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112448-1
Sdg Number: Washingtonville CSD - Middle School

Client Sample ID: 52 Room 114 Sink 4
Lab Sample ID: 420-112448-52

Date Sampled: 10/22/2016 0651
Date Received: 10/26/2016 1405
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/19/2016 1752	
Prep Method: 200			Date Prepared:	11/18/2016 1750	
Pb	4.75	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112448-1
Sdg Number: Washingtonville CSD - Middle School

Client Sample ID: 53 Fountain by Candy Room
Lab Sample ID: 420-112448-53

Date Sampled: 10/22/2016 0653
Date Received: 10/26/2016 1405
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/19/2016 1754	
Prep Method: 200			Date Prepared:	11/18/2016 1750	
Pb	31.4 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112448-1
Sdg Number: Washingtonville CSD - Middle School

Client Sample ID: 54 Stage Sink
Lab Sample ID: 420-112448-54

Date Sampled: 10/22/2016 0654
Date Received: 10/26/2016 1405
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 11/19/2016 1756		
Prep Method: 200			Date Prepared: 11/18/2016 1750		
Pb	23.1 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112448-1
Sdg Number: Washingtonville CSD - Middle School

Client Sample ID: 55 Room 113 Bathroom Sink
Lab Sample ID: 420-112448-55

Date Sampled: 10/22/2016 0654
Date Received: 10/26/2016 1405
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/19/2016 1758	
Prep Method: 200			Date Prepared:	11/18/2016 1750	
Pb	9.10	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112448-1
Sdg Number: Washingtonville CSD - Middle School

Client Sample ID: 56 Room 112 Right Sink
Lab Sample ID: 420-112448-56

Date Sampled: 10/22/2016 0655
Date Received: 10/26/2016 1405
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/19/2016 1759	
Prep Method: 200			Date Prepared:	11/18/2016 1750	
Pb	6.84	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112448-1
Sdg Number: Washingtonville CSD - Middle School

Client Sample ID: 57 Room 112 Left Sink
Lab Sample ID: 420-112448-57

Date Sampled: 10/22/2016 0655
Date Received: 10/26/2016 1405
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/19/2016 1801	
Prep Method: 200			Date Prepared:	11/18/2016 1750	
Pb	14.4	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112448-1
Sdg Number: Washingtonville CSD - Middle School

Client Sample ID: 58 Room 105 Sink
Lab Sample ID: 420-112448-58

Date Sampled: 10/22/2016 0657
Date Received: 10/26/2016 1405
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/19/2016 1803	
Prep Method: 200			Date Prepared:	11/18/2016 1750	
Pb	3.58	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112448-1
Sdg Number: Washingtonville CSD - Middle School

Client Sample ID: 59 Room 104 Bathroom Sink
Lab Sample ID: 420-112448-59

Date Sampled: 10/22/2016 0658
Date Received: 10/26/2016 1405
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/19/2016 1805	
Prep Method: 200			Date Prepared:	11/18/2016 1750	
Pb	1.06	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112448-1
Sdg Number: Washingtonville CSD - Middle School

Client Sample ID: 60 Mail Room Sink
Lab Sample ID: 420-112448-60

Date Sampled: 10/22/2016 0658
Date Received: 10/26/2016 1405
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/19/2016 1807	
Prep Method: 200			Date Prepared:	11/18/2016 1750	
Pb	3.62	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112448-1
Sdg Number: Washingtonville CSD - Middle School

Client Sample ID: 61 Main Office Bathroom Sink
Lab Sample ID: 420-112448-61

Date Sampled: 10/22/2016 0659
Date Received: 10/26/2016 1405
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 11/19/2016 1813		
Prep Method: 200			Date Prepared: 11/18/2016 1750		
Pb	9.09	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112448-1
Sdg Number: Washingtonville CSD - Middle School

Client Sample ID: 62 Principal Bathroom Sink
Lab Sample ID: 420-112448-62

Date Sampled: 10/22/2016 0659
Date Received: 10/26/2016 1405
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 11/19/2016 1815		
Prep Method: 200			Date Prepared: 11/18/2016 1750		
Pb	20.4 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112448-1
Sdg Number: Washingtonville CSD - Middle School

Client Sample ID: 63 Fountain by Nurse
Lab Sample ID: 420-112448-63

Date Sampled: 10/22/2016 0700
Date Received: 10/26/2016 1405
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 11/19/2016 1817		
Prep Method: 200			Date Prepared: 11/18/2016 1750		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112448-1
Sdg Number: Washingtonville CSD - Middle School

Client Sample ID: 64 Nurse Handicapped Bathroom Sink
Lab Sample ID: 420-112448-64

Date Sampled: 10/22/2016 0701
Date Received: 10/26/2016 1405
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 11/19/2016 1819		
Prep Method: 200			Date Prepared: 11/19/2016 0900		
Pb	11.5 V	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112448-1
Sdg Number: Washingtonville CSD - Middle School

Client Sample ID: 65 Nurse Sink
Lab Sample ID: 420-112448-65

Date Sampled: 10/22/2016 0701
Date Received: 10/26/2016 1405
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/28/2016 1701	
Prep Method: 200			Date Prepared:	11/21/2016 0830	
Pb	9.29	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112448-1
Sdg Number: Washingtonville CSD - Middle School

Client Sample ID: 66 Nurses Bathroom Sink
Lab Sample ID: 420-112448-66

Date Sampled: 10/22/2016 0701
Date Received: 10/26/2016 1405
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/19/2016 1826	
Prep Method: 200			Date Prepared:	11/19/2016 0900	
Pb	7.23	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112448-1
Sdg Number: Washingtonville CSD - Middle School

Client Sample ID: 67 Ice Machine
Lab Sample ID: 420-112448-67

Date Sampled: 10/22/2016 0704
Date Received: 10/26/2016 1405
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 11/19/2016 1828		
Prep Method: 200			Date Prepared: 11/19/2016 0900		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112448-1
Sdg Number: Washingtonville CSD - Middle School

Client Sample ID: 68 Room 216 Left Sink
Lab Sample ID: 420-112448-68

Date Sampled: 10/22/2016 0710
Date Received: 10/26/2016 1405
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/19/2016 1830	
Prep Method: 200			Date Prepared:	11/19/2016 0900	
Pb	30.4 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112448-1
Sdg Number: Washingtonville CSD - Middle School

Client Sample ID: 69 Room 216 Back Left Sink
Lab Sample ID: 420-112448-69

Date Sampled: 10/22/2016 0710
Date Received: 10/26/2016 1405
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/19/2016 1836	
Prep Method: 200			Date Prepared:	11/19/2016 0900	
Pb	98.9 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112448-1
Sdg Number: Washingtonville CSD - Middle School

Client Sample ID: 70 Room 216 Back Right Sink
Lab Sample ID: 420-112448-70

Date Sampled: 10/22/2016 0710
Date Received: 10/26/2016 1405
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/19/2016 1838	
Prep Method: 200			Date Prepared:	11/19/2016 0900	
Pb	19.1 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112448-1
Sdg Number: Washingtonville CSD - Middle School

Client Sample ID: 71 Room 214 Sink
Lab Sample ID: 420-112448-71

Date Sampled: 10/22/2016 0712
Date Received: 10/26/2016 1405
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 11/19/2016 1840		
Prep Method: 200			Date Prepared: 11/19/2016 0900		
Pb	32.6 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112448-1
Sdg Number: Washingtonville CSD - Middle School

Client Sample ID: 72 Room 213 Sink
Lab Sample ID: 420-112448-72

Date Sampled: 10/22/2016 0712
Date Received: 10/26/2016 1405
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/19/2016 1842	
Prep Method: 200			Date Prepared:	11/19/2016 0900	
Pb	43.7 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112448-1
Sdg Number: Washingtonville CSD - Middle School

Client Sample ID: 73 Girls Bathroom by Library Sink 1
Lab Sample ID: 420-112448-73

Date Sampled: 10/22/2016 0715
Date Received: 10/26/2016 1405
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/19/2016 1844	
Prep Method: 200			Date Prepared:	11/19/2016 0900	
Pb	17.7 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112448-1
Sdg Number: Washingtonville CSD - Middle School

Client Sample ID: 74 Girls Bathroom by Library Sink 2
Lab Sample ID: 420-112448-74

Date Sampled: 10/22/2016 0715
Date Received: 10/26/2016 1405
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/19/2016 1846	
Prep Method: 200			Date Prepared:	11/19/2016 0900	
Pb	1.74	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112448-1
Sdg Number: Washingtonville CSD - Middle School

Client Sample ID: 75 Girls Bathroom by Library Sink 3
Lab Sample ID: 420-112448-75

Date Sampled: 10/22/2016 0715
Date Received: 10/26/2016 1405
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/19/2016 1847	
Prep Method: 200			Date Prepared:	11/19/2016 0900	
Pb	5.50	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112448-1
Sdg Number: Washingtonville CSD - Middle School

Client Sample ID: 76 Faculty Bathroom Sink by Library
Lab Sample ID: 420-112448-76

Date Sampled: 10/22/2016 0716
Date Received: 10/26/2016 1405
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 11/19/2016 1849		
Prep Method: 200			Date Prepared: 11/19/2016 0900		
Pb	15.2 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112448-1
Sdg Number: Washingtonville CSD - Middle School

Client Sample ID: 77 Boys Bathroom by Library Sink 1
Lab Sample ID: 420-112448-77

Date Sampled: 10/22/2016 0716
Date Received: 10/26/2016 1405
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/19/2016 1851	
Prep Method: 200			Date Prepared:	11/19/2016 0900	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112448-1
Sdg Number: Washingtonville CSD - Middle School

Client Sample ID: 78 Boys Bathroom by Library Sink 2
Lab Sample ID: 420-112448-78

Date Sampled: 10/22/2016 0716
Date Received: 10/26/2016 1405
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/19/2016 1853	
Prep Method: 200			Date Prepared:	11/19/2016 0900	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112448-1
Sdg Number: Washingtonville CSD - Middle School

Client Sample ID: 79 Boys Bathroom by Library Sink 3
Lab Sample ID: 420-112448-79

Date Sampled: 10/22/2016 0716
Date Received: 10/26/2016 1405
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/19/2016 1859	
Prep Method: 200			Date Prepared:	11/19/2016 0900	
Pb	3.25	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112448-1
Sdg Number: Washingtonville CSD - Middle School

Client Sample ID: 80 Room 209 Sink
Lab Sample ID: 420-112448-80

Date Sampled: 10/22/2016 0718
Date Received: 10/26/2016 1405
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/19/2016 1901	
Prep Method: 200			Date Prepared:	11/19/2016 0900	
Pb	45.3 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112448-1
Sdg Number: Washingtonville CSD - Middle School

Client Sample ID: 81 Room 211 Faucet Without Eye Wash
Lab Sample ID: 420-112448-81

Date Sampled: 10/22/2016 0720
Date Received: 10/26/2016 1405
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/19/2016 1903	
Prep Method: 200			Date Prepared:	11/19/2016 0900	
Pb	102 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112448-1
Sdg Number: Washingtonville CSD - Middle School

Client Sample ID: 82 Room 211 Faucet With Eye Wash
Lab Sample ID: 420-112448-82

Date Sampled: 10/22/2016 0720
Date Received: 10/26/2016 1405
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/19/2016 1905	
Prep Method: 200			Date Prepared:	11/19/2016 0900	
Pb	49.0 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112448-1
Sdg Number: Washingtonville CSD - Middle School

Client Sample ID: 83 Second Floor Psychology Sink
Lab Sample ID: 420-112448-83

Date Sampled: 10/22/2016 0722
Date Received: 10/26/2016 1405
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 11/21/2016 2219		
Prep Method: 200			Date Prepared: 11/19/2016 0900		
Pb	44.3 g	ug/L	5.00	5.00	5.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112448-1
Sdg Number: Washingtonville CSD - Middle School

Client Sample ID: 84 Second Floor Faculty Mens Bathroom Sink
Lab Sample ID: 420-112448-84

Date Sampled: 10/22/2016 0724
Date Received: 10/26/2016 1405
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/19/2016 1909	
Prep Method: 200			Date Prepared:	11/19/2016 0920	
Pb	13.9	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112448-1
Sdg Number: Washingtonville CSD - Middle School

Client Sample ID: 85 Second Floor Faculty Womens Bathroom
Lab Sample ID: 420-112448-85

Date Sampled: 10/22/2016 0724
Date Received: 10/26/2016 1405
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 11/19/2016 1911		
Prep Method: 200			Date Prepared: 11/19/2016 0920		
Pb	4.45	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112448-1
Sdg Number: Washingtonville CSD - Middle School

Client Sample ID: 86 Fountain by 206
Lab Sample ID: 420-112448-86

Date Sampled: 10/22/2016 0725
Date Received: 10/26/2016 1405
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 11/19/2016 1922		
Prep Method: 200			Date Prepared: 11/19/2016 0920		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-112448-1
Sdg Number: Washingtonville CSD - Middle School

Client Sample ID: 87 Room 206 Sink
Lab Sample ID: 420-112448-87

Date Sampled: 10/22/2016 0726
Date Received: 10/26/2016 1405
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 11/19/2016 1924		
Prep Method: 200			Date Prepared: 11/19/2016 0920		
Pb	4.87	ug/L	1.00	1.00	1.0

DATA REPORTING QUALIFIERS

Client: Orange-Ulster BOCES

Job Number:
Sdg Number: Washingtonville CSD - Middle School

Lab Section	Qualifier	Description
Metals		
	g	Result fails applicable NYS drinking water standards
	U	The analyte was analyzed for but not detected at or above the lowest stated limit.
	V	Serial Dilution exceeds the control limits

Certification Information

Client: Orange-Ulster BOCES

Job Number:

Sdg Number: Washingtonville CSD - Middle School

The following analytes are Not Part of the ELAP scope of accreditation:

Sulfur, Tungsten, Silicon, Bicarbonate Alkalinity, 7 Day BOD 5210C, 28 Day BOD, Soluble BOD, Carbon Dioxide, Carbonate Alkalinity, CBOD Soluble, Chlorine, Cyanide (WAD), Ferrous Iron, Ferric Iron, Total Nitrogen, Total Organic Nitrogen, Dissolved Oxygen, pH, Phenolphthalein Alkalinity, Solids (Fixed), Solids (Percent), Solids (Percent Moisture), Solids (Percent Volatile), Solids (Volatile Suspended), Temperature, TKN (Soluble), Total Inorganic Carbon, Volatile Acids as Acetic Acid, 2-Aminopyridine, 3-Picoline, 1-Methyl-2-pyrrilidinone, Aziridine, Dimethyl sulfoxide, 1-Chlorohexane, Iron Bacteria, Salmonella, & Sulfur Reducing Bacteria.

The following analytes are Not Part of ELAP Potable Water scope of accreditation:

Cobalt (200.7, 200.8), Tin (200.7), Strontium (200.7), Gold (200.7), Platinum (200.7), Palladium (200.7), Titanium (200.7), Phosphorus (365.3), Nitrate-Nitrite (10-107-4-1C, 353.2), m-Xylene & p-Xylene (502.2, 524), Naphthalene (502.2), o-Xylene (502.2, 524), & Fecal Coliform (9222D).

The following analytes are Not Part of ELAP Solid and Hazardous Waste scope of accreditation:

Ammonia (SM 4500NH3G), TKN (351.2), Phosphorus (365.3), 1,2-Dichloro-1,1,2-trifluoroethane (8260), & Chlorodifluoromethane (8260).

The following analytes are Not Part of ELAP Non Potable Water scope of accreditation:

Dissolved Organic Carbon (5310C), Mecoprop (8151A), & MCPA (8151A).

Definitions and Glossary

Client: Orange-Ulster BOCES

Job Number:

Sdg Number: Washingtonville CSD - Middle School

<u>Abbreviation</u>	<u>These commonly used abbreviations may or may not be present in this report.</u>
%R	Percent Recovery
DL, RA, RE	Indicates a Dilution, Reanalysis or Reextraction.
EPA	United States Environmental Protection Agency
MDL	Method Detection Limit - an estimate of the minimum amount of a substance that an analytical process can reliably detect. A MDL is analyte- and matrix-specific and may be laboratory-dependent.
ND	Not detected at the reporting limit (or MDL if shown).
QC	Quality Control
RL	Reporting Limit - the minimum levels, concentrations, or quantities of a target variable (e.g., target analyte) that can be reported with a specified degree of confidence.
RPD	Relative Percent Difference - a measure of the relative difference between two points.



CHAIN OF CUSTODY

Lab Name
Address & Phone

EnviroTest Laboratories
315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890

REPORT# (Lab Use Only)

112448

PROJECT REFERENCE: Washingtonville CSD - Middle School
 ENVIROTEST PROJECT MANAGER: Debra Bayer
 CLIENT (SITE) PM: Jack DeGraw
 CLIENT NAME: Orange-Ulster BOCES
 CLIENT ADDRESS: 53 Gibson Road, Goshen, NY 10924
 COMPANY CONTRACTING THIS WORK (if applicable): christy.fischer.oubooces.org
 PROJECT NO.:
 P.O. NUMBER:
 CLIENT PHONE: 845-781-4887
 CLIENT FAX:
 PROJECT LOCATION:
 TOWN:
 CLIENT FAX:
 MATRIX TYPE:
 OTHER SPECIFY:

PAGE 1 of 87

TURNAROUND TIME

NORMAL

QUICK

VERBAL

OF COOLERS

REMARKS

Lead (DW 200.8)

Lead (DW 200.8)

Lead (DW 200.8)

Lead (DW 200.8)

Lead (DW 200.8)

Lead (DW 200.8)

Lead (DW 200.8)

Lead (DW 200.8)

Lead (DW 200.8)

Lead (DW 200.8)

Lead (DW 200.8)

Lead (DW 200.8)

Lead (DW 200.8)

Lead (DW 200.8)

Lead (DW 200.8)

Lead (DW 200.8)

Lead (DW 200.8)

Lead (DW 200.8)

Lead (DW 200.8)

Lead (DW 200.8)

Lead (DW 200.8)

REQUIRED ANALYSES	NUMBER OF CONTAINERS SUBMITTED	REMARKS
40ml Vials HCl	1	
Liter Amber HCl	1	
250ml Plastic Nitric Acid	1	
250ml Plastic Sulfuric Acid	1	
Liter Plastic	1	
250ml Plastic	1	
Terra Core	1	
Other	1	
Other	1	

MATRIX TYPE	COMPOSITE (C) OR GRAB (G) INDICATE	TIME	RECEIVED BY: (SIGNATURE)	COMP DATE	TIME
AQUEOUS (WATERS)	G				
D (Drinking Water) or W (Waste Water) Indicate	D				
SOLID OR SEMISOLID	G				
OTHER SPECIFY					

DATE	TIME	SAMPLE IDENTIFICATION	COMPANY	DATE	TIME	RECEIVED BY: (SIGNATURE)	COMP DATE	TIME
10/22/2016	6:07	1 Room 192 Sink	oubooces	10/22/16	6:07			
10/22/2016	6:09	2 Room 193 Sink	oubooces	10/22/16	6:07			
10/22/2016	6:10	3 Womens Bathroom by 193 Sink 1	oubooces	10/22/16	6:07			
10/22/2016	6:10	4 Womens Bathroom by 193 Sink 2	oubooces	10/22/16	6:07			
10/22/2016	6:11	5 Mens Bathroom by 193 Sink 1	oubooces	10/22/16	6:07			
10/22/2016	6:12	6 Outside Spigot North Side	oubooces	10/22/16	6:07			
10/22/2016	6:16	7 Mens Locker Room Sink 1	oubooces	10/22/16	6:07			
10/22/2016	6:16	8 Mens Locker Room Sink 2	oubooces	10/22/16	6:07			
10/22/2016	6:17	9 Boya Coch Bathroom Sink	oubooces	10/22/16	6:07			
10/22/2016	6:18	10 Cafeteria B Fountain	oubooces	10/22/16	6:07			
10/22/2016	6:20	11 Kitchen Bathroom Sink	oubooces	10/22/16	6:07			
10/22/2016	6:21	12 Kitchen Sink by Bathroom	oubooces	10/22/16	6:07			
10/22/2016	6:21	13 Kitchen B Servng Line	oubooces	10/22/16	6:07			

RELINQUISHED BY: (SIGNATURE)	DATE	TIME	RECEIVED BY: (SIGNATURE)	COMP DATE	TIME
<i>[Signature]</i>	10/22/16	6:07	<i>[Signature]</i>		
<i>[Signature]</i>	10/22/16	6:07	<i>[Signature]</i>		

RECEIVED FOR LABORATORY BY: (SIGNATURE)	DATE	TIME	RECEIVED BY: (SIGNATURE)	COMP DATE	TIME
<i>[Signature]</i>	10/22/16	1405	<i>[Signature]</i>		

LABORATORY REMARKS:	ICE (Y/N)	pH	CL2	Revised by
				R#3



CHAIN OF CUSTODY

Lab Name: **EnviroTest Laboratories**
 Address & Phone: **315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890**

REPORT# (Lab Use Only)

112448

PROJECT REFERENCE Washingtonville CSD - Middle School		PROJECT NO.	PROJECT LOCATION	MATRIX TYPE		REQUIRED ANALYSES							PAGE 2 of 87
ENVIROTEST PROJECT MANAGER Debra Bayer		P.O. NUMBER	TOWN	SOLID OR SEMISOLID		40ml Vials HCl	250ml Plastic Nitric Acid	250ml Plastic Sulfuric Acid	Liter Plastic	250ml Plastic	Terra Core	Other	TURNAROUND TIME
CLIENT (SITE) PM Jack DeGraw		CLIENT PHONE 845-781-4887	CLIENT FAX	AQUEOUS (WATER)		Liter Amber HCl	250ml Plastic Nitric Acid	250ml Plastic Sulfuric Acid	Liter Plastic	250ml Plastic	Other	NORMAL	
CLIENT NAME Orange-Ulster BOCES		christy.fischer@oubooces.org		COMPOSITE (C) OR GRAB (G) INDICATE		NUMBER OF CONTAINERS SUBMITTED							QUICK
CLIENT ADDRESS 53 Gibson Road, Goshen, NY 10924		SAMPLE IDENTIFICATION		OTHER SPECIFY		# OF COOLERS							VERBAL
COMPANY CONTRACTING THIS WORK (if applicable)		DATE	TIME	RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)							COMPDATE
		10/22/2016	6:24	<i>[Signature]</i>		Lead (DW 200.8)							TIME
		10/22/2016	6:24	<i>[Signature]</i>		Lead (DW 200.8)							TIME
		10/22/2016	6:24	<i>[Signature]</i>		Lead (DW 200.8)							TIME
		10/22/2016	6:25	<i>[Signature]</i>		Lead (DW 200.8)							TIME
		10/22/2016	6:25	<i>[Signature]</i>		Lead (DW 200.8)							TIME
		10/22/2016	6:25	<i>[Signature]</i>		Lead (DW 200.8)							TIME
		10/22/2016	6:25	<i>[Signature]</i>		Lead (DW 200.8)							TIME
		10/22/2016	6:26	<i>[Signature]</i>		Lead (DW 200.8)							TIME
		10/22/2016	6:27	<i>[Signature]</i>		Lead (DW 200.8)							TIME
		10/22/2016	6:29	<i>[Signature]</i>		Lead (DW 200.8)							TIME
		10/22/2016	6:29	<i>[Signature]</i>		Lead (DW 200.8)							TIME
		10/22/2016	6:30	<i>[Signature]</i>		Lead (DW 200.8)							TIME
		10/22/2016	6:30	<i>[Signature]</i>		Lead (DW 200.8)							TIME

RELINQUISHED BY: (SIGNATURE) *[Signature]* COMPANY *oubooces* DATE *10/22/16* TIME *6:24*

RECEIVED BY: (SIGNATURE) *[Signature]* COMPANY *oubooces* DATE *10/22/16* TIME *6:24*

RECEIVED BY: (SIGNATURE) *[Signature]* COMPANY *oubooces* DATE *10/22/16* TIME *6:24*


RECEIVED BY: (SIGNATURE) *[Signature]* COMPANY *oubooces* DATE *10/22/16* TIME *6:24*

RECEIVED FOR LABORATORY BY: (SIGNATURE) *[Signature]* DATE *10/20/16* TIME *14:05*

RECEIVED BY: (SIGNATURE) *[Signature]* DATE *10/20/16* TIME *14:05*

LABORATORY REMARKS: ICE (Y/N) pH *7* CL2 _____ Revisited by _____

COOLER TEMP (C): *15.9*



CHAIN OF CUSTODY

REPORT# (Lab Use Only)

112448


EnviroTest Laboratories
315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890

PROJECT REFERENCE: Washingtonville CSD - Middle School
 ENVIROTEST PROJECT MANAGER: Debra Bayer
 CLIENT (SITE) PM: Jack DeGraw
 CLIENT NAME: Orange-Ulster BOCES
 CLIENT ADDRESS: 53 Gibson Road, Goshen, NY 10924
 COMPANY CONTRACTING THIS WORK (if applicable): christy.fischer.cuboces.org

PROJECT NO.	P.O. NUMBER	CLIENT PHONE	CLIENT FAX	PROJECT LOCATION	MATRIX TYPE	REQUIRED ANALYSES	OTHER	TURNAROUND TIME
		845-781-4887				40ml Vials HCl Liter Amber HCl 250ml Plastic Nitric Acid 250ml Plastic Sulfuric Acid Liter Plastic 250ml Plastic Terra Core Other		87
						Total # of Containers		

DATE	TIME	SAMPLE IDENTIFICATION	COMPOSITE (C) OR GRAB (G) INDICATE	RELINQUISHED BY (SIGNATURE)	COMPANY	DATE	TIME	RECEIVED BY (SIGNATURE)	COMP/DATE	REMARKS
10/22/2016	6:34	27 Seventy Wing fountain	G							Lead (DW 200.8)
10/22/2016	6:34	28 Seventy Wing Girls Bathroom Sink 1	G							Lead (DW 200.8)
10/22/2016	6:34	29 Seventy Wing Girls Bathroom Sink 2	G							Lead (DW 200.8)
10/22/2016	6:34	30 Seventy Wing Girls Bathroom Sink 3	G							Lead (DW 200.8)
10/22/2016	6:35	31 Seventy Wing Handicapped Bathroom Sink	G							Lead (DW 200.8)
10/22/2016	6:36	32 Seventy Wing Boys Bathroom Sink 1	G							Lead (DW 200.8)
10/22/2016	6:36	33 Seventy Wing Boys Bathroom Sink 2	G							Lead (DW 200.8)
10/22/2016	6:36	34 Seventy Wing Boys Bathroom Sink 3	G							Lead (DW 200.8)
10/22/2016	6:39	35 Girls Bathroom by Cafeteria Sink 1	G							Lead (DW 200.8)
10/22/2016	6:39	36 Girls Bathroom by Cafeteria Sink 2	G							Lead (DW 200.8)
10/22/2016	6:39	37 Girls Bathroom by Cafeteria Sink 3	G							Lead (DW 200.8)
10/22/2016	6:39	38 Girls Bathroom by Cafeteria Sink 4	G							Lead (DW 200.8)
10/22/2016	6:40	39 Boys Bathroom by Cafeteria Sink 1	G							Lead (DW 200.8)

RELINQUISHED BY (SIGNATURE): *[Signature]*
 COMPANY: cuboces
 DATE: 10/22/16
 TIME: 6:34
 RECEIVED BY (SIGNATURE): *[Signature]*
 COMPANY: cuboces
 DATE: 10/26/16
 TIME: 1405
 RECEIVED FOR LABORATORY BY (SIGNATURE): *[Signature]*
 DATE: 10/26/16
 TIME: 1445
 CUSTODY INTACT: YES
 COOLER Temp (C): 15.9
 LABOURATORY REMARKS: ICE (Y/N) pH CL2 Revisited by: RB#3



CHAIN OF CUSTODY

REPORT# (Lab Use Only)

112448

Lab Name: EnviroTest Laboratories
 Address & Phone: 315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890

PROJECT REFERENCE Washingtonville CSD - Middle School		PROJECT LOCATION	MATRIX TYPE		REQUIRED ANALYSES							PAGE 5 of 87	
ENVIROTEST PROJECT MANAGER Debra Bayer		TOWN	OTHER Specify		Total # of Containers							TURNAROUND TIME	
CLIENT (SITE) PM Jack DeGraw		CLIENT PHONE 845-781-4887	D (Drinking Water) or W (Waste Water) Indicate		40ml Vials HCl	Liter Amber HCl	250ml Plastic Nitric Acid	250ml Plastic Sulfuric Acid	Liter Plastic	250ml Plastic	Terra Core	Other	Other
CLIENT NAME Orange-Ulster BOCES		christy.fischer@uboces.org	AQUEOUS (WATER)		Liter Amber HCl	250ml Plastic Nitric Acid	250ml Plastic Sulfuric Acid	Liter Plastic	250ml Plastic	Terra Core	Other	Other	
CLIENT ADDRESS 53 Gibson Road, Goshen, NY 10924			COMPOSITE (C) OR GRAB (G) INDICATE		NUMBER OF CONTAINERS SUBMITTED							# OF COOLERS	
COMPANY CONTRACTING THIS WORK (If applicable)													
SAMPLE IDENTIFICATION		DATE	TIME	DATE	TIME	DATE	TIME	DATE	TIME	DATE	TIME	DATE	TIME
10/22/2016 6:53 53 Fountain by Candy Room		10/22/2016	6:53										
10/22/2016 6:54 54 Stage Sink		10/22/2016	6:54										
10/22/2016 6:54 55 Room 113 Bathroom Sink		10/22/2016	6:54										
10/22/2016 6:55 56 Room 112 Right Sink		10/22/2016	6:55										
10/22/2016 6:55 57 Room 112 Left Sink		10/22/2016	6:55										
10/22/2016 6:57 58 Room 105 Sink		10/22/2016	6:57										
10/22/2016 6:58 59 Room 104 Bathroom Sink		10/22/2016	6:58										
10/22/2016 6:58 60 Mail Room Sink		10/22/2016	6:58										
10/22/2016 6:59 61 Main Office Bathroom Sink		10/22/2016	6:59										
10/22/2016 6:59 62 Principal Bathroom Sink		10/22/2016	6:59										
10/22/2016 7:00 63 Fountain by Nurse		10/22/2016	7:00										
10/22/2016 7:01 64 Nurse Handicapped Bathroom Sink		10/22/2016	7:01										
10/22/2016 7:01 65 Nurse Sink		10/22/2016	7:01										
RELINQUISHED BY: (SIGNATURE)		COMPANY	DATE	TIME	RECEIVED BY: (SIGNATURE)	COMPANY	DATE	TIME	RECEIVED BY: (SIGNATURE)	COMPANY	DATE	TIME	RECEIVED BY: (SIGNATURE)
<i>Christy Fischer</i>		BOCES	10/22/16	6:53	<i>Christy Fischer</i>	BOCES	10/22/16	6:53	<i>Christy Fischer</i>	BOCES	10/22/16	6:53	<i>Christy Fischer</i>
RECEIVED FOR LABORATORY BY: (SIGNATURE)		DATE	TIME	CUSTODY INTACT YES/NO	Cooler Temp(C):	LABORATORY REMARKS:	ICE (Y/N) PH CL2	Revised by					
<i>Christy Fischer</i>		10/26/16	1405	YES	15.9			<i>RFH</i>					



CHAIN OF CUSTODY

Lab Name: **EnviroTest Laboratories**
 Address & Phone: **315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890**

REPORT# (Lab Use Only)

112448

PROJECT REFERENCE Washingtonville CSD - Middle School		PROJECT NO.	PROJECT LOCATION		MATRIX TYPE		REQUIRED ANALYSES						PAGE 6 of 87	
ENVIROTEST PROJECT MANAGER Debra Bayer		P.O. NUMBER	TOWN		OTHER Specify		Total # of Containers						TURNAROUND TIME	
CLIENT (SITE) PM Jack DeGraw		CLIENT PHONE 845-781-4887	CLIENT FAX		SOLID OR SEMISOLID		40ml Amber HCl						NORMAL	
CLIENT NAME Orange-Ulster BOCES		christy.fischer@ulbooces.org		ACQUEOUS (WATER)		Liter Amber HCl						QUICK		
CLIENT ADDRESS 53 Gibson Road, Goshen, NY 10924		COMPOSITE (C) OR GRAB (G) INDICATE		D (Drinking Water) or W (Waste Water) Indicate		250ml Plastic Sulfuric Acid						VERBAL		
COMPANY CONTRACTING THIS WORK (If applicable)		SAMPLE IDENTIFICATION		TIME		250ml Plastic Nitric Acid						# OF COOLERS		
DATE		TIME		RECEIVED BY: (SIGNATURE)		Liter Plastic						REMARKS		
10/22/2016		7:01		10/22/16		250ml Plastic Sulfuric Acid						Lead (DW 200.8)		
10/22/2016		7:04		10/22/16		Liter Amber HCl						Lead (DW 200.8)		
10/22/2016		7:10		10/22/16		250ml Plastic Nitric Acid						Lead (DW 200.8)		
10/22/2016		7:10		10/22/16		250ml Plastic Sulfuric Acid						Lead (DW 200.8)		
10/22/2016		7:10		10/22/16		Liter Amber HCl						Lead (DW 200.8)		
10/22/2016		7:12		10/22/16		250ml Plastic Nitric Acid						Lead (DW 200.8)		
10/22/2016		7:12		10/22/16		250ml Plastic Sulfuric Acid						Lead (DW 200.8)		
10/22/2016		7:15		10/22/16		Liter Amber HCl						Lead (DW 200.8)		
10/22/2016		7:15		10/22/16		250ml Plastic Nitric Acid						Lead (DW 200.8)		
10/22/2016		7:15		10/22/16		250ml Plastic Sulfuric Acid						Lead (DW 200.8)		
10/22/2016		7:16		10/22/16		Liter Amber HCl						Lead (DW 200.8)		
10/22/2016		7:16		10/22/16		250ml Plastic Nitric Acid						Lead (DW 200.8)		
10/22/2016		7:16		10/22/16		250ml Plastic Sulfuric Acid						Lead (DW 200.8)		
RELINQUISHED BY: (SIGNATURE)		DATE		CUSTODY INTACT		RECEIVED BY: (SIGNATURE)						COMP/DATE		
COMPANY		DATE		YES		RECEIVED BY: (SIGNATURE)						TIME		
COMPANY		10/26/16		NO		RECEIVED BY: (SIGNATURE)						TIME		
COMPANY		1405		Cooler Temp(C):		RECEIVED BY: (SIGNATURE)						TIME		
COMPANY		1405		15.9		RECEIVED BY: (SIGNATURE)						TIME		
COMPANY		1405		LABORATORY REMARKS:		RECEIVED BY: (SIGNATURE)						TIME		
COMPANY		1405		ICE () N () PH () CL2 ()		RECEIVED BY: (SIGNATURE)						TIME		
COMPANY		1405		Reviewed by		RECEIVED BY: (SIGNATURE)						TIME		

LOGIN SAMPLE RECEIPT CHECK LIST

Client: Orange-Ulster BOCES

Job Number: 420-112448-1

SDG Number: Washingtonville CSD - Middle School

Login Number: 112448

Question	T/F/NA	Comment
Samples were collected by ETL employee as per SOP-SAM-1	NA	
The cooler's custody seal, if present, is intact.	NA	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	False	
Cooler Temperature is recorded.	True	15.9 C
Cooler Temp. is within method specified range.(0-6 C PW, 0-8 C NPW, or BAC <10 C	False	
If false, was sample received on ice within 6 hours of collection.	False	
Based on above criteria cooler temperature is acceptable.	True	Method does not require cooling. AE 10/26/16
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the sample IDs on the containers and the COC.	True	
Samples are received within Holding Time.	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
VOA sample vials do not have headspace or bubble is <6mm (1/4") in diameter.	NA	
If necessary, staff have been informed of any short hold time or quick TAT needs	True	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	