



AQUA ENVIRONMENTAL LAB

56 Church Hill Road • Newtown, CT 06470 • (203) 270-9973


Report of Analysis

Name: Parkway School
 Greenwich Public Schools - Cordes George
 290 Greenwich Ave
 Greenwich, CT 06830-6521
Sample Date: 8/28/2019 12:15 PM
Receipt Date: 8/28/2019 3:50 PM
Report Date: 8/29/2019
Sample Site: WELL #2

Sample ID#: 234861
Sample Type: Drinking Water
Sampler: PT
PWS ID: CT0570212

Parameter	Sample Result	Units	Method	Minimum Detection Level	Analysis Date	Analyst
Biological e Coli Bacteria	0	Col/100 m	SM9223B-22	0	8/28/2019	KH

ND = Not Detected
 * = Above Specified Limit

Report Approved by:  _____ CT Lic PH-0787 NY Lic 11706
 Lab Director

Analytical results relate to the samples as received at the laboratory. Report shall not be reproduced except in its entirety without written approval from the laboratory.