

Consumer Notice of Lead Tap Water Results

Public Water System: Parkway School

PWS ID: CT0570212

We are responsible for providing water at this location and ensuring that the drinking water we provide to you meets state and federal standards. This notice is to inform you of the lead tap monitoring results for the drinking water samples collected at the locations identified below:

Drinking Water Sample Results for Lead		
Location	Date	Lead Result (mg/L)
PS001	11/13/2019	0.002
PS008	11/13/2019	<0.001
PS004	11/13/2019	0.004
PS005	11/13/2019	<0.001
PS006	11/13/2019	0.005
PS007	11/13/2019	0.004
PS010	11/13/2019	0.004
PS011	11/13/2019	0.002
PS017	11/13/2019	<0.001
PS018	11/13/2019	0.003
PS019	11/13/2019	<0.001
PS020	11/13/2019	<0.001
PS022	11/13/2019	0.003
PS023	11/13/2019	<0.001
PS024	11/13/2019	0.003
PS002	11/13/2019	0.004
5N	11/13/2019	0.005
2S	11/13/2019	0.003
PS003	11/13/2019	0.004
Nurses office	11/13/2019	0.004

What Does This Mean?

Under the authority of the Safe Drinking Water Act, EPA set the action level for lead in drinking water at 0.015 milligrams of lead per liter of water (mg/L). This means utilities must ensure that water from the customer's tap does not exceed this level in at least 90 percent of the sites sampled. The action level is the concentration of the contaminant, which if exceeded, triggers treatment or other requirements which a water system must follow to correct the problem. Because lead may pose serious health risks, the EPA set a Maximum Contaminant Level Goal (MCLG) of zero for lead. The MCLG is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

What Are The Health Effects of Lead?

Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults. Lead is stored in the bones, and it can be released later in life. During pregnancy, the child receives lead from the mother's bones, which may affect brain development.

What Are Some Sources of Lead?

Although the primary sources of lead exposure for most children are deteriorating lead-based paint, lead-contaminated dust, and lead-contaminated soil, the U.S. EPA estimates that 10 to 20 percent of human exposure to lead may come from drinking water. Exposure to lead is a significant health concern, especially for young children and infants whose growing bodies tend to absorb more lead than the average adult. Although our facility's lead levels were below the action level, if you are concerned about lead exposure in your home, parents should ask their health care providers about testing children to determine levels of lead in their blood.

What Can I Do To Reduce Exposure to Lead in Drinking Water?

- Run the Water To Flush Out Lead. Run water for 15-30 seconds or until it becomes cold or reaches a steady temperature before using it for drinking or cooking. This flushes lead-containing water from the pipes.
- Use Cold Water for Cooking and Preparing Baby Formula. Do not cook with or drink water from the hot water tap; lead dissolves more easily in hot water. Do not use water from the hot water tap to make baby formula.
- Do not boil water to remove lead. Boiling water will not reduce lead.
- Look for alternative sources of water.

For More Information

Call us at _____. For more information on reducing lead exposure around your home and the health effects of lead, visit EPA's Web site at www.epa.gov/lead, call the National Lead Information Center at 800-424-LEAD, or contact your health care provider.

Although the primary sources of lead exposure for most children are deteriorating lead-based paint, lead-contaminated dust, and lead-contaminated soil, the U.S. EPA estimates that 10 to 20 percent of human exposure to lead may come from drinking water. Exposure to lead is a significant health concern, especially for young children and infants whose growing bodies tend to absorb more lead than the average adult. Although our facility's lead levels were below the action level, if you are concerned about lead exposure in your home, parents should ask their health care providers about testing children to determine levels of lead in their blood.

What Can I Do To Reduce Exposure to Lead in Drinking Water?

- Run the Water To Flush Out Lead. Run water for 15-30 seconds or until it becomes cold or reaches a steady temperature before using it for drinking or cooking. This flushes lead-containing water from the pipes.
- Use Cold Water for Cooking and Preparing Baby Formula. Do not cook with or drink water from the hot water tap; lead dissolves more easily in hot water. Do not use water from the hot water tap to make baby formula.
- Do not boil water to remove lead. Boiling water will not reduce lead.
- Look for alternative sources of water.

For More Information — GREEN PUBLIC SCHOOLS — FACILITIES DEPT.

Call us at 203/625-7450. For more information on reducing lead exposure around your home and the health effects of lead, visit EPA's Web site at www.epa.gov/lead, call the National Lead Information Center at 800-424-LEAD, or contact your health care provider.



AQUA ENVIRONMENTAL LAB

56 Church Hill Road • Newtown, CT 06470 • (203) 270-9973

Report of Analysis

Name: Parkway School
Greenwich Public Schools - Cordes George
290 Greenwich Ave
Greenwich, CT 06830-6521
Sample Date: 11/13/2019 6:35 AM
Receipt Date: 11/13/2019 1:50 PM
Report Date: 12/9/2019
Sample Site: DISTRIBUTION SYSTEM

Sample ID#: 238868
Sample Type: Drinking Water
Sample Source: PS001
Sampler: PD
PWS ID: CT0570212

Parameter	Sample Result	Units	Method	MDL	Analysis Date/Time	Analyst
Metals						
Copper	0.10	mg/L	EPA 200.5	0.01	11/14/2019 15:49	TJB
Lead	0.002	mg/L	EPA 200.5	0.001	11/14/2019 15:49	TJB

Comments: Samples were collected in accordance with the NE States Sample Collection Manual Rev 5.0

ND = Not Detected
* = Above Specified Limit

Report Approved by: _____

Lab Director

CT Lic PH-0787

NY Lic 11706

Analytical results relate to the samples as received at the laboratory. Report shall not be reproduced except in its entirety without written approval from the laboratory.



AQUA ENVIRONMENTAL LAB

56 Church Hill Road • Newtown, CT 06470 • (203) 270-9973

Report of Analysis

Name: Parkway School
Greenwich Public Schools - Cordes George
290 Greenwich Ave
Greenwich, CT 06830-6521
Sample Date: 11/13/2019 6:35 AM
Receipt Date: 11/13/2019 1:50 PM
Report Date: 12/9/2019
Sample Site: DISTRIBUTION SYSTEM

Sample ID#: 238869
Sample Type: Drinking Water
Sample Source: PS008
Sampler: PD
PWS ID: CT0570212

Parameter	Sample Result	Units	Method	MDL	Analysis Date/Time	Analyst
Metals						
Copper	0.05	mg/L	EPA 200.5	0.01	11/14/2019 15:49	TJB
Lead	<0.001	mg/L	EPA 200.5	0.001	11/14/2019 15:49	TJB

Comments: Samples were collected in accordance with the NE States Sample Collection Manual Rev 5.0

ND = Not Detected
* = Above Specified Limit

Report Approved by:

Lab Director

CT Lic PH-0787

NY Lic 11706

Analytical results relate to the samples as received at the laboratory. Report shall not be reproduced except in its entirety without written approval from the laboratory.



AQUA ENVIRONMENTAL LAB

56 Church Hill Road • Newtown, CT 06470 • (203) 270-9973

Report of Analysis

Name: Parkway School
Greenwich Public Schools - Cordes George
290 Greenwich Ave
Greenwich, CT 06830-6521
Sample ID#: 238870
Sample Type: Drinking Water
Sample Source: PS004
Sampler: PD
PWS ID: CT0570212
Sample Date: 11/13/2019 6:35 AM
Receipt Date: 11/13/2019 1:50 PM
Report Date: 12/9/2019
Sample Site: DISTRIBUTION SYSTEM

Parameter	Sample Result	Units	Method	MDL	Analysis Date/Time	Analyst
Metals						
Copper	0.10	mg/L	EPA 200.5	0.01	11/14/2019 15:49	TJB
Lead	0.004	mg/L	EPA 200.5	0.001	11/14/2019 15:49	TJB

Comments: Samples were collected in accordance with the NE States Sample Collection Manual Rev 5.0

ND = Not Detected
* = Above Specified Limit

Report Approved by: 

Lab Director

CT Lic PH-0787

NY Lic 11706

Analytical results relate to the samples as received at the laboratory. Report shall not be reproduced except in its entirety without written approval from the laboratory.



AQUA ENVIRONMENTAL LAB

56 Church Hill Road • Newtown, CT 06470 • (203) 270-9973

Report of Analysis

Name: Parkway School
Greenwich Public Schools - Cordes George
290 Greenwich Ave
Greenwich, CT 06830-6521

Sample ID#: 238871
Sample Type: Drinking Water
Sample Source: PS005
Sampler: PD
PWS ID: CT0570212

Sample Date: 11/13/2019 6:35 AM
Receipt Date: 11/13/2019 1:50 PM
Report Date: 12/9/2019
Sample Site: DISTRIBUTION SYSTEM

Parameter	Sample Result	Units	Method	MDL	Analysis Date/Time	Analyst
Metals						
Copper	0.22	mg/L	EPA 200.5	0.01	11/14/2019 15:49	TJB
Lead	<0.001	mg/L	EPA 200.5	0.001	11/14/2019 15:49	TJB

Comments: Samples were collected in accordance with the NE States Sample Collection Manual Rev 5.0

ND = Not Detected
* = Above Specified Limit

Report Approved by: _____

Lab Director

CT Lic PH-0787

NY Lic 11706

Analytical results relate to the samples as received at the laboratory. Report shall not be reproduced except in its entirety without written approval from the laboratory.



AQUA ENVIRONMENTAL LAB

56 Church Hill Road • Newtown, CT 06470 • (203) 270-9973

Report of Analysis

Name: Parkway School
Greenwich Public Schools - Cordes George
290 Greenwich Ave
Greenwich, CT 06830-6521
Sample Date: 11/13/2019 6:35 AM
Receipt Date: 11/13/2019 1:50 PM
Report Date: 12/9/2019
Sample Site: DISTRIBUTION SYSTEM

Sample ID#: 238872
Sample Type: Drinking Water
Sample Source: PS006
Sampler: PD
PWS ID: CT0570212

Parameter	Sample Result	Units	Method	MDL	Analysis Date/Time	Analyst
Metals						
Copper	0.15	mg/L	EPA 200.5	0.01	11/14/2019 15:49	TJB
Lead	0.005	mg/L	EPA 200.5	0.001	11/14/2019 15:49	TJB

Comments: Samples were collected in accordance with the NE States Sample Collection Manual Rev 5.0

ND = Not Detected
* = Above Specified Limit

Report Approved by: _____

Lab Director

CT Lic PH-0787

NY Lic 11706

Analytical results relate to the samples as received at the laboratory. Report shall not be reproduced except in its entirety without written approval from the laboratory.



AQUA ENVIRONMENTAL LAB

56 Church Hill Road • Newtown, CT 06470 • (203) 270-9973

Report of Analysis


Name: Parkway School
Greenwich Public Schools - Cordes George
290 Greenwich Ave
Greenwich, CT 06830-6521
Sample ID#: 238873
Sample Type: Drinking Water
Sample Source: PS007
Sampler: PD
PWS ID: CT0570212
Sample Date: 11/13/2019 6:35 AM
Receipt Date: 11/13/2019 1:50 PM
Report Date: 12/9/2019
Sample Site: DISTRIBUTION SYSTEM

Parameter	Sample Result	Units	Method	MDL	Analysis Date/Time	Analyst
Metals						
Copper	0.07	mg/L	EPA 200.5	0.01	11/14/2019 15:49	TJB
Lead	0.004	mg/L	EPA 200.5	0.001	11/14/2019 15:49	TJB

Comments: Samples were collected in accordance with the NE States Sample Collection Manual Rev 5.0

ND = Not Detected
* = Above Specified Limit

Report Approved by: _____


Lab Director

CT Lic PH-0787

NY Lic 11706

Analytical results relate to the samples as received at the laboratory. Report shall not be reproduced except in its entirety without written approval from the laboratory.



AQUA ENVIRONMENTAL LAB

56 Church Hill Road • Newtown, CT 06470 • (203) 270-9973

Report of Analysis

Name: Parkway School
Greenwich Public Schools - Cordes George
290 Greenwich Ave
Greenwich, CT 06830-6521
Sample ID#: 238874
Sample Type: Drinking Water
Sample Source: PS010
Sampler: PD
PWS ID: CT0570212
Sample Date: 11/13/2019 6:35 AM
Receipt Date: 11/13/2019 1:50 PM
Report Date: 12/9/2019
Sample Site: DISTRIBUTION SYSTEM

Parameter	Sample Result	Units	Method	MDL	Analysis Date/Time	Analyst
Metals						
Copper	0.14	mg/L	EPA 200.5	0.01	11/14/2019 15:50	TJB
Lead	0.004	mg/L	EPA 200.5	0.001	11/14/2019 15:50	TJB

Comments: Samples were collected in accordance with the NE States Sample Collection Manual Rev 5.0

ND = Not Detected
* = Above Specified Limit

Report Approved by: _____

Lab Director

CT Lic PH-0787

NY Lic 11706

Analytical results relate to the samples as received at the laboratory. Report shall not be reproduced except in its entirety without written approval from the laboratory.



AQUA ENVIRONMENTAL LAB

56 Church Hill Road • Newtown, CT 06470 • (203) 270-9973

Report of Analysis

Name: Parkway School
Greenwich Public Schools - Cordes George
290 Greenwich Ave
Greenwich, CT 06830-6521
Sample Date: 11/13/2019 6:35 AM
Receipt Date: 11/13/2019 1:50 PM
Report Date: 12/9/2019
Sample Site: DISTRIBUTION SYSTEM

Sample ID#: 238875
Sample Type: Drinking Water
Sample Source: PS011
Sampler: PD
PWS ID: CT0570212

Parameter	Sample Result	Units	Method	MDL	Analysis Date/Time	Analyst
Metals						
Copper	0.11	mg/L	EPA 200.5	0.01	11/14/2019 15:50	TJB
Lead	0.002	mg/L	EPA 200.5	0.001	11/14/2019 15:50	TJB

Comments: Samples were collected in accordance with the NE States Sample Collection Manual Rev 5.0

ND = Not Detected
* = Above Specified Limit

Report Approved by: 

Lab Director

CT Lic PH-0787

NY Lic 11706

Analytical results relate to the samples as received at the laboratory. Report shall not be reproduced except in its entirety without written approval from the laboratory.



AQUA ENVIRONMENTAL LAB

56 Church Hill Road • Newtown, CT 06470 • (203) 270-9973

Report of Analysis

Name: Parkway School
Greenwich Public Schools - Cordes George
290 Greenwich Ave
Greenwich, CT 06830-6521
Sample Date: 11/13/2019 6:35 AM
Receipt Date: 11/13/2019 1:50 PM
Report Date: 12/9/2019
Sample Site: DISTRIBUTION SYSTEM

Sample ID#: 238876
Sample Type: Drinking Water
Sample Source: PS017
Sampler: PD
PWS ID: CT0570212

Parameter	Sample Result	Units	Method	MDL	Analysis Date/Time	Analyst
Metals						
Copper	0.09	mg/L	EPA 200.5	0.01	11/14/2019 15:51	TJB
Lead	<0.001	mg/L	EPA 200.5	0.001	11/14/2019 15:51	TJB

Comments: Samples were collected in accordance with the NE States Sample Collection Manual Rev 5.0

ND = Not Detected
* = Above Specified Limit

Report Approved by: 

Lab Director

CT Lic PH-0787

NY Lic 11706

Analytical results relate to the samples as received at the laboratory. Report shall not be reproduced except in its entirety without written approval from the laboratory.



AQUA ENVIRONMENTAL LAB

56 Church Hill Road • Newtown, CT 06470 • (203) 270-9973

Report of Analysis

Name: Parkway School
Greenwich Public Schools - Cordes George
290 Greenwich Ave
Greenwich, CT 06830-6521
Sample ID#: 238877
Sample Type: Drinking Water
Sample Source: PS018
Sampler: PD
PWS ID: CT0570212
Sample Date: 11/13/2019 6:35 AM
Receipt Date: 11/13/2019 1:50 PM
Report Date: 12/9/2019
Sample Site: DISTRIBUTION SYSTEM

Parameter	Sample Result	Units	Method	MDL	Analysis Date/Time	Analyst
Metals						
Copper	0.14	mg/L	EPA 200.5	0.01	11/14/2019 15:51	TJB
Lead	0.003	mg/L	EPA 200.5	0.001	11/14/2019 15:51	TJB

Comments: Samples were collected in accordance with the NE States Sample Collection Manual Rev 5.0

ND = Not Detected
* = Above Specified Limit

Report Approved by: _____

Lab Director

CT Lic PH-0787

NY Lic 11706

Analytical results relate to the samples as received at the laboratory. Report shall not be reproduced except in its entirety without written approval from the laboratory.



AQUA ENVIRONMENTAL LAB

56 Church Hill Road • Newtown, CT 06470 • (203) 270-9973

Report of Analysis

Name: Parkway School
Greenwich Public Schools - Cordes George
290 Greenwich Ave
Greenwich, CT 06830-6521
Sample ID#: 238878
Sample Type: Drinking Water
Sample Source: PS019
Sampler: PD
PWS ID: CT0570212
Sample Date: 11/13/2019 6:35 AM
Receipt Date: 11/13/2019 1:50 PM
Report Date: 12/9/2019
Sample Site: DISTRIBUTION SYSTEM

Parameter	Sample Result	Units	Method	MDL	Analysis Date/Time	Analyst
Metals						
Copper	0.06	mg/L	EPA 200.5	0.01	11/14/2019 15:52	TJB
Lead	<0.001	mg/L	EPA 200.5	0.001	11/14/2019 15:52	TJB

Comments: Samples were collected in accordance with the NE States Sample Collection Manual Rev 5.0

ND = Not Detected
* = Above Specified Limit

Report Approved by: 

Lab Director

CT Lic PH-0787

NY Lic 11706

Analytical results relate to the samples as received at the laboratory. Report shall not be reproduced except in its entirety without written approval from the laboratory.



AQUA ENVIRONMENTAL LAB

56 Church Hill Road • Newtown, CT 06470 • (203) 270-9973

Report of Analysis

Name: Parkway School
Greenwich Public Schools - Cordes George
290 Greenwich Ave
Greenwich, CT 06830-6521
Sample Date: 11/13/2019 6:35 AM
Receipt Date: 11/13/2019 1:50 PM
Report Date: 12/9/2019
Sample Site: DISTRIBUTION SYSTEM

Sample ID#: 238879
Sample Type: Drinking Water
Sample Source: PS020
Sampler: PD
PWS ID: CT0570212

Parameter	Sample Result	Units	Method	MDL	Analysis Date/Time	Analyst
Metals						
Copper	0.06	mg/L	EPA 200.5	0.01	11/14/2019 15:52	TJB
Lead	<0.001	mg/L	EPA 200.5	0.001	11/14/2019 15:52	TJB

Comments: Samples were collected in accordance with the NE States Sample Collection Manual Rev 5.0

ND = Not Detected
* = Above Specified Limit

Report Approved by: _____

Lab Director

CT Lic PH-0787

NY Lic 11706

Analytical results relate to the samples as received at the laboratory. Report shall not be reproduced except in its entirety without written approval from the laboratory.



AQUA ENVIRONMENTAL LAB

56 Church Hill Road • Newtown, CT 06470 • (203) 270-9973

Report of Analysis

Name: Parkway School
Greenwich Public Schools - Cordes George
290 Greenwich Ave
Greenwich, CT 06830-6521
Sample ID#: 238880
Sample Type: Drinking Water
Sample Source: PS022
Sampler: PD
PWS ID: CT0570212
Sample Date: 11/13/2019 6:35 AM
Receipt Date: 11/13/2019 1:50 PM
Report Date: 12/9/2019
Sample Site: DISTRIBUTION SYSTEM

Parameter	Sample Result	Units	Method	MDL	Analysis Date/Time	Analyst
Metals						
Copper	0.08	mg/L	EPA 200.5	0.01	11/14/2019 15:52	TJB
Lead	0.003	mg/L	EPA 200.5	0.001	11/14/2019 15:52	TJB

Comments: Samples were collected in accordance with the NE States Sample Collection Manual Rev 5.0

ND = Not Detected
* = Above Specified Limit

Report Approved by: 

Lab Director

CT Lic PH-0787

NY Lic 11706

Analytical results relate to the samples as received at the laboratory. Report shall not be reproduced except in its entirety without written approval from the laboratory.



AQUA ENVIRONMENTAL LAB

56 Church Hill Road • Newtown, CT 06470 • (203) 270-9973

Report of Analysis

Name: Parkway School
Greenwich Public Schools - Cordes George
290 Greenwich Ave
Greenwich, CT 06830-6521
Sample ID#: 238881
Sample Type: Drinking Water
Sample Source: PS023
Sampler: PD
PWS ID: CT0570212
Sample Date: 11/13/2019 6:35 AM
Receipt Date: 11/13/2019 1:50 PM
Report Date: 12/9/2019
Sample Site: DISTRIBUTION SYSTEM

Parameter	Sample Result	Units	Method	MDL	Analysis Date/Time	Analyst
Metals						
Copper	0.15	mg/L	EPA 200.5	0.01	11/14/2019 15:52	TJB
Lead	<0.001	mg/L	EPA 200.5	0.001	11/14/2019 15:52	TJB

Comments: Samples were collected in accordance with the NE States Sample Collection Manual Rev 5.0

ND = Not Detected
* = Above Specified Limit

Report Approved by: 

Lab Director

CT Lic PH-0787

NY Lic 11706

Analytical results relate to the samples as received at the laboratory. Report shall not be reproduced except in its entirety without written approval from the laboratory.



AQUA ENVIRONMENTAL LAB

56 Church Hill Road • Newtown, CT 06470 • (203) 270-9973

Report of Analysis

Name: Parkway School
Greenwich Public Schools - Cordes George
290 Greenwich Ave
Greenwich, CT 06830-6521
Sample Date: 11/13/2019 6:35 AM
Receipt Date: 11/13/2019 1:50 PM
Report Date: 12/9/2019
Sample Site: DISTRIBUTION SYSTEM

Sample ID#: 238882
Sample Type: Drinking Water
Sample Source: PS024
Sampler: PD
PWS ID: CT0570212

Parameter	Sample Result	Units	Method	MDL	Analysis Date/Time	Analyst
Metals						
Copper	0.13	mg/L	EPA 200.5	0.01	11/14/2019 15:52	TJB
Lead	0.003	mg/L	EPA 200.5	0.001	11/14/2019 15:52	TJB

Comments: Samples were collected in accordance with the NE States Sample Collection Manual Rev 5.0

ND = Not Detected
* = Above Specified Limit

Report Approved by: _____

Lab Director

CT Lic PH-0787

NY Lic 11706

Analytical results relate to the samples as received at the laboratory. Report shall not be reproduced except in its entirety without written approval from the laboratory.



AQUA ENVIRONMENTAL LAB

56 Church Hill Road • Newtown, CT 06470 • (203) 270-9973

Report of Analysis

Name: Parkway School
Greenwich Public Schools - Cordes George
290 Greenwich Ave
Greenwich, CT 06830-6521
Sample ID#: 238883
Sample Type: Drinking Water
Sample Source: PS002
Sampler: PD
PWS ID: CT0570212
Sample Date: 11/13/2019 6:35 AM
Receipt Date: 11/13/2019 1:50 PM
Report Date: 12/9/2019
Sample Site: DISTRIBUTION SYSTEM

Parameter	Sample Result	Units	Method	MDL	Analysis Date/Time	Analyst
Metals						
Copper	0.19	mg/L	EPA 200.5	0.01	11/14/2019 15:52	TJB
Lead	0.004	mg/L	EPA 200.5	0.001	11/14/2019 15:52	TJB

Comments: Samples were collected in accordance with the NE States Sample Collection Manual Rev 5.0

ND = Not Detected
* = Above Specified Limit

Report Approved by: _____

Lab Director

CT Lic PH-0787

NY Lic 11706

Analytical results relate to the samples as received at the laboratory. Report shall not be reproduced except in its entirety without written approval from the laboratory.



AQUA ENVIRONMENTAL LAB

56 Church Hill Road • Newtown, CT 06470 • (203) 270-9973

Report of Analysis

Name: Parkway School
Greenwich Public Schools - Cordes George
290 Greenwich Ave
Greenwich, CT 06830-6521
Sample Date: 11/13/2019 6:35 AM
Receipt Date: 11/13/2019 1:50 PM
Report Date: 12/9/2019
Sample Site: DISTRIBUTION SYSTEM

Sample ID#: 238884
Sample Type: Drinking Water
Sample Source: 5N
Sampler: PD
PWS ID: CT0570212

Parameter	Sample Result	Units	Method	MDL	Analysis Date/Time	Analyst
Metals						
Copper	0.13	mg/L	EPA 200.5	0.01	11/14/2019 15:52	TJB
Lead	0.005	mg/L	EPA 200.5	0.001	11/14/2019 15:52	TJB

Comments: Samples were collected in accordance with the NE States Sample Collection Manual Rev 5.0

ND = Not Detected
* = Above Specified Limit

Report Approved by: _____

Lab Director

CT Lic PH-0787

NY Lic 11706

Analytical results relate to the samples as received at the laboratory. Report shall not be reproduced except in its entirety without written approval from the laboratory.



AQUA ENVIRONMENTAL LAB

56 Church Hill Road • Newtown, CT 06470 • (203) 270-9973

Report of Analysis

Name: Parkway School
Greenwich Public Schools - Cordes George
290 Greenwich Ave
Greenwich, CT 06830-6521
Sample ID#: 238885
Sample Type: Drinking Water
Sample Source: 2S
Sampler: PD
PWS ID: CT0570212
Sample Date: 11/13/2019 6:35 AM
Receipt Date: 11/13/2019 1:50 PM
Report Date: 12/9/2019
Sample Site: DISTRIBUTION SYSTEM

Parameter	Sample Result	Units	Method	MDL	Analysis Date/Time	Analyst
Metals						
Copper	0.09	mg/L	EPA 200.5	0.01	11/14/2019 15:53	TJB
Lead	0.003	mg/L	EPA 200.5	0.001	11/14/2019 15:53	TJB

Comments: Samples were collected in accordance with the NE States Sample Collection Manual Rev 5.0

ND = Not Detected
* = Above Specified Limit

Report Approved by

Lab Director

CT Lic PH-0787

NY Lic 11706

Analytical results relate to the samples as received at the laboratory. Report shall not be reproduced except in its entirety without written approval from the laboratory.



AQUA ENVIRONMENTAL LAB

56 Church Hill Road • Newtown, CT 06470 • (203) 270-9973

Report of Analysis

Name: Parkway School
Greenwich Public Schools - Cordes George
290 Greenwich Ave
Greenwich, CT 06830-6521
Sample ID#: 238886
Sample Type: Drinking Water
Sample Source: PS003
Sampler: PD
PWS ID: CT0570212
Sample Date: 11/13/2019 6:35 AM
Receipt Date: 11/13/2019 1:50 PM
Report Date: 12/9/2019
Sample Site: DISTRIBUTION SYSTEM

Parameter	Sample Result	Units	Method	MDL	Analysis Date/Time	Analyst
Metals						
Copper	0.11	mg/L	EPA 200.5	0.01	11/14/2019 15:54	TJB
Lead	0.004	mg/L	EPA 200.5	0.001	11/14/2019 15:54	TJB

Comments: Samples were collected in accordance with the NE States Sample Collection Manual Rev 5.0

ND = Not Detected
* = Above Specified Limit

Report Approved by: 

Lab Director

CT Lic PH-0787

NY Lic 11706

Analytical results relate to the samples as received at the laboratory. Report shall not be reproduced except in its entirety without written approval from the laboratory.



AQUA ENVIRONMENTAL LAB

56 Church Hill Road • Newtown, CT 06470 • (203) 270-9973

Report of Analysis

Name: Parkway School
Greenwich Public Schools - Cordes George
290 Greenwich Ave
Greenwich, CT 06830-6521
Sample Date: 11/13/2019 6:35 AM
Receipt Date: 11/13/2019 1:50 PM
Report Date: 12/9/2019
Sample Site: DISTRIBUTION SYSTEM

Sample ID#: 238887
Sample Type: Drinking Water
Sample Source: Nurses office
Sampler: PD
PWS ID: CT0570212

Parameter	Sample Result	Units	Method	MDL	Analysis Date/Time	Analyst
Metals						
Copper	0.11	mg/L	EPA 200.5	0.01	11/14/2019 15:59	TJB
Lead	0.004	mg/L	EPA 200.5	0.001	11/14/2019 15:59	TJB

Comments: Samples were collected in accordance with the NE States Sample Collection Manual Rev 5.0

ND = Not Detected
* = Above Specified Limit

Report Approved by: 

Lab Director

CT Lic PH-0787

NY Lic 11706

Analytical results relate to the samples as received at the laboratory. Report shall not be reproduced except in its entirety without written approval from the laboratory.