

Glenview School District 34
Summary of Water Test Results for Lead by Building
(Information as of April 25, 2016)

Below are the summary results of the water testing done to date in District 34. Some schools have more testing dates (rows) than others due to confirmatory testing done on initially flagged fixtures in those schools

School	Date of Test Results	Total # Locations Sampled	Total # NonDetect	Total # Detect < 15 ppb	Total # > 15 ppb	Notes re samples > 15 ppb
Attea Middle School	7-Apr-16	3	2	1	0	
	15-Apr-16	8	6	1	1	Rm A112-D tap at 34.2 ppb. Non-food tap taken off-line until repair/replace and satisfactorily retested.
	19-Apr-16	32	32	0	0	
Glen Grove Elementary	7-Apr-16	3	3	0	0	
	15-Apr-16	3	3	0	0	
	19-Apr-16	29	29	0	0	
Henking Elementary	7-Apr-16	3	2	1	0	
	15-Apr-16	3	2	1	0	
	19-Apr-16	37	34	3	0	
Hoffman Elementary	7-Apr-16	3	2	0	1	1 kitchen non-food tap (dish rinse) at 150 ppb. Subsequent retest confirm elevated levels (Location 02-D at 55.5 ppb). Fixture already replaced and satisfactorily retested.
	15-Apr-16	5	3	0	2	Room 32-B at 20.6 ppb. Hoffman kitchen steamer (non-food prep) taken offline until repair/replace and satisfactorily retested.
	19-Apr-16	12	7	1	4	Classroom 23 DF at 548 ppb; Classroom 24 DF at 19.5 ppb.; Classroom 25 DF at 299 ppb.; and Classroom 26 DF at 269 ppb. Will be kept out of service pending confirmation testing and repairs as necessary.
	21-Apr-16	4	4	0	4	Rm 23 at 209 ppb in standing test and ND in flow test. Rm 24 at 446 ppb in standing test and ND in flow test. Rm 25 at 409 ppb in standing test and ND in flow test. Rm 26 at 185 ppb in standing test and ND in flow test.
Lyon Elementary	7-Apr-16	3	3	0	0	
	15-Apr-16	6	6	0	0	
	19-Apr-16	8	8	0	0	
Pleasant Ridge Elementary	7-Apr-16	3	2	1	0	
	15-Apr-16	2	2	0	0	
	19-Apr-16	30	21	7	2	Classroom 106 DF at 61.7 ppb., Hallway DF 304A at 16.3 ppb. Will be kept out of service pending further testing and repairs as necessary.
	21-Apr-16	2	1	1	0	Confirmation testing shows Rm 106 DF at 8.21 ppb in standing test and ND in flow test. Confirmation testing shows Hallway DF 304A at 36.5 ppb in standing test and at ND in flow test.
Springman Middle School	7-Apr-16	3	3	0	0	
	15-Apr-16	11	9	1	1	Kitchen tap-A at 40.3 ppb. Non-food tap taken offline until repair/replace and satisfactorily retested.
	19-Apr-16	20	19	0	1	Hallway Fountain 101B at 80.3 ppb. Will be kept out of service pending confirmation testing and repairs as necessary.
	21-Apr-16	1	1	0	1	Hallway Fountain 101B at 56.5 ppb in standing test and ND in flow test.
Westbrook Elementary	7-Apr-16	3	1	2	0	
	15-Apr-16	3	0	0	0	
	19-Apr-16	35	35	0	0	
Administration Building	7-Apr-16	1	1	0	0	
TOTAL		276				Some locations tested more than once.