



April 15, 2016

Valerie Hofmann  
Hygieneering, Inc.  
7575 Plaza Court  
Willowbrook, IL 60521

Work Order: 1604971

TEL: (630) 654-2550

FAX:

RE: 2016-2607 / Westbrook Elementary

Dear Valerie Hofmann:

All data for the associated quality control (QC) met EPA, method, or internal laboratory specifications except where noted in the case narrative. If you are comparing these results to external QC specifications or compliance limits and have any questions, please contact us.

This final report of laboratory analysis consists of this cover letter, case narrative, analytical report, dates report, and any accompanying documentation including, but not limited to, chain of custody records, raw data, and letters of explanation or reliance. This report may not be reproduced, except in full, without the prior written approval of Suburban Laboratories, Inc.

If you have any questions regarding these test results, please call me at (708) 544-3260.

Sincerely,

A handwritten signature in black ink that reads "Pat Rodriguez".

Pat Rodriguez  
Customer Service Manager  
708-544-3260 ext. 214  
[pat@suburbanlabs.com](mailto:pat@suburbanlabs.com)





## Case Narrative

**Client:** HYGIENEERING

**Date:** April 15, 2016

**Project:** 2016-2607 / Westbrook Elementary

**PO:** 2016-2607

**WorkOrder:** 1604971

**QC Level:**

**Temperature of samples upon receipt at lab:** 4 C

**Chain of Custody:** EV

### General Comments:

- All results reported in wet weight unless otherwise indicated. (dry = Dry Weight)
- Sample results relate only to the analytes of interest tested and to sample as received by the laboratory.
- Environmental compliance sample results meet the requirements of 35 IAC Part 186 unless otherwise indicated.
- Waste water analysis follows the rules set forth in 40 CFR part 136 except where otherwise noted.
- Accreditation by the State of Illinois is not an endorsement or a guarantee of the validity of data generated.
- For more information about the laboratories' scope of accreditation, please contact us at (708) 544-3260 or the Agency at (217) 782-6455.
- All water analyses that are required to be performed in the field (e.g., pH, residual chlorine, sulfite, temperature, etc.) but are analyzed in the lab are identified as "in lab" and are considered past holding time. Following industry practices these results do not contain an "H" flag but are qualified as being analyzed in the lab.

### Abbreviations:

- Reporting Limit: The concentration at which an analyte can be routinely detected on a day to day basis, and which also meets regulatory and client needs.
- Quantitation Limit: The lowest concentration at which results can be accurately quantitated.
- J: The analyte was positively identified above our Method Detection Limit and is considered detectable and usable; however, the associated numerical value is the approximate concentration of the analyte in the sample.
- ATC: Automatic Temperature Correction. - TNTC: Too Numerous To Count
- TIC: Tentatively Identified Compound (GCMS library search identification, concentration estimated to nearest internal standard).
- SS (Surrogate Standard): Quality control compound added to the sample by the lab.

### Method References:

For a complete list of method references please contact us.

- E: USEPA Reference methods
- SW: USEPA, Test Methods for Evaluating Solid Waste (SW-846)
- M: Standard Methods for the Examination of Water and Wastewater
- USP: Latest version of United States Pharmacopeia

### Workorder Specific Comments:

# SUBURBAN LABORATORIES, Inc.

1950 S. Batavia Ave., Suite 150, Geneva, IL 60134 (708) 544-3260



## Laboratory Results

**Client:** Hygieneering, Inc.

**Report Date:** April 15, 2016

**Project:** 2016-2607 / Westbrook Elementary

**Workorder:** 1604971

**Client Sample ID:** 1333 Rm 28 A

**Matrix:** Drinking Water

**Lab ID:** 1604971-001

**Date Received:** 4/14/2016 14:20 PM

**Collection Date:** 4/13/2016 11:52 AM

Parameter	Result	MCL	Report Limit	Qual	Units	DF	Date Analyzed	BatchID
METALS by ICPMS			Method: EPA-200.8-5.4, 1994			Analyst: jmk		
Lead	ND	15.0	5.00		µg/L	1	4/14/2016 3:25 PM	35598

**Client Sample ID:** 1333 Rm 28 B

**Matrix:** Drinking Water

**Lab ID:** 1604971-002

**Date Received:** 4/14/2016 14:20 PM

**Collection Date:** 4/13/2016 11:52 AM

Parameter	Result	MCL	Report Limit	Qual	Units	DF	Date Analyzed	BatchID
METALS by ICPMS			Method: EPA-200.8-5.4, 1994			Analyst: jmk		
Lead	ND	15.0	5.00		µg/L	1	4/14/2016 3:27 PM	35598

**Client Sample ID:** 1333 Rm 28 C

**Matrix:** Drinking Water

**Lab ID:** 1604971-003

**Date Received:** 4/14/2016 14:20 PM

**Collection Date:** 4/13/2016 11:53 AM

Parameter	Result	MCL	Report Limit	Qual	Units	DF	Date Analyzed	BatchID
METALS by ICPMS			Method: EPA-200.8-5.4, 1994			Analyst: jmk		
Lead	ND	15.0	5.00		µg/L	1	4/14/2016 3:42 PM	35598

# SUBURBAN LABORATORIES, Inc.

1950 S. Batavia Ave., Suite 150, Geneva, IL 60134 (708) 544-3260



## Prep Dates

**Client:** Hygieneering, Inc.

**Report Date:** April 15, 2016  
Original

**Project:** 2016-2607 / Westbrook Elementary

**Workorder:** 1604971

---

Sample ID	Client Sample ID	Collection Date	Prep Batch	Prep Test Name	Leachate Date	Prep Date
1604971-001A	1333 Rm 28 A	4/13/2016 11:52 AM	35598	Turbidity Check		4/14/2016 2:33 PM
1604971-002A	1333 Rm 28 B	4/13/2016 11:52 AM	35598	Turbidity Check		4/14/2016 2:33 PM
1604971-003A	1333 Rm 28 C	4/13/2016 11:53 AM	35598	Turbidity Check		4/14/2016 2:33 PM



**Report Date:** April 15, 2016

**WorkOrder:** 1604971

---

### Qualifiers:

- \* Value exceeds Maximum Contaminant Level
- B Analyte detected in the associated Method Blank
- c Analyte not in SLI scope of accreditation
- C Value is below Minimum Concentration Limit
- E Estimated, detected above quantitation range
- G Refer to case narrative page for specific comments
- H Holding times for preparation or analysis exceeded
- J Analyte detected below quantitation limit (QL)
- N Tentatively identified compound
- ND Not Detected at the Reporting Limit
- P Present
- R RPD outside accepted recovery limits
- S Spike Recovery outside accepted recovery limits
- W Sample container temperature is out of limit as specified at testcode



**SUBURBAN LABORATORIES, Inc.**  
 1950 S Batavia Ave Ste 150 Geneva, IL 60134  
 Tel: 708.544.3260 Fax: 708.544.8587

Tel: 708.544.3260 Fax: 708.544.8587  
 Toll Free: 800.783.1ABS  
 www.suburbanlabs.com

**CHAIN OF CUSTODY RECORD**

# Electronic Version

Company Name: Hygiene-Ring Inc  
 Company Address: 7575 Plaza Court  
 City: Willard brook State: IL Zip: 60527  
 Phone: 630-706-6894 Fax:  Fax Report  
 Email Address: Wofmann@hygiene-ring.com  
 Project ID / Location: 2016-2007 / Westbrook Elementary  
 Project Manager (Report to): Valerie Hofmann  
 Sample Collector(s): Josh Lee

TURNAROUND TIME REQUESTED  
 Normal  RUSH\* \*Additional Rush Charges Approved  
 \*Date & Time Needed: NEXT DAT TAT  
 Normal TAT is 5-7 work days for most work. Rush work must be pre-approved and additional charges apply.  
 Specify Regulatory Program:  None/Info only  
 LUST  SRP  SDWA  
 S03 Sludge  NPDES  MWRDGC  
 Disposal  Other \*Please specify in comment section below.

ANALYSIS & METHOD REQUESTED  
 Enter an "X" in box below for request  
 Method 200.8 Lead

Page 1 of 1  
 PO No. 2016-2007  
 Shipping Method  
 QC Reporting Level:  1  2  3  
**LAB USE ONLY**  
 Sample containers supplied by customer?  Yes  No  
 Temperature of Received Samples: 4 °C  
 Samples received within 24 hours of collection?  Yes  No

SAMPLE IDENTIFICATION	COLLECTION		MATRIX	GRAB/COMP.	CONTAINERS	PRESERVATIVE	ANALYSIS & METHOD REQUESTED	CONDITION CODES
	DATE	TIME						
1 1333-Run28-A	4/13/16	11:52	DW	G	1 1 Liter Plastic		X	002A
2 1333-Run28-B		11:52					X	002A
3 1333-Run28-C		11:53					X	003A
4								
5								
6								
7								
8								
9								
10								
11								
12								

COMMENTS & SPECIAL INSTRUCTIONS:

MATRIX: Drinking Water (DW), Soil (S), Waste Water (WW), Surface Water(SW), Ground Water (GW), Solid Waste (WA), Sludge (L), Wipe (P) CONTAINER: 2oz, 4oz, 8oz, 40ml Vial, 500ml, Liter (L), Tube, Glass (G), Plastic (P) PRESERVATIVE: H<sub>2</sub>SO<sub>4</sub>, HCl, HNO<sub>3</sub>, Methanol (MeOH), NaOH, Sodium Bisulfate (NaB), Nalthio

1. Requisitioned By: Josh Lee Date: 4-14-16  
 2. Requisitioned By: [Signature] Date: 4-14-16  
 3. Requisitioned By: [Signature] Date: 4-14-16  
 4. Requisitioned By: [Signature] Date: 4-14-16

CONDITION CODES  
 1. Improper/damaged container/cap  
 2. Improper preservation  
 3. Insufficient sample volume  
 4. Headspace/air bubbles for VOCs  
 5. Received past holding time  
 6. Received frozen  
 7. Label conflicts with COC

Received By: [Signature] Time: 9:35  Ice  
 Received By: [Signature] Time: 14:20  Ice  
 Received By: [Signature] Time: [Blank]  Ice  
 Received By: [Signature] Time: [Blank]  Ice

Submission of samples subject to Terms and Conditions on back. Rev. 7/20/08 Please fill out this form completely, print, sign & submit with samples. Keep a copy for your records.