



Name of Sampler: Liz Carr
Date Collected: 01/08/2020
School Name: Jason Lee Elementary
School Code: 2786
School District: Richland
School Address: 1750 McMurray Ave, Richland WA 99354
School County: Benton
Number of Samples Collected: 61
School Point of Contact (POC): Jeffrey Lettau
POC Title: Director Facilities & Operations
POC Email: Jeffrey.lettau@rsd.edu
POC Phone Number: 509-578-8381
Date Samples Sent to Lab: 01/08/2020
Date Samples Received by Lab: 01/13/2020
Shipment Tracking Number: 8133 8049 6200, 8133 8049 6211

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
30057	other	other	Blank	<1	01/15/2020	
30058	FirstDraw	Bubbler	Gym	<1	01/15/2020	
30059	FirstDraw	Tap	Kitchen	9	02/04/2020	
30060	FirstDraw	other	Kitchen	<1	01/15/2020	Sample taken from same fixture as sample 30059
30061	FirstDraw	Tap	Health Room	<1	01/15/2020	Aka nursing room
30062	FirstDraw	Tap	Rm 7	<1	01/15/2020	
30063	FirstDraw	Tap	Library	<1	01/15/2020	
30064	FirstDraw	Bubbler	Rm 15	1	01/15/2020	
30065	FirstDraw	Tap	Rm 15	2	01/15/2020	
30066	FirstDraw	Bubbler	Rm 12	<1	01/15/2020	
30068	FirstDraw	Tap	Rm 25	<1	01/15/2020	
30069	FirstDraw	Bubbler	Rm 25	<1	01/15/2020	
30069	FirstDraw	Tap	Rm 24	<1	01/15/2020	
30070	FirstDraw	Tap	Rm 23	<1	01/15/2020	

(continued)

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
30071	FirstDraw	Tap	Rm 22 art room	1	01/15/2020	Left sink
30072	FirstDraw	Tap	Rm 22 art room	<1	01/15/2020	Right Sink
30073	FirstDraw	Tap	Rm 20 staff lounge	<1	01/15/2020	
30074	FirstDraw	Bubbler	First floor north hallway	<1	01/15/2020	Right lower bubbler
30075	FirstDraw	Bubbler	First floor north hallway	<1	01/15/2020	Left bubbler
30076	FirstDraw	Bubbler	Rm 30	1	01/15/2020	
30077	FirstDraw	Tap	Rm 30	3	01/15/2020	
30078	FirstDraw	Bubbler	Rm 31	<1	01/15/2020	
30079	FirstDraw	Tap	Rm 31	1	01/15/2020	
30080	FirstDraw	Bubbler	Rm 32	<1	01/15/2020	
30081	FirstDraw	Tap	Rm 32	1	01/15/2020	
30082	FirstDraw	Bubbler	Rm 33	<1	01/15/2020	
30083	FirstDraw	Tap	Rm 33	<1	01/15/2020	
30084	FirstDraw	Bubbler	Rm 34	<1	01/15/2020	
30085	FirstDraw	Tap	Rm 34	1	01/15/2020	
30086	FirstDraw	Bubbler	Rm 50	<1	01/15/2020	
30087	FirstDraw	Tap	Rm 50	1	01/15/2020	
30088	FirstDraw	Bubbler	Rm 51	<1	01/15/2020	
30089	FirstDraw	Tap	Rm 51	1	01/15/2020	
30090	FirstDraw	Bubbler	Rm 52	<1	01/15/2020	
30091	FirstDraw	Tap	Rm 52	<1	01/15/2020	
30092	FirstDraw	Bubbler	Rm 53	<1	01/15/2020	
30093	FirstDraw	Tap	Rm 53	<1	01/15/2020	
30094	Flush	Bubbler	Rm 54	<1	01/15/2020	
30095	FirstDraw	Tap	Rm 54	<1	01/15/2020	
30096	FirstDraw	Bubbler	Rm 40	<1	01/15/2020	
30097	FirstDraw	Tap	Rm 40	<1	01/15/2020	
30098	FirstDraw	Bubbler	Rm 41	<1	01/15/2020	
30099	FirstDraw	Tap	Rm 41	<1	01/15/2020	

(continued)

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
30100	FirstDraw	Bubbler	Rm 42	<1	01/15/2020	
30101	FirstDraw	Tap	Rm 42	<1	01/15/2020	
30102	FirstDraw	Bubbler	Rm 43	<1	01/15/2020	
30103	FirstDraw	Tap	Rm 43	<1	01/15/2020	
30104	FirstDraw	Bubbler	Rm 44	<1	01/15/2020	
30105	FirstDraw	Tap	Rm 44	1	01/15/2020	
30106	FirstDraw	Bubbler	2nd Floor hallway	<1	01/15/2020	Right lower drinking fountain
30107	FirstDraw	Bubbler	2nd floor hallway	<1	01/15/2020	Left drinking fountain
30108	FirstDraw	Bubbler	Rm 60	<1	01/15/2020	
30109	FirstDraw	Tap	Rm 60	1	01/15/2020	
30110	FirstDraw	Bubbler	Rm 61	<1	01/15/2020	
30111	FirstDraw	Tap	Rm 61	<1	01/16/2020	
30112	FirstDraw	Bubbler	Rm 62	<1	01/16/2020	
30113	FirstDraw	Tap	Rm 62	1	01/16/2020	
30114	FirstDraw	Bubbler	Rm 63	<1	01/16/2020	
30115	FirstDraw	Tap	Rm 63	<1	01/16/2020	
30116	FirstDraw	Bubbler	Rm 64	<1	01/16/2020	
30117	FirstDraw	Tap	Rm 64	<1	01/16/2020	