



Name of Sampler: Liz Carr
Date Collected: 01/07/2020
School Name: William Wiley Elementary
School Code: 4543
School District: Richland
School Address: 2820 S Highlands Blvd, West Richland WA 99353
School County: Benton
Number of Samples Collected: 54
School Point of Contact (POC): Rick Schulte
POC Title: Superintendent
POC Email: Rick.schulte@rsd.edu
POC Phone Number: 509-967-6001
Date Samples Sent to Lab: 01/07/2020
Date Samples Received by Lab: 01/09/2020
Shipment Tracking Number: 8133 8049 6531, 8133 8049 6542

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
29862	FirstDraw	other	Blank	<1	01/10/2020	
29863	FirstDraw	Bubbler	Hallway main entrance	<1	01/10/2020	Bubbler right of hydration station
29864	FirstDraw	Bubbler	Main hallway entrance	<1	01/10/2020	Hydration station
29865	FirstDraw	BottleFiller	Main hallway entrance	<1	01/10/2020	
29866	FirstDraw	Bubbler	Rm 201	<1	01/10/2020	
29867	FirstDraw	Tap	Rm 201	<1	01/10/2020	
29868	FirstDraw	Bubbler	Rm 202	1	01/10/2020	
29869	FirstDraw	Tap	Rm 202	1	01/10/2020	tap leaking
29870	FirstDraw	Bubbler	Rm 203	<1	01/10/2020	
29871	FirstDraw	Tap	Rm 203	<1	01/13/2020	
29872	FirstDraw	Bubbler	Rm 204	<1	01/13/2020	
29873	FirstDraw	Tap	Rm 204	<1	01/13/2020	
29874	FirstDraw	Bubbler	Room 206	3	01/13/2020	
29875	FirstDraw	Tap	Rm 206	1	01/13/2020	
29876	FirstDraw	Tap	Rm 217 art room	<1	01/13/2020	Sink on left

(continued)

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
29877	FirstDraw	Tap	Rm 217 art	1	01/13/2020	Sink on right
29878	FirstDraw	Bubbler	Rm 211 kindergarten	2	01/13/2020	
29879	FirstDraw	Tap	Rm 211 kindergarten	<1	01/13/2020	
29880	FirstDraw	Bubbler	Rm 229	<1	01/13/2020	
29881	FirstDraw	Tap	Rm 229	2	01/13/2020	
29882	FirstDraw	Bubbler	Rm 228	<1	01/13/2020	
29883	FirstDraw	Tap	Rm 228	1	01/13/2020	
29884	FirstDraw	Bubbler	Rm 227	<1	01/13/2020	
29885	FirstDraw	Tap	Rm 227	<1	01/13/2020	
29886	FirstDraw	Bubbler	Rm 226	<1	01/13/2020	
29887	FirstDraw	Tap	Rm 226	<1	01/13/2020	
29888	FirstDraw	Bubbler	South restroom hydration station	<1	01/13/2020	
29889	FirstDraw	BottleFiller	South entrance restroom hydration station	<1	01/13/2020	
29890	FirstDraw	Tap	Kitchen	1	01/13/2020	
29891	FirstDraw	other	Kitchen spray nozzle	<1	01/13/2020	
29892	FirstDraw	Bubbler	Rm 156	1	01/13/2020	
29893	FirstDraw	Tap	Rm 156	<1	01/10/2020	
29894	FirstDraw	Bubbler	Rm 155	1	01/10/2020	
29895	FirstDraw	Tap	Rm 155	<1	01/10/2020	
29896	FirstDraw	Bubbler	Rm 153	1	01/10/2020	
29897	FirstDraw	Tap	Rm 153	1	01/10/2020	Motion tap, we set at cold
29898	FirstDraw	Bubbler	Rm 145	2	01/10/2020	
29899	FirstDraw	Tap	Rm 145	1	01/10/2020	

(continued)

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
29900	FirstDraw	Bubbler	Rm 152	<1	01/10/2020	
29901	FirstDraw	Tap	Rm 152	1	01/10/2020	
29902	FirstDraw	Bubbler	Rm 151	1	01/10/2020	
29903	FirstDraw	Tap	Rm 151	83	01/10/2020	
29904	FirstDraw	Bubbler	Rm 132	2	01/10/2020	
29905	FirstDraw	Tap	Rm 132	12	01/10/2020	
29906	FirstDraw	Bubbler	Rm 131	<1	01/10/2020	
29908	FirstDraw	Bubbler	Rm 129	<1	01/10/2020	
29909	FirstDraw	Tap	Rm 131	1	01/10/2020	Tap leaking
29909	FirstDraw	Tap	Rm 129	1	01/10/2020	
29910	FirstDraw	Bubbler	Rm 134	3	01/10/2020	
29911	FirstDraw	Tap	Rm 134	2	01/10/2020	
29912	FirstDraw	Tap	Rm 136	1	01/10/2020	
29913	FirstDraw	Tap	Nurses Room	1	01/10/2020	
29914	FirstDraw	Tap	Rm 104 Staff Lounge	<1	01/10/2020	
29915	FirstDraw	Tap	Rm 142 music room	1	01/10/2020	