

CLEAN
SAFE
HEALTHY
SCHOOLS

Amity Regional School
District No. 5

25 Newton Road

Woodbridge, CT 06525

Phone: 203-397-4817

Fax: 203-397-4864



Amity Regional School District No. 5

Facilities Department Monthly Report

Completed Projects:

- The replacement of the air handler in the custodial area at Amity Regional High School has been completed. All facets of work are done and it is operating properly.
- The cabinetry and plumbing was removed from the Senior Lounge at Amity Regional High School. This is to facilitate the redesign of the room by students.
- The door to the walk-in cooler in the kitchen at Amity Middle School, Bethany Campus, had warped and become leaky. The internal door heaters had also failed. A new door was ordered and installed by our contractor.
- Both large acid neutralization tanks at Amity Regional High School were serviced during the February break. The old limestone was vacuumed out, the tanks were pressure washed, and new limestone media was put in. As a preventive measure, this is done every two years.
- All required code inspections were conducted during the February break.
- During a preventive maintenance visit, our vendor noticed the check valves on the septic tank system at Amity Middle School, Orange Campus, were sticking. The valves were rebuilt by our vendor.
- The honey bee enclosure at Amity Regional High School was relocated from the rooftop location to a prepared area by the grounds garage. All work was done by in-house personnel.
- The field house at Amity Regional High School had its winter cleaning. Floors were repainted as were the walls to prepare for the new athletic seasons.

Projects in process:

- The newest student-led project of construction of two storage buildings across from the loading dock at Amity Regional High School has commenced. The first building's foundation, floor, roof, walls and partial siding have been installed to date. The roll-up door was also installed. Construction of sections of the second shed has begun.
- Engineering and design has commenced for the Athletic Fields projects at Amity Regional High School.
- It was requested to add a second actor preparation area in the Green Room of the auditorium at Amity Regional High School. Our in-house personnel is repurposing counters and electrical power bars from other locations to accomplish this work.

Outstanding issues to be addressed:

- None at this time.