

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



1 of 2

Facility Information

RESULT: Satisfactory

Permit Number: 35-51-01134
Name of Facility: Mascotte Elementary Charter
Address: 460 Midway Avenue
City, Zip: Mascotte 34753

Correct By: Next Inspection
Re-Inspection Date: None

Type: Public Charter School
Owner: Mascotte Elementary Charter
Person In Charge: Johnson, Nancy Phone: (352) 429-2294
PIC Email: johnsonn1@lake.k12.fl.us

Inspection Information

Purpose: Routine
Inspection Date: 3/11/2020

Begin Time: 12:00 PM
End Time: 01:00 PM

Additional Information

FEMALES 394
MALES 408

CENSUS 802

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

SCHOOL SANITATION	<u>IN</u>	11. Group Toilet Rooms	<u>IN</u>	21. Pest Control
<u>IN</u> 1. School Site	<u>IN</u>	12. Toilet Facilities		SAFETY
<u>IN</u> 2. Playground, Equip & Athletic Fields*	<u>OUT</u>	13. Handwashing Facilities	<u>IN</u>	22. First Aid Kit
<u>IN</u> 3. Athletic & Playground Equipment	<u>IN</u>	14. Soap Dispensers		DIAPER CHANGING STATION
BUILDING CONST/MAINT.	<u>IN</u>	15. Shower Facilities	<u>IN</u>	23. Sanitizers
<u>IN</u> 4. Construction	<u>IN</u>	16. Showers Water Temperatures	<u>IN</u>	24. Changing Station & Mats
<u>OUT</u> 5. Maintenance & Repair		WATER SUPPLY	<u>IN</u>	25. Hand Sink
<u>IN</u> 6. Lighting Standards	<u>IN</u>	17. Approved Source	<u>IN</u>	26. Garbage Can
<u>IN</u> 7. Heating, Ventilation, A/C Standards	<u>IN</u>	18. Drinking Fountains		ANIMAL HEALTH & SAFETY
<u>IN</u> 8. Natural Ventilation		LIQUID WASTE & WASTE WATER	<u>IN</u>	27. Animal Maintenance/Aggressive
<u>IN</u> 9. Mechanical Ventilation	<u>IN</u>	19. Sewage Disposal		DORM/RESIDENTIAL FACILITIES
SANITARY FACILITIES	<u>IN</u>	20. Solid Waste	<u>IN</u>	28. Maintenance/Complaint
<u>IN</u> 10. Provided/Accessible/Separation		PEST CONTROL	<u>IN</u>	29. Other

Marking Key: *IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation*

Violation Key: * = 2. Playground, Equipment & Athletic Fields

General Comments

See Comments. Satisfactory inspection.

Email Address(es): johnsonr@lake.k12.fl.us;
mayhugh-regot@lakr.k12.fl.us;

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

Violations Comments

Violation #5. Maintenance & Repair
Lights in room 113, 148, 139, 201 have burned out bulbs. Bulbs should be replaced.
CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.

Violation #13. Handwashing Facilities
Paper towels empty in room 140.
CODE REFERENCE: 13. Handwashing Facilities. 5(13)(h)1 SREF. Hot and cold water shall be provided in toilet rooms at the lavatory. Hot water temperature shall not exceed 110°F. 468.3.5.7.1 FBC. Handwashing facilities shall be located within or adjoining each toilet room.

Inspection Conducted By: George Hughes (28341)
Inspector Contact Number: Work: (352) 253-6130 ex. 5820
Print Client Name:
Date: 3/11/2020

Inspector Signature:

Handwritten signature of George Hughes.

Client Signature:

Handwritten signature of the client.