



8612 Eagle Creek Parkway, Savage, MN 55378

Tel: (952) 746-5880 ♦ Fax: (952) 746-5882

Mailbox@FieldConsultingInc.com

www.FieldConsultingInc.com

Independent School District #197
1897 Delaware Avenue
Mendota Heights, MN 55118
Attn: Mr. Mark Fenton

RE: Lead in Drinking Water Sampling

SITE: District Office

DATE: December 2018

Dear Mark Fenton,

Field Environmental Consulting, Inc. (FIELD ENVIRONMENTAL) appreciates the opportunity to provide results for lead in drinking water sampling conducted at the District Office.

Initial sampling ("first draw") was completed on Friday, October 5, 2018. Results indicated one (1) fixture, a water cooler/bottle filler, above the action level of 20 ppb (or $\mu\text{g/L}$). ISD #197 Operations Department removed this unit from service and replaced it with a new combination water cooler/bottle filler. FIELD ENVIRONMENTAL re-sampled the new fixture on Friday, November 16, 2018. No lead was detected after fixtures were replaced.

Analysis was conducted by Pace Analytical Services, Inc. of Minneapolis, Minnesota using EPA Method 200.8 ICPMS for determination of trace elements in drinking water.

PREPARED and REVIEWED BY:

Field Environmental Consulting, Inc.

A handwritten signature in cursive script, appearing to read "Amy Weinzierl".

Amy Weinzierl (CSP #27824)

Environmental Health and Safety Manager

amy@fieldconsultinginc.com

952-746-5880

School Name: **District Office (DO)**

Dates: **10/5/2018 & 11/16/2018**

Floor	Room Number	Location	Sample ID	Type DF = Drinking Fountain S = Sink WC = Water Cooler BF = Bottle Filler K=Kettle	Lead Result 10/5/18 (ppb)	Lead Result 11/16/18 (ppb)	Lead Result 30 Sec Flush 11/16/18 (ppb)
First	A147	Lounge	1	S	0.74	-	-
First	A147	Lounge	2	WC	ND	-	-
First	-	Outside BR	3	WC	25.1	ND	ND
First	-	Outside BR	4	BF	39.2	ND	ND

District Office
Lead in Drinking Water
Project # 19010



First Draw Sampling (October 2018)

- ◆ Lead <= 20 ppb
- ◆ Lead > 20 ppb (Action Level)

First Draw Sampling (November 2018)

- Lead <= 20 ppb
- Lead > 20 ppb (Action Level)

Flush Sampling (November 2018)

- ★ Lead <= 20 ppb
- ★ Lead > 20 ppb (Action Level)

