



8612 Eagle Creek Parkway, Savage, MN 55378

Tel: (952) 746-5880 ♦ Fax: (952) 746-5882

Mailbox@FieldConsultingInc.com

www.FieldConsultingInc.com

Independent School District #197
1897 Delaware Avenue
Mendota Heights, MN 55118
Attn: Mr. Mark Fenton

RE: Lead in Drinking Water Sampling
SITE: Transportation Building
DATE: November 16, 2018

Dear Mark Fenton,

Field Environmental Consulting, Inc. (FIELD ENVIRONMENTAL) appreciates the opportunity to provide results for lead in drinking water sampling conducted at the Transportation Building.

Initial sampling ("first draw") was completed on Wednesday, October 3, 2018. All samples were below the action level of 20 ppb (or µg/L).

Analysis was conducted by Pace Analytical Services, Inc. of Minneapolis, Minnesota using EPA Method 200.8 ICPMS for determination of trace elements in drinking water.

PREPARED and REVIEWED BY:

Field Environmental Consulting, Inc.

A handwritten signature in cursive script that reads "Amy Weinzierl".

Amy Weinzierl (CSP #27824)

Environmental Health and Safety Manager

amy@fieldconsultinginc.com

952-746-5880

School Name: **Transportation (TRANS)**

Date: **10/3/2018**

Floor	Room Number	Location	Sample ID	Type DF = Drinking Fountain S = Sink WC = Water Cooler BF = Bottle Filler K=Kettle	Lead Result (ppb)
First	-	Hallway	1	WC	ND
First	-	Men BR	2	S	0.82
First	-	Women BR	3	S	0.99