



Independent School District #197
1897 Delaware Avenue
Mendota Heights, MN 55118
Attn: Mr. Mark Fenton

RE: Short-Term Radon Monitoring
SITE: District Office
DATE: November 2018

Dear Mark Fenton,

Field Environmental Consulting, Inc. (FIELD ENVIRONMENTAL) appreciates the opportunity to provide results for short-term radon monitoring conducted at the District Office.

Radon levels are measured in picocuries per liter or pCi/L. The Environmental Protection Agency (EPA) and the Minnesota Department of Health (MDH) action level for indoor radon is 4.0 pCi/L.

Radon monitoring was conducted using AccuStar® PicoCan 275 short-term open face charcoal canisters (registered device #AC-6048).

Fourteen (14) detectors were analyzed for radon concentration. All samples were below the action level of 4.0 pCi/L. No additional action necessary.

PREPARED and REVIEWED BY:

Field Environmental Consulting, Inc.

Amy Weinzierl (CSP #27824)
Environmental Health and Safety Manager
amy@fieldconsultinginc.com
952-746-5880

NRPP 105011 AL
NRSB ARL0007

EPA Method #402-R-92-004
Charcoal Canister
NRPP Device Code 6048
NRSB Device Code 10317

Laboratory Report for:

Property Tested:

Field Environmental Consulting, Inc.
8612 Eagle Creek Parkway
Savage MN 55378

19055 District Office
1897 Delaware Ave
Mendota Heights MN 55118

Log Number	Device Number	Test Exposure Duration:		Area Tested	Result (pCi/L)
3193049	3803340	11/05/2018 6:00 pm	11/08/2018 2:00 pm	First Floor Room A148D District Office Slot	0.7
3193050	3803394	11/05/2018 6:00 pm	11/08/2018 2:00 pm	First Floor Room A145 Office Near Plant	0.6
3193051	3803396	11/05/2018 6:00 pm	11/08/2018 2:00 pm	First Floor Room A144 Office Files On Desk	0.4
3193052	3803397	11/05/2018 6:00 pm	11/08/2018 2:00 pm	First Floor Room A148B Office Near Doll	1.5
3193053	3803395	11/05/2018 6:00 pm	11/08/2018 2:00 pm	First Floor Room A141 Office Printer	0.4
3193054	3803400	11/05/2018 6:00 pm	11/08/2018 2:00 pm	First Floor Room A142 Office Printer	0.7
3193055	3803399	11/05/2018 6:00 pm	11/08/2018 2:00 pm	First Floor Room A134B Office Files	0.7
3193056	3803398	11/05/2018 6:00 pm	11/08/2018 2:00 pm	First Flr Room A130A Office Behind Computer	1.0
3193057	3803388	11/05/2018 6:00 pm	11/08/2018 2:00 pm	First Floor Room A131 Office Desk	0.9
3193058	3803333	11/05/2018 6:00 pm	11/08/2018 2:00 pm	First Floor Room A132 Office Wood Shelf	0.7

Comment: A copy of this report was emailed to mailbox@fieldconsultinginc.om.

Test Performed By: Amy Weinzierl

Distributed by: Field Environmental Consulting, Inc.

Date Received: 11/10/2018 Date Logged: 11/10/2018 Date Analyzed: 11/10/2018 Date Reported: 11/12/2018

Report Reviewed By: 

Report Approved By: 

Disclaimer:

The uncertainty of this radon measurement is +/- 10 %. Factors contributing to uncertainty include statistical variations, daily and seasonal variations in radon concentrations, sample collection techniques and operation of the dwelling. Interference with test conditions may influence the test results.

This report may only be transferred to a third party in its entirety. Analytical results relate to the samples AS RECEIVED BY THE LABORATORY. Results shown on this report represent levels of radon gas measured between the dates shown in the room or area of the site identified above as "Property Tested". Incorrect information will affect results. The results may not be construed as either predictive or supportive of measurements conducted in any area of this structure at any other time. AccuStar Labs, its employees and agents are not responsible for the consequences of any action taken or not taken based upon the results reported or any verbal or written interpretation of the results.

NRPP 105011 AL
NRSB ARL0007

EPA Method #402-R-92-004
Charcoal Canister
NRPP Device Code 6048
NRSB Device Code 10317

Laboratory Report for:

Property Tested:

Field Environmental Consulting, Inc.
8612 Eagle Creek Parkway
Savage MN 55378

19055 District Office
1897 Delaware Ave
Mendota Heights MN 55118


Log Number	Device Number	Test Exposure Duration:		Area Tested	Result (pCi/L)
3193059	3803404	11/05/2018 6:00 pm	11/08/2018 2:05 pm	First Floor Room A133 Office Awards	1.1
3193060	3803401	11/05/2018 6:00 pm	11/08/2018 2:05 pm	First Floor Room A145 Superintendent Main Offic	0.4
3193061	3803402	11/05/2018 6:00 pm	11/08/2018 2:05 pm	First Floor Room A136 Shelf Near Fridge	0.8
3193062	3803403	11/05/2018 6:00 pm	11/08/2018 2:05 pm	First Floor Room A137 Near Coffee	1.4

Comment: A copy of this report was emailed to mailbox@fieldconsultinginc.om.

Test Performed By: Amy Weinzierl

Distributed by: Field Environmental Consulting, Inc.

Date Received: 11/10/2018 Date Logged: 11/10/2018 Date Analyzed: 11/10/2018 Date Reported: 11/12/2018

Report Reviewed By: 

Report Approved By: 

Disclaimer:

The uncertainty of this radon measurement is +/- 10 %. Factors contributing to uncertainty include statistical variations, daily and seasonal variations in radon concentrations, sample collection techniques and operation of the dwelling. Interference with test conditions may influence the test results.

This report may only be transferred to a third party in its entirety. Analytical results relate to the samples AS RECEIVED BY THE LABORATORY. Results shown on this report represent levels of radon gas measured between the dates shown in the room or area of the site identified above as "Property Tested". Incorrect information will affect results. The results may not be construed as either predictive or supportive of measurements conducted in any area of this structure at any other time. AccuStar Labs, its employees and agents are not responsible for the consequences of any action taken or not taken based upon the results reported or any verbal or written interpretation of the results.

District Office
Short-Term Radon Monitoring
Project #19055



Short-Term Radon (November 2018)

- ◆ Radon < 4 pCi/L
- ◆ Radon ≥ 4 pCi/L

