

# VANDENBERG VILLAGE COMMUNITY SERVICES DISTRICT

3757 Constellation Road • Vandenberg Village • Lompoc, CA 93436  
Telephone: (805) 733-2475 • Fax: (805) 733-2109



*"Pride in Community Service"*

<http://vvcasd.org>  
[info@vvcasd.org](mailto:info@vvcasd.org)

February 8, 2018

Interim Principal Susan Pettis  
Cabrillo High School  
4350 Constellation Road  
Lompoc, CA 93436

**SUBJECT: Lead Test Results**

Dear Ms. Pettis:

On January 10, Vandenberg Village Community Services District (VVCSD) took water samples from four locations within Cabrillo High School's potable water system. Clinical Laboratory of San Bernardino, Inc., analyzed the samples for lead. All four test results were **Not Detected (ND)** for lead.

A recent California law, Assembly Bill 746, requires public water systems like VVCSD to test drinking water at all public K-12 schools with a building constructed before 2010. Detailed information is available at the following website:

[https://www.waterboards.ca.gov/drinking\\_water/certlic/drinkingwater/leadsamplinginschools.shtml](https://www.waterboards.ca.gov/drinking_water/certlic/drinkingwater/leadsamplinginschools.shtml)

EPA has established an action level (AL) of 15 parts per billion (ppb or  $\mu\text{g/l}$ ) for lead. Drinking water with elevated levels of lead can cause behavioral and cognitive issues, as well as headaches and stomach issues. In children, lead consumption can lead to permanent brain damage.

Please contact me at (805) 733-2475 or [mgarner@vvcasd.org](mailto:mgarner@vvcasd.org) if you have questions.

Sincerely,

A handwritten signature in blue ink that reads "Mike Garner" with a long horizontal flourish extending to the right.

Mike Garner  
Operations & Maintenance Manager

Enclosure  
Clinical Laboratory Test Results, Reported 1/29/18

# Clinical Laboratory of San Bernardino, Inc.

Celebrating 50 Years of Analytical Service 1967-2017



<b>Vandenberg Village CSD</b> 3757 Constellation Lompoc CA, 93436	Project: Routine Sub Project: Cabrillo HS Project Manager: Water Quality Supervisor	Work Order: 18A1162 Received: 01/11/18 09:05 Reported: 01/29/18
---	---	---

**C-1** **18A1162-01 (Water)** **Sample Date:** 01/10/18 6:15 **Sampler:** Not Listed

Analyte	Method	Result	Rep. Limit	Action Level	Units	Prepared	Analyzed	Batch	Qualifier
---------	--------	--------	------------	--------------	-------	----------	----------	-------	-----------

<b>Metals</b>									
Lead (Pb)	SM3113-B	ND	5.0	15	ug/L	01/23/18	01/25/18	1804036	

**C-2** **18A1162-02 (Water)** **Sample Date:** 01/10/18 6:20 **Sampler:** Not Listed

Analyte	Method	Result	Rep. Limit	Action Level	Units	Prepared	Analyzed	Batch	Qualifier
---------	--------	--------	------------	--------------	-------	----------	----------	-------	-----------

<b>Metals</b>									
Lead (Pb)	SM3113-B	ND	5.0	15	ug/L	01/23/18	01/25/18	1804036	

**C-3** **18A1162-03 (Water)** **Sample Date:** 01/10/18 6:30 **Sampler:** Not Listed

Analyte	Method	Result	Rep. Limit	Action Level	Units	Prepared	Analyzed	Batch	Qualifier
---------	--------	--------	------------	--------------	-------	----------	----------	-------	-----------

<b>Metals</b>									
Lead (Pb)	SM3113-B	ND	5.0	15	ug/L	01/23/18	01/25/18	1804036	

**C-4** **18A1162-04 (Water)** **Sample Date:** 01/10/18 6:40 **Sampler:** Not Listed

Analyte	Method	Result	Rep. Limit	Action Level	Units	Prepared	Analyzed	Batch	Qualifier
---------	--------	--------	------------	--------------	-------	----------	----------	-------	-----------

<b>Metals</b>									
Lead (Pb)	SM3113-B	ND	5.0	15	ug/L	01/23/18	01/25/18	1804036	

ND Analyte NOT DETECTED at or above the reporting limit

**Gregory Nelson**  
**Project Manager**

18A 1162

# Clinical Lab of San Bernardino, Inc.

21881 Barton Road Grand Terrace CA 92313 909 825-7693 / 516-A N 8th St. Lompoc CA 93436 805 737-7300

## Chain of Custody

WO

Client		Destination Laboratory		Analysis Requested				
VANDENBERG VILLAGE CSD		[ ] Clinical Grand Terrace / ELAP 1098						
Address: 3757 CONSTELLATION RD		[ ] Clinical Lompoc / ELAP 1678						
Lompoc CA 93436		[ ] Other:						
Client Contact: MIKE BARNER		Total Containers		LEAD				
Phone No.: 805 733 2475 FAX No.: 805 733 2109		ZnC4H6O4		✓				
System No.: 4210017		Na2SO3		✓				
Project: CABRILLO HS		NaOH		✓				
Sampled By:		HCl		✓				
Comments:		HNO3						
		C6H8O6						
		NH4Cl						
		Na2S2O3						
		Unpreserved						
		Sample Type						
		Matrix						
		Container ID						
Date	Time	Sample Identification	No. of Preserved Cont.	Matrix	Sample Type	Container ID	Comments	Turn Around Time (TAT)
1/10/16	6:15AM	C-1						
1/10/16	6:20AM	C-2						
1/10/16	6:30AM	C-3						
1/10/16	6:40AM	C-4						
Matrix: DW - Drinking Water GW - Ground Water SW - Surface Water W - Water WW - Wastewater SWR - Stormwater Runoff S - Sludge O - Other		Use for Bacteria Samples / Sample Type: 1-Routine 2-Repeat 3-Replacement 4-Special D-Distribution W-Well		TAT: (10) Ten Day (5) Five Day Rush (2) Two Day Rush				
Relinquished By (Sign)	Print Name / Company	Date / Time	Received By (Sign)	Print Name / Company				
<i>[Signature]</i>	Tim Vandenburgh / VVCS	1/10/16 1:40 PM	<i>[Signature]</i>	Parker / CSB				
<i>[Signature]</i>	Parker / CSB	1-10-16 9:00	<i>[Signature]</i>	KHinkley				
		1-11-16 5:05						

(Lab Use Only) Lompoc Lab Receipt Temp.: 7 °C  
 Shipped Via: [ ] Fed Ex [ ] Golden State Overnight [ ] UPS [ ] OnTrac [ ] USPS [ ] Other  
 Condition: [ ] On Wet Ice [ ] On Blu Ice [ ] Intact [ ] Custody Seals Samples / COC Checked By: Work Order Logged By: Clinical Lab Receipt Temp.: 26 °C  
 Receipt Comments: