


# VANDENBERG VILLAGE COMMUNITY SERVICES DISTRICT

3757 Constellation Road • Vandenberg Village • Lompoc, CA 93436  
Telephone: (805) 733-2475 • Fax: (805) 733-2109



*"Pride in Community Service"*

<http://vvcasd.org>  
[info@vvcasd.org](mailto:info@vvcasd.org)

February 8, 2018

Principal Katy Wallace  
Maple High School  
4010 Jupiter Avenue  
Lompoc, CA 93436

**SUBJECT: Lead Test Results**

Dear Ms. Wallace:

On January 10, Vandenberg Village Community Services District (VVCSD) took water samples from four locations within Maple High School's potable water system. Clinical Laboratory of San Bernardino, Inc., analyzed the samples for lead. All four test results were **Not Detected (ND)** for lead.

A recent California law, Assembly Bill 746, requires public water systems like VVCSD to test drinking water at all public K-12 schools with a building constructed before 2010. Detailed information is available at the following website:

[https://www.waterboards.ca.gov/drinking\\_water/certlic/drinkingwater/leadsamplinginschools.shtml](https://www.waterboards.ca.gov/drinking_water/certlic/drinkingwater/leadsamplinginschools.shtml)

EPA has established an action level (AL) of 15 parts per billion (ppb or µg/l) for lead. Drinking water with elevated levels of lead can cause behavioral and cognitive issues, as well as headaches and stomach issues. In children, lead consumption can lead to permanent brain damage.

Please contact me at (805) 733-2475 or [mgarner@vvcasd.org](mailto:mgarner@vvcasd.org) if you have questions.

Sincerely,

A handwritten signature in blue ink that reads "Mike Garner" with a long horizontal flourish extending to the right.

Mike Garner  
Operations & Maintenance Manager

Enclosure  
Clinical Laboratory Test Results, Reported 1/29/18

# Clinical Laboratory of San Bernardino, Inc.

Celebrating 50 Years of Analytical Service 1967-2017



Vandenberg Village CSD  
3757 Constellation  
Lompoc CA, 93436

Project: Routine  
Sub Project: Maple HS  
Project Manager: Water Quality Supervisor

Work Order: 18A1204  
Received: 01/11/18 09:05  
Reported: 01/29/18

**M-1** **18A1204-01 (Water)** **Sample Date:** 01/10/18 6:45 **Sampler:** Not Listed

Analyte	Method	Result	Rep. Limit	Action Level	Units	Prepared	Analyzed	Batch	Qualifier
---------	--------	--------	------------	--------------	-------	----------	----------	-------	-----------

**Metals**

Lead (Pb) SM3113-B ND 5.0 15 ug/L 01/23/18 01/25/18 1804036

**M-2** **18A1204-02 (Water)** **Sample Date:** 01/10/18 6:55 **Sampler:** Not Listed

Analyte	Method	Result	Rep. Limit	Action Level	Units	Prepared	Analyzed	Batch	Qualifier
---------	--------	--------	------------	--------------	-------	----------	----------	-------	-----------

**Metals**

Lead (Pb) SM3113-B ND 5.0 15 ug/L 01/23/18 01/25/18 1804036

**M-3** **18A1204-03 (Water)** **Sample Date:** 01/10/18 7:10 **Sampler:** Not Listed

Analyte	Method	Result	Rep. Limit	Action Level	Units	Prepared	Analyzed	Batch	Qualifier
---------	--------	--------	------------	--------------	-------	----------	----------	-------	-----------

**Metals**

Lead (Pb) SM3113-B ND 5.0 15 ug/L 01/23/18 01/25/18 1804036

**M-4** **18A1204-04 (Water)** **Sample Date:** 01/10/18 7:20 **Sampler:** Not Listed

Analyte	Method	Result	Rep. Limit	Action Level	Units	Prepared	Analyzed	Batch	Qualifier
---------	--------	--------	------------	--------------	-------	----------	----------	-------	-----------

**Metals**

Lead (Pb) SM3113-B ND 5.0 15 ug/L 01/23/18 01/25/18 1804036

ND Analyte NOT DETECTED at or above the reporting limit

Gregory Nelson  
Project Manager

