



ADDENDUM# 2

EXTERIOR RESTORATION & RELATED WORK AT SEDGWICK MIDDLE SCHOOL Bid # 200028

May 5, 2020

The attention of bidders submitting proposals for the above-referenced project is called to the following Addendum to the specifications. The items set forth herein, whether of omission, addition, substitution or other change, are all to be included in and form a part of the proposed Contract Documents for the work. Bidders shall acknowledge this Addendum in the bid response.

BID OPENING DATE CHANGED:

BIDS ARE DUE THURSDAY MAY 7, 2020 AT 2:00 pm

Response to RFI's received:

Q1: There is a huge discrepancy with the new bid form and the addendum #1. The addendum #1 questions 3 says to cut and point all masonry limestone joints. The bid form allowances for masonry repointing say to carry 400 square feet of masonry pointing and any adds or deducts will be per the unit price. Please advise on what we are to carry.

A1: The Limestone joint repointing is part of the base bid and not part of the 400 square feet of masonry pointing allowance. That's noted on the drawings to repoint ALL Limestone joints, but the brick masonry joints are not noted because they're part of the allowance.

Thank you for your time and consideration.

C: Mike Longo, Facilities Manager
W. Al Jacunski, Jacunski +Humes Architects
John Luby, Enviromed