



AQUA ENVIRONMENTAL LAB

56 Church Hill Road • Newtown, CT 06470 • (203) 270-9973

Report of Analysis

Name:	Parkway School Greenwich Public Schools - Cordes George 290 Greenwich Ave Greenwich, CT 06830-6521	Sample ID#:	246814
Sample Date:	5/29/2020 7:15 AM	Sample Type:	Drinking Water
Receipt Date:	5/29/2020 3:00 PM	Sample Source:	PS022
Report Date:	5/30/2020	Sampler:	PD
Sample Site:	DISTRIBUTION SYSTEM	PWS ID:	CT0570212

Parameter	Sample Result	Units	Method	Minimum Detection Level	Analysis Date	Analyst
Metals						
Copper	0.07	mg/L	EPA 200.5	0.005	5/30/2020	TJB
Lead	0.003	mg/L	EPA 200.5	0.001	5/30/2020	TJB

ND = Not Detected * = Above Specified Limit
--

Report Approved by:  CT Lic PH-0787 NY Lic 11706
 Lab Director

Analytical results relate to the samples as received at the laboratory. Report shall not be reproduced except in its entirety without written approval from the laboratory.