



AQUA ENVIRONMENTAL LAB

56 Church Hill Road • Newtown, CT 06470 • (203) 270-9973

Report of Analysis


Name: Parkway School
 Greenwich Public Schools - Cordes George
 290 Greenwich Ave
 Greenwich, CT 06830-6521

Sample ID#: 246800
Sample Type: Drinking Water
Sample Source: PS004
Sampler: PD
PWS ID: CT0570212

Sample Date: 5/29/2020 7:15 AM
Receipt Date: 5/29/2020 3:00 PM
Report Date: 5/30/2020
Sample Site: DISTRIBUTION SYSTEM

| Parameter | Sample Result | Units | Method | Minimum Detection Level | Analysis Date | Analyst |
|---------------|---------------|-------|-----------|-------------------------|---------------|---------|
| Metals | | | | | | |
| Copper | 0.11 | mg/L | EPA 200.5 | 0.005 | 5/30/2020 | TJB |
| Lead | <0.001 | mg/L | EPA 200.5 | 0.001 | 5/30/2020 | TJB |

ND = Not Detected
 * = Above Specified Limit

Report Approved by:  _____ CT Lic PH-0787 NY Lic 11706
 Lab Director

Analytical results relate to the samples as received at the laboratory. Report shall not be reproduced except in its entirety without written approval from the laboratory.