



AQUA ENVIRONMENTAL LAB

56 Church Hill Road • Newtown, CT 06470 • (203) 270-9973

Report of Analysis

Name: Parkway School
 Greenwich Public Schools - Cordes George
 290 Greenwich Ave
 Greenwich, CT 06830-6521
Sample ID#: 246803
Sample Type: Drinking Water
Sample Source: PS009
Sampler: PD
PWS ID: CT0570212
Sample Date: 5/29/2020 7:15 AM
Receipt Date: 5/29/2020 3:00 PM
Report Date: 5/30/2020
Sample Site: DISTRIBUTION SYSTEM

Parameter	Sample Result	Units	Method	Minimum Detection Level	Analysis Date	Analyst
Metals						
Copper	0.17	mg/L	EPA 200.5	0.005	5/30/2020	TJB
Lead	0.004	mg/L	EPA 200.5	0.001	5/30/2020	TJB

ND = Not Detected
 * = Above Specified Limit

Report Approved by:  _____ CT Lic PH-0787 NY Lic 11706
 Lab Director

Analytical results relate to the samples as received at the laboratory. Report shall not be reproduced except in its entirety without written approval from the laboratory.