



Rockford Board of Education
501 Seventh Street
Rockford, IL 61104

June 8, 2016

Addendum No. 3: 16-59 East High School Pool Renovations and Upgrades

To All Bidders:

Attached are modification, clarifications and/or corrections for the Project Manual and is hereby made a part of the contract documents. Please attach this addendum to the Project Manual(s) in your possession. Please note the receipt of this addendum on the bid form. Bidders shall review changes to all portions of this work as changes to one portion may affect the work of another.

ATTENTION: THE BID OPENING WILL BE CHANGED TO THURSDAY, JUNE 9, 2016 AT 2:00 P.M. (CDST) IN THE 6TH FLOOR CONFERENCE ROOM.

Refer all questions relative to the business aspect, Instructions to Bidders, Special Conditions, and questions concerning the technical aspect of the documents to the Purchasing Process Manager by email at tamara.pugh@rps205.com.

ROCKFORD BOARD OF EDUCATION

By: Tamara Pugh

Purchasing Process Manager

EAST HIGH SCHOOL
POOL RENOVATIONS AND UPGRADES
ROCKFORD PUBLIC SCHOOLS 205
ROCKFORD, ILLINOIS

LARSON & DARBY GROUP

4949 Harrison Avenue, Suite 100
815/484-0739

ARCHITECTURE-ENGINEERING-INTERIORS

P. O. Box 5207, Rockford, IL 61125-0207
FAX 815.229.9867

TO: ALL BIDDERS

RE: ADDENDUM #3

Changes to Bidding Documents Dated April 29, 2016

PROJECT: EAST HIGH SCHOOL
POOL RENOVATIONS AND UPGRADES
ROCKFORD PUBLIC SCHOOLS 205
ROCKFORD, ILLINOIS

PROJECT NO.: 26009

DATE: June 8, 2016

Please attach this Addendum to the Project Manual and Drawings for the referenced project. Take the changes to the Project Manual and Drawings into consideration in preparing your Bid.

Bidders shall make note in writing on Bid Form that this Addendum has been taken into consideration. Failure to do so may be sufficient cause to reject the Bid.

LARSON & DARBY GROUP

By 
Stephen M. Nelson

This Addendum consists of 2 pages.

I. CLARIFICATIONS

- A. Raceways for all wiring in the natatorium, Room Pool 103, including but not limited to speaker wire and fire alarm wiring, shall be in PVC coated galvanized conduit, regardless of whether the Owner accepts the Base Bid ceiling or the Alternate No. 6 ceiling. Light fixture whips shall be liquid-tight flexible metal conduit.
- B. Items removed from the existing building and turned over to the Owner: Contractor shall transport these items to RPS 205 Operations, 1907 Kishwaukee Street, Rockford, IL.

II. ADDITIONS OR CHANGES TO THE PROJECT MANUAL

INVITATION TO BID

- A. Change "Other Key Dates" as follows:

"Tuesday, June 14, 2016; RPS Board Meeting.
Wednesday, June 15, 2016; Award / Notice to Proceed."

DOCUMENT 004100 – BID OFFER FORM

- A. Page 00 41 00-3, COMPLETION TIME: Change paragraphs 1a, 1b, and 1c as follows:

"a. Start Work: June 16, 2016.

EAST HIGH SCHOOL
POOL RENOVATIONS AND UPGRADES
ROCKFORD PUBLIC SCHOOLS 205
ROCKFORD, ILLINOIS

- b. Substantial Completion: September 16, 2016.
- c. Final Completion: September 30, 2016."

SECTION 08 88 10 – FIRE RATED GLASS AND FRAMING

A. Page 08 88 10-2: After paragraph 2.01B1, add the following:

- "C. Subject to compliance with the Contract Documents including mullion spacing and pattern, fire rated glass and framing system by Aluflam is acceptable."

III. ADDITIONS OR CHANGES TO THE DRAWINGS:

DRAWING A1.1

- A. Opening Schedule: Change frame material designations for openings 100A and 100B from "HM" to "Fire-rated glass and framing system". Change frame material designations for all openings except 100A and 100B from "HM" to "SS". Delete paint finish on doors and frames. In "Notes" column, delete all instances of Note 1 and Note 2.
- B. Opening Schedule Notes: Delete Note 1 and Note 2.

DRAWING A7.1

- A. Lintels for each louver opening in masonry shall be two back-to-back L 3-1/2 x 3 x 1/4 galvanized steel angles.
- B. Lintel at opening 103C shall be two back-to-back L 3-1/2 x 3 x 3/8 galvanized steel angles.
- C. Details H3 and J3: In lieu of 1/4-inch stainless steel plate head and jamb closure, provide 0.078-inch thick stainless steel cased openings wrapping around both faces of existing wall to cover cut edge of wall. Fabricate stainless steel cased openings in accordance with specification Section 081119 – STAINLESS STEEL DOORS AND FRAMES. Secure with postinstalled expansion-type jamb anchors.

DRAWING E3.0:

- A. ELECTRICAL SPECIFICATIONS: In Note 21 - Plates, delete "metal wrinkle finish, final color to be selected by Architect."

END OF ADDENDUM #3