



**ROCKFORD BOARD OF EDUCATION
INVITATION FOR BID ON SUPPLIES, MATERIALS, EQUIPMENT OR SERVICES
FOR SCHOOL DISTRICT NO. 205
ROCKFORD, ILLINOIS**

IFB No. 16-62 Washington Academy Renovations - REBID

DATE: Tuesday, June 14, 2016

RE: ADDENDUM NO. 2

To All Bidders:

Attached are modifications, clarifications and/or corrections for the Project Manual and are hereby made a part of the contract documents. Please attach this addendum to the Project Manual(s) in your possession. Please note the receipt of this addendum on the bid form. Bidders shall review changes to all portions of this work as changes to one portion may affect the work of another.

Refer all questions relative to the business aspect, Instructions to Bidders, Special Conditions, and questions concerning the technical aspect of the documents to the Purchasing Process Manager by email at tamara.pugh@rps205.com.

ADDENDUM TWO

Project No.: **15-049**

Date: **June 14, 2016**

Subject: **CHANGES to the BIDDING DOCUMENTS**

Project: **RENOVATIONS TO
WASHINGTON ACADEMY - REBID
ROCKFORD PUBLIC SCHOOLS
ROCKFORD, ILLINOIS**

Bids Due: **2:00PM, THURSDAY, JUNE 16, 2016**

From: **RICHARD L. JOHNSON ASSOCIATES, INC.
4703 CHARLES STREET
ROCKFORD, IL 61108**

To: **ALL PROJECT DOCUMENT HOLDERS**



Please reproduce this Addendum as needed, and attach to the Project Manuals for the above project.

Bidders shall indicate receipt of this and all Addenda in the space provided on the Bid Form. Failure to do so may be sufficient cause to reject the bid.

Sincerely,
RICHARD L. JOHNSON ASSOCIATES, INC.



Scott R. Johnson, AIA, LEED AP

This Addendum consists of:
Pages 1 thru 2.
8 1/2 x 11 Addendum Drawing ADM2.1

NOTE: Wherein this Addendum conflicts with the original Project Manual and Drawings, this Addendum shall govern.

CHANGES to the PROJECT MANUAL

1. RFI QUESTIONS AND ANSWERS


- 1.1. Question - I am writing in regards to the above project and am looking to do a substitution request for the "ALUMINUM WINDOWS," listed under section 085113 in the specification documents. Please see the attached substitution request form, and supporting documentation to the request for Litex Windows.
- 1.2. Answer – Litex Windows is not permitted. The system is not a storefront framing system for the fixed windows as we have specified.

CHANGES to the DRAWINGS

2. SHEET M104

- 2.1. See attached addendum drawing ADM2.1 showing the additional piping insulation required due to asbestos abatement.


END ADDENDUM NUMBER 2



BOILER ROOM - LPS PIPING NEW WORK PLAN

SCALE: 1/4" = 1'-0"

(SHEET M104)



BOILER ROOM - LPS PIPING NEW WORK PLAN

SCALE: 1/4" = 1'-0"

(SHEET M104)



NOTE:

ORIGINAL DRAWINGS SHALL REMAIN IN FORCE EXCEPT FOR CHANGES HERE-IN NOTED

MECHANICAL AND ELECTRICAL RENOVATION WORK FOR
 WASHINGTON ELEMENTARY SCHOOL
 ROCKFORD PUBLIC SCHOOLS

RLJA Richard L. Johnson Associates, Inc.
 architects • interior designers
 4703 Charles Street, Rockford, IL 61108
 815/398-1231 815/398-1280 Fax
 www.rljarch.com

JOB NO. 15-049

ADDENDUM DWG.

DATE: June 6, 2016

ADM2.1