



**ROCKFORD BOARD OF EDUCATION
INVITATION FOR BID ON SUPPLIES, MATERIALS, EQUIPMENT OR SERVICES
FOR SCHOOL DISTRICT NO. 205
ROCKFORD, ILLINOIS**

IFB No. **16-16 Kennedy Middle School Window Replacement**

DATE: **Monday, November 02, 2015**

RE: **ADDENDUM NO. 3**

To All Bidders:

Attached are modifications, clarifications and/or corrections for the Project Manual and are hereby made a part of the contract documents. Please attach this addendum to the Project Manual(s) in your possession. Please note the receipt of this addendum on the bid form. Bidders shall review changes to all portions of this work as changes to one portion may affect the work of another.

**BID OPENING: WEDNESDAY, NOVEMBER 4, 2015 AT 2:00 PM (CST), 501 7TH STREET,
ROCKFORD, IL 61104, 4TH FLOOR CONFERENCE ROOM.**

Refer all questions relative to the business aspect, Instructions to Bidders, Special Conditions, and questions concerning the technical aspect of the documents to the Purchasing Process Manager by email at tamara.pugh@rps205.com.

ADDENDUM THREE

Project No.: **14-044**

Date: **November 2, 2015**

Subject: **CHANGES to the BIDDING DOCUMENTS**

Project: **WINDOW REPLACEMENT FOR
KENNEDY MIDDLE SCHOOL
ROCKFORD PUBLIC SCHOOLS
ROCKFORD, ILLINOIS**

Bids Due: **2:00PM, WEDNESDAY, NOVEMBER 4, 2015**

From: **RICHARD L. JOHNSON ASSOCIATES, INC.
4703 CHARLES STREET
ROCKFORD, IL 61108**


To: **ALL PROJECT DOCUMENT HOLDERS**



Please reproduce this Addendum as needed, and attach to the Project Manuals for the above project.

Bidders shall indicate receipt of this and all Addenda in the space provided on the Bid Form. Failure to do so may be sufficient cause to reject the bid.

Sincerely,
RICHARD L. JOHNSON ASSOCIATES, INC.



Scott R. Johnson, AIA, LEED AP

This Addendum consists of:
Pages 1 thru 2

NOTE: Wherein this Addendum conflicts with the original Project Manual and Drawings, this Addendum shall govern.

GENERAL ITEM

1. QUESTION #1

1.1. "At the Prebid meeting and followed up in Add #1, the mounting surface for shades was to be to the existing exposed wood at the window head UNLESS asbestos ceiling tile was at the window head, then we were to attach to the face of the window mullion.

If ceiling tile is at the window head, but does NOT contain asbestos, do we still attach to the face of the window mullions for a more secure attachment?"

2. ANSWER #1

2.1. Answer is yes if there is ceiling tile or a steel lintel then the window shades are to be mounted to the window mullions, keeping the same installation consistent with in each room.

END ADDENDUM NUMBER 3