



**ROCKFORD BOARD OF EDUCATION
INVITATION FOR BID ON SUPPLIES, MATERIALS, EQUIPMENT OR SERVICES
FOR SCHOOL DISTRICT NO. 205
ROCKFORD, ILLINOIS**

IFB No. **16-39 West Middle School HVAC and Electrical Replacement**

DATE: **Monday, April 04, 2016**

RE: **ADDENDUM NO. 4**

To All Bidders:

Attached are modifications, clarifications and/or corrections for the Project Manual and are hereby made a part of the contract documents. Please attach this addendum to the Project Manual(s) in your possession. Please note the receipt of this addendum on the bid form. Bidders shall review changes to all portions of this work as changes to one portion may affect the work of another.

If you plan to hand deliver your IFB submission on the due date, please note you must check in on the 3rd floor prior to delivering your bid submission. Please allow time for this as late submission will not be accepted.

Refer all questions relative to the business aspect, Instructions to Bidders, Special Conditions, and questions concerning the technical aspect of the documents to the Purchasing Process Manager by email at tamara.pugh@rps205.com.

WEST MIDDLE SCHOOL
HVAC AND ELECTRICAL RENOVATIONS
ROCKFORD PUBLIC SCHOOLS 205
ROCKFORD, ILLINOIS

LARSON & DARBY GROUP

4949 Harrison Avenue, Suite 100
815/484-0739

ARCHITECTS-ENGINEERS-PLANNERS

P. O. Box 5207, Rockford, IL 61125-0207
FAX 815.229.9867

TO: ALL BIDDERS

RE: ADDENDUM #4

Changes to Bidding Documents Dated February 29, 2016

PROJECT: WEST MIDDLE SCHOOL
HVAC AND ELECTRICAL RENOVATIONS
ROCKFORD PUBLIC SCHOOLS 205
ROCKFORD, ILLINOIS

PROJECT NO.: 25107

DATE: April 4, 2016

Please attach this Addendum to the Project Manual and Drawings for the referenced project. Take the changes to the Project Manual and Drawings into consideration in preparing your Bid.

Bidders shall make note in writing on Bid Form that this Addendum has been taken into consideration. Failure to do so may be sufficient cause to reject the Bid.

LARSON & DARBY GROUP

By Stephen Nelson (RAS)
Stephen M. Nelson

This Addendum consists of 1 pages, plus materials itemized herein.

I. ADDITIONS OR CHANGES TO THE PROJECT MANUAL

SPECIFICATIONS SECTION 23 53 13 – BOILER FEEDWATER SYSTEM

- A. REVISE Paragraph 2.1.C.1 to read: "Welded carbon steel." And delete any requirement for galvanization.

END OF ADDENDUM #4