



**ROCKFORD BOARD OF EDUCATION
INVITATION FOR BID ON SUPPLIES, MATERIALS, EQUIPMENT OR SERVICES
FOR SCHOOL DISTRICT NO. 205
ROCKFORD, ILLINOIS**

IFB No. 17-31 Brookview & Bloom Elementary Schools Window Replacement

DATE: Friday, February 24, 2017

RE: ADDENDUM NO. 2

To All Bidders:

Attached are modifications, clarifications and/or corrections for the Project Manual and are hereby made a part of the contract documents. Please attach this addendum to the Project Manual(s) in your possession. Please note the receipt of this addendum on the bid form. Bidders shall review changes to all portions of this work as changes to one portion may affect the work of another.

If you plan to hand deliver your IFB submission on the due date, please note you must check in on the 3rd floor prior to coming to the bid opening. Please allow time for this as late submission will not be accepted.

Refer all questions relative to the business aspect, Instructions to Bidders, Special Conditions, and questions concerning the technical aspect of the documents to the Purchasing Manager by email at tamara.pugh@rps205.com.



4615 E. State Street Suite 206 Rockford Illinois 61108
815 / 397-3330

ADDENDUM NO. 2

Date: February 24, 2017

Project: IFB No. 17-31 Brookview & Bloom Window Replacement Project
Project Number: C1822

To: All Bidders

This addendum is issued to modify, clarify, or correct the original Project Manual and/or Drawings and is hereby made a part of the contract documents. Please attach this addendum to the Project Manual(s) in your possession. Please note the receipt of this addendum on the bid form. Bidders shall review changes to all portions of this work as changes to one portion may affect the work of another.

Changes to the Construction Specifications

1. No changes to specifications

Brookview School Changes to the Construction Drawings

1. No changes to Brookview construction drawings

Bloom School Changes to the Construction Drawings

1. Sheet A1.10 Elevations – 1 North Elevation; Wall Section Tag 1/A1.15 & 1 Sim./A1.15 to Read as Follows: 1/A2.15 & 1 Sim./A2.15.

BN-RFI: 01 – Bloom Elementary School Construction Drawing:

REQUEST:

Subject: Bloom ES Roller Shades RFI

Dwg. A1.00 indicates "W4" window at two "Stairs" and one "Corridor"
"W5" window at one "Corridor"

Dwg. A1.11 notes "NO SHADE REQUIRED" at Window Type W4 ONLY.

Are shades to be EXCLUDED from "Stairs" ONLY?

Are shades to be included in "Corridor" at Window Type W5?

Are shades to be EXCLUDED in "Stairs" AND "Corridor"?

Regards,

Roger Stoeckel, Owner
Shade Aire Company
7511 Grace Dr.
Roscoe, IL 61073
815 623-7597
815 623-8541 fax
815 543-0612 cell

RESPONSE:

No shades required for Window Type W4 – Which is in the Stairways all other windows to have shades.

See the following attachments

N/A

End of Addendum #2