

RENOVATIONS TO STERLING HOLLEY CENTER
ROCKFORD PUBLIC SCHOOL DISTRICT 205
ROCKFORD, ILLINOIS

LARSON & DARBY GROUP

4949 Harrison Avenue, Suite 100
815/484-0739

ARCHITECTS-ENGINEERS-PLANNERS

P. O. Box 5207, Rockford, IL 61125-0207
FAX 815.229.9867

TO: ALL BIDDERS

RE: ADDENDUM #2

Changes to Bidding Documents Dated November 3, 2016

PROJECT: RENOVATIONS TO STERLING HOLLEY CENTER
ROCKFORD PUBLIC SCHOOLS 205
ROCKFORD, ILLINOIS

PROJECT NO.: 25011-06

DATE: November 28, 2016

Please attach this Addendum to the Project Manual and Drawings for the referenced project. Take the changes to the Project Manual and Drawings into consideration in preparing your Bid.

Bidders shall make note in writing on Bid Form that this Addendum has been taken into consideration. Failure to do so may be sufficient cause to reject the Bid.

LARSON & DARBY GROUP

By _____
Stephen M. Nelson

This Addendum consists of 1 page, plus materials itemized herein.

I. GENERAL CLARIFICATIONS

A. The following is clarified in response to RFI submitted by contractor:

- a. Clarification: Under the base bid, the gas piping shown on sheet P1.1 shall be capped right after the connection to SUH-1 for future piping.
- b. Clarification: The gas piping to relocated MAU shown on sheet P1.2 shall be required only if the alternate bid (M-1) for relocating MAU is accepted. It is not required under the base bid.

II. ADDITIONS OR CHANGES TO THE PROJECT MANUAL

None

III. ADDITIONS OR CHANGES TO THE DRAWINGS

None

END OF ADDENDUM #2



2279 Yellow Creek Road
P.O. Box 690
Freeport, IL 61032
Phone: (815) 297-6042
FAX (815) 297-9075

Request for Information

To:	RPS 205	From:	Mechanical Inc.
Att:	Tamara Pugh	Pages:	1
E-Mail	tamara.pugh@rps205.com	Date:	11/24/2016
Re:	Sterling Holley Center	CC:	File

Urgent For review Comment Please reply

Please clarify the following:

1. Drawing P1.1 is showing gas piping running to Emergency Generator. If Alt. M-2 is not accepted do we still need to run the gas pipe to that area as shown and or at what point should we cap the gas pipe for base bid? Will this change gas pipe size?
2. Drawing P1.2 is showing gas to the relocated MAU which is an alternate. Should the new 2" pipe that is being tied into the existing be in base bid or included in the alternate price?

1. Under the base bid, the gas piping shown on sheet P1.1 shall be capped right after the connection to SUH-1 for future piping.
2. The gas piping to relocated MAU shown on sheet P1.2 shall be required only if the alternate bid (M-1) for relocating MAU is accepted. It is not required under the base bid.

Raed Salem
Larson & Darby Group
11-28-2016