



**ROCKFORD BOARD OF EDUCATION
INVITATION FOR BID ON SUPPLIES, MATERIALS, EQUIPMENT OR SERVICES
FOR SCHOOL DISTRICT NO. 205
ROCKFORD, ILLINOIS**

IFB No. **17-21 Mechanical & Electrical Upgrades for Thurgood Marshall Middle School**

DATE: **Friday, January 6, 2017**

RE: **ADDENDUM NO. 2**

To All Bidders:

Attached are modifications, clarifications and/or corrections for the Project Manual and are hereby made a part of the contract documents. Please attach this addendum to the Project Manual(s) in your possession. Please note the receipt of this addendum on the bid form. Bidders shall review changes to all portions of this work as changes to one portion may affect the work of another.

If you plan to hand deliver your IFB submission on the due date, please note you must check in on the 3rd floor prior to coming to the bid opening. Please allow time for this as late submission will not be accepted.

Refer all questions relative to the business aspect, Instructions to Bidders, Special Conditions, and questions concerning the technical aspect of the documents to the Purchasing Manager by email at tamara.pugh@rps205.com.

ADDENDUM TWO

Project No.: **RPS# 17-21**

Date: **January 6, 2017**

Subject: **CHANGES to the BIDDING DOCUMENTS**

Project: **MECHANICAL AND ELECTRICAL UPGRADES TO MARSHALL MIDDLE SCHOOL
ROCKFORD PUBLIC SCHOOLS
ROCKFORD, ILLINOIS**

Bids Due: **2:00PM, TUESDAY, JANUARY 10, 2017**


From: **RICHARD L. JOHNSON ASSOCIATES, INC.
4703 CHARLES STREET
ROCKFORD, IL 61108**

To: **ALL PROJECT DOCUMENT HOLDERS**

Please reproduce this Addendum as needed, and attach to the Project Manuals for the above project.

Bidders shall indicate receipt of this and all Addenda in the space provided on the Bid Form. Failure to do so may be sufficient cause to reject the bid.

Sincerely,
RICHARD L. JOHNSON ASSOCIATES, INC.



Scott R. Johnson, AIA, LEED AP

This Addendum consists of:
Pages 1 thru 2.

NOTE: Wherein this Addendum conflicts with the original Project Manual and Drawings, this Addendum shall govern.

GENERAL ITEMS

1. QUESTION #1

1.1. "Would you please let me know if the roof is under warranty?".

If ceiling tile is at the window head, but does NOT contain asbestos, do we still attach to the face of the window mullions for a more secure attachment?"

2. ANSWER #1

2.1. The roof area where work is taking place is out of warranty.

END ADDENDUM NUMBER 2