



**ROCKFORD BOARD OF EDUCATION
INVITATION FOR BID ON SUPPLIES, MATERIALS, EQUIPMENT OR SERVICES
FOR SCHOOL DISTRICT NO. 205
ROCKFORD, ILLINOIS**

IFB No. 17-23 Washington Academy Window Replacement

DATE: Friday, January 27, 2017

RE: ADDENDUM NO. 2

To All Bidders:

Attached are modifications, clarifications and/or corrections for the Project Manual and are hereby made a part of the contract documents. Please attach this addendum to the Project Manual(s) in your possession. Please note the receipt of this addendum on the bid form. Bidders shall review changes to all portions of this work as changes to one portion may affect the work of another.

If you plan to hand deliver your IFB submission on the due date, please note you must check in on the 3rd floor prior to coming to the bid opening. Please allow time for this as late submission will not be accepted.

Refer all questions relative to the business aspect, Instructions to Bidders, Special Conditions, and questions concerning the technical aspect of the documents to the Purchasing Process Manager by email at tamara.pugh@rps205.com.



ADDENDUM TWO

Project No.: **16-062**

Date: **January 27, 2017**

Subject: **CHANGES to the BIDDING DOCUMENTS**

Project: **WINDOW REPLACEMENT PROJECT FOR
WASHINGTON ACADEMY
ROCKFORD PUBLIC SCHOOLS
ROCKFORD, ILLINOIS**

Bids Due: **2:00PM, THURSDAY, FEBRUARY 2, 2017**


From: **RICHARD L. JOHNSON ASSOCIATES, INC.
4703 CHARLES STREET
ROCKFORD, IL 61108**

To: **ALL PROJECT DOCUMENT HOLDERS**

Please reproduce this Addendum as needed, and attach to the Project Manuals for the above project.

Bidders shall indicate receipt of this and all Addenda in the space provided on the Bid Form. Failure to do so may be sufficient cause to reject the bid.

Sincerely,
RICHARD L. JOHNSON ASSOCIATES, INC.



Scott R. Johnson, AIA, LEED AP

This Addendum consists of:
Pages 1 thru 2.

NOTE: Wherein this Addendum conflicts with the original Project Manual and Drawings, this Addendum shall govern.

CHANGES to the PROJECT MANUAL

1. GENERAL ITEMS

1.1. The asbestos contractor will be removing ceilings as required for them to demo the existing window systems. Where the ceiling comes flat across and dies into the top of the window frame, the intent is that the asbestos contractor will remove the lay-in ceiling system back to the closest ceiling grid and set aside. The window contractor shall re-install the existing ceilings after the windows are installed. Where the ceilings come flat across and then turn vertical at the windows and then back flat to the windows, the intent is that the asbestos contractor will remove the ceilings including the vertical back to the first ceiling grid and set aside. The window contractor shall re-install the existing ceilings after the windows are installed in similar locations.

2. SPECIFICATION SECTION ROLLER WINDOW SHADES 100413

2.1. Page 100413-3,2.2,A.3.a: Remove "3000 Series" fabric.

3. QUESTIONS AND ANSWERS

3.1. Question 1 - Would you accept an architectural window system in lieu of a storefront system?

3.2. Answer 1 - No. The window system needs to be storefront so it matches the new windows being installed in the rest of the building.

END ADDENDUM NUMBER 2